



Himachal Pradesh

Public Works Department

Office of the Assistant Engineer, Electrical Sub-Division, HPPWD, Solan

Web. WWW.hppwd.gov.in E-mail: esdhppwdsolan01@gmail.com Phone/Fax No. 01792-223860

No. PW-ESD-Tender/2025-26- 466-69
To

Dated:- 21-02-2026


The Executive Engineer (IT),
HPPWD, Nirman Bhawan,
Nigam Vihar, Shimla-171002.

Subject: - Publication of Tender Notice.

Respected Sir,

Enclosed please find herewith the tender notice of works as given in the notice inviting Tender No. PW-ESD-Tender/2025-26- 454-65 Dated 21-02-2026 for uploading on department web site as per Notification vide Secy. (PW) to the Govt. of Himachal Pradesh letter No. PBW (B) A (3) 1/2024 dated 03-01-2024 as the works mentioned in the Tender Notice are urgent in nature and public interest.


Encl. :- As above.


Assistant Engineer,
Electrical Sub-Division,
HP. PWD, Solan.

Copy to the Superintending Engineer, 1st Electrical Circle, HPPWD, Shimla-9 for information please.

Copy to the Computer Cell O/o the Executive Engineer, (IT Cell), Nirman Bhawan, Nigam Vihar, Shimla-2 for information with request for uploading the tenders on department website as per notification given above please.

Copy to the Executive Engineer, Electrical Division No. 1, HPPWD, Shimla-09 for information please.


Assistant Engineer,
Electrical Sub-Division,
HP.PWD, Solan.

Himachal Pradesh
Public Works Department

Notice Inviting Tender

Sealed percentage rate tender on form 6 & 8 are invited by the Assistant Engineer, Electrical Sub- Division HPPWD Solan for the following works from the approved and eligible contractors enlisted in HPPWD, so as reach in thois office as per time schedule given below. The undersigned reserves the right to accept/reject any application/tender or all the tender without assigning qany reason.

Date of Receipts of application for Tender form
Date of Issue/sale of Tender Forms
Date of Opening of Tender

02-03-2026 upto 12:00 PM
02-03-2026 From 11:00 AM to 1:00 PM
03-03-2026 at 11:00 AM

The tender shall be received upto 10:30 on 03-03-2026 and will be opened on the same day at 11:00 AM in the presense of intending contractors or their authorized representative who may like be present . The tender form can be received from this office against cash payment [Non refundable] up to 1:00 P.M on dated 02-03-2026.

The earnest money in the shape of national saving certificate/time deposit account /saving account in any of the post office in HP duly pledged in favour of Executive Engineer must accompanying with each application. The conditional tenders, application for tender received without earnest money will simultaneously be rejected.

Sr. No.	Name of work.	Estimated Cost.	EMD	Form Cost	Time Period
1	Annual Repair and Maintenance (AMC) of Air Conditioners installed in 1 st Floor of Himachal Pradesh Sewa Sadan Building at sector 25 West Chandigarh for the Year 2025-26.	97,800/-	2000/-	350/-	One Year
2	Annual Repair and Maintenance (AMC) of Air Conditioners installed in 2nd Floor of Himachal Pradesh Sewa Sadan Building at sector 25 West Chandigarh for the Year 2025-26.	98,000/-	2000/-	350/-	One Year
3	Providing Earthing and Electrical accessories at DIET building Solan Tehsil & Distt. Solan for the Year 2025-26.	98,533/-	2000/-	350/-	One month
4	Providing Electrical Wiring and accessories in various N/R buildings under ESD HPPWD, Solan (Section Parwanoo) District Solan HP	98,961/-	2000/-	350/-	Two month
5	Providing Electrical Wiring and accessories in various N/R buildings under ESD HPPWD, Solan (Section Solan) District Solan HP	99,681/-	2000/-	350/-	Two month
6	Providing Electrical accessories in Rajasav Sadan aty Kotla Nala Tehsil & District Solan HP	99,620/-	2000/-	350/-	One month

Certified that Tender of above works are being called on emergent nature in exigency of public interest .

Assistant Engineer,
Elect. Sub-Division,
HPPWD Solan
Dated:- 21-02-2026

NO.PW-ESD-Tender/2025-26- 454-65
Copy forwarded to the :

- 1 Engineer- in-chief Nirman Bhavan HPPWD Shimla for information please.
- 2 Superintending Engineer Elect. Wing Shimla -9 for information please.
- 3 Executive Engineer Elect. Division No 1 HPPWD Shimla 9 for information please.
- 4 All the Executive Engineer in Elect wing.
- 5 Assistant Engineer Elect. Sub Division NO 1, No 2, and Nahan.
- 5 President contractors association
- 7 All the approved contractors in Elect.
- 8 Notice Board.


Assistant Engineer,
Elect. Sub-Division,
HPPWD Solan.

Estimated cost Rs.97800/=
 Earnest Money Rs.2000/=


Time Period . One year

SCHEDULE OF QUANTITY						
Name of Work :- Annual Repair and Maintenance (AMC) of Air Conditioners installed in 1st floor of Himachal Pradesh Sewa Sadan building at Sector 25 West Chandigarh for the year 2025-						
Sr.No	items	Description of	Qty.	Rate	Unit	Amount
1	AMC of Air Conditioner of different types and capacity installed in Himachal Pradesh Sewa Sadan building at Sector 25 West Chandigarh. This includes all types of spare parts to be replaced and 3 Nos Services during the year, rewinding of compressor motor, replacement of where necessary and refilling of gas etc.as required and as directed by the Engineer-in-charge.					
A	Window type air conditioner 1.5 tonne capacity.		20	4500	Each	90000
2	Replacement/repair of voltage stabilizer and PCB of air co		4	1950	Each	7800
Total:-						97800

It is certified that tender is being called on emergency nature in urgency of public interest.


 Assistant Engineer
 Electrical Division,
 HPPW, Shimla

DNIT No for the year 2025-26 duly approved for Rs 97800/- only


 Executive Engineer,
 Electrical Division No-1,
 HPPW Kasumpti, Shimla-9

Estimated cost Rs.98000/=

Earnest Money Rs.2000/=

Time Period . One year

SCHEDULE OF QUANTITY

Sr.No	Description of	Qty.	Rate	Unit	Amount
1	AMC of Air Conditioner of different types and capacity installed in Himachal Pradesh Sewa Sadan building at Sector 25 West Chandigarh. This includes all types of spare parts to be replaced and 3 Nos Services during the year, rewinding of compressor motor, replacement of where necessary and refilling of gas etc.as required and as directed by the Engineer-in-charge.				
A	Tower type Air conditioner 2.0 tonne capacity	1	4700	Each	4700
B	Window type air conditioner 1.5 tonne capacity.	19	4500	Each	85500
2	Replacement/repair of voltage stabilizer and PCB of air co	4	1950	Each	7800
Total:-					98000

It is certify that tender is being called on emergency nature in exigency of public interest.

[Signature]
 Assistant Engineer
 Electrical Sub-Division,
 HPPWD Solan

DN17 No for the year 2025-26 duly approved for Rs. 978000/-


[Signature]
 Executive Engineer,
 Electrical Division No-1,
 HPPWD, Kasumpti, Shimla-9


Estimated Cost Rs 98533/=
 Earnest Money Rs 2000/=
 Time Period 1 month

SCHEDULE OF QUANTITY						
Name of Work:- Providing earthing & electrical accessories at DIET building Solan Tehsil & Distt. Solan HP.						
Sr.No	Description of items	Quantity	Rate	Unit	Amount	Remarks
1	Earthing with copper earth plate 600 mm X 600 mm X 3 mm thick including accessories, and providing masonry enclosure with cover plate having locking arrangement and watering pipe of 2.7 metre long etc. with charcoal/ coke and salt as required.	2	13689	P/set	27378	A.R
2	Providing and fixing 25 mm X 5 mm copper strip on surface or in recess for connections etc. as required.	40	1167	P/mtr	46680	A.R
3	Providing & Laying of one number aluminium conductor, PVC insulated and PVC sheathed armoured/ XLPE power cable, 1.1 KV grade of following sizes on wall surface as required.					
a	Armoured cable 25 sq. mm (3.5 core)	55	445	Each	24475	A.R
	Total				98533	

It is certified that the tender is being called on emergency basis in emergency of public interest.

Draft Schedule of Quantity Approved for Rs. 98,533/= (Rupees; Ninety eight thousand five hundred thirty three) only


 Assistant Engineer
 Electrical Sub-Division,
 HPPWD Solan


 Executive Engineer,
 Electrical Division No-1,
 HPPWD, Kasumpti, Shimla-9

Estimated cost Rs.98961/=

Earnest Money Rs.2000/=

Time Period . 2 month

SCHEDULE OF QUANTITY

Name of Work :- Providing electrical wiring and electrical accessories in various N/R buildings under ESD HPPWD Solan (Section Parwanoo), District Solan HP.

Sr.No	Description of items	Qty.	Rate	Unit	Amount
1	Wiring for light point/ fan point/ exhaust fan point/ call bell point with 1.5 sq.mm FRLS PVC insulated copper conductor single core cable in surface / recessed medium class PVC conduit, with modular switch, modular plate, suitable GI box and earthing the point with 1.5 sq.mm FRLS PVC insulated copper conductor single core cable etc. as required..Group C	8	1283	Each	10264
2	Wiring for circuit/ submain wiring alongwith earth wire with the following sizes of FRLS PVC insulated copper conductor, single core cable in surface/ recessed medium class PVC conduit as required.				
a	2 X 1.5 sq. mm + 1 X 1.5 sq. mm earth wire	80	209	P/mtr	16720
b	2 X 4 sq. mm + 1 X 4 sq. mm earth wire	60	315	P/mtr	18900
c	2 X 10 sq. mm + 1 X 6 sq. mm earth wire	12	558	P/mtr	6696
3	Supplying and drawing following sizes of FRLS PVC insulated copper conductor, single core cable in the existing surface/ recessed steel/ PVC conduit as required.				
a	3x1.5 Sq. mm.	20	93	P/mtr	1860
b	3x4.0 Sq. mm.	40	205	P/mtr	8200
4	Supplying and fixing of following sizes of medium class PVC conduit along with accessories in surface/recess including cutting the wall and making good the same in case of recessed conduit as required.:-25 mm. dia	50	125	P/mtr	6250
5	Supplying and fixing suitable size GI box with modular plate and cover in front on surface or in recess, including providing and fixing 3 pin 5/6 A modular socket outlet and 5/6 A modular switch, connections etc. as required.	6	431	Each	2586
6	Supplying and fixing suitable size GI box with modular plate and cover in front on surface or in recess, including providing and fixing 6 pin 5/6 & 15/16 A modular socket outlet and 15/16 A modular switch, connections etc. as required.	6	544	Each	3264
7	S/E of LED Downlighter surface square with CRCA/PDC body and diffuser The fitting should be installed on existing surface The job includes carriage, erection, making connections testing and commissioning of the fittings.				


	Wattage of LED fittings-As per following parameter.						
	Total lumens of the fittings.-as below						
	Diffuser - Polycarbonate diffuser/PMMA						
	Operating voltage =140 V to 270 V, AC supply or better.						
	Input frequency =50 Hz + 1 Hz						
	Power factor =Minimum 0.90						
	Luminaire efficacy =>85 lm/w						
	Color rendering index=CRI shall be greater than 80						
	Working/ operating temperature =0 o to + 45 oc or better						
	Color temperature =6000K + 10%						
	Electronic Driver						
	Drive current (LED)=As per OEM.						
	Operating voltage =140 V to 270 V, AC supply or better.						
	Type of driver =Constant current output driver						
	THD =Less than 10%						
	Surge Protection =2.5 KV minimum						
	Efficiency Driver=>85%						
	Protection=Shall have under voltage and over voltage protection.						
	Guarantee of LED fittings including LED driver =2 years against manufacturing defect.						
	Fixture =Should comply with LM 79 test from UL/NABL lab.						
	LED Type/ Make/ Model-Power CREE/ OSRAM/ NICHIA/ Philips LUMILED with life more than 50,000 burning hours @70% lumen maintenance complying with LM 80 test report from the manufacturer.						
	Life of LED=50000 burning hours at 70% lumen maintenance						
a	Lumen output of the fitting=>1500 Lumens	7	1735	Each	12145		
8	S/E of LED Batten with polycarboante body and diffuser The fitting should be installed on existing surface/recess The job includes carriage, erection, making connections testing and commissioning of the fittings.Specification of LED fittings:						
	Wattage of LED fittings-As per following parameter.						
	Total lumens of the fittings.-as below						
	Diffuser - Polycarbonate diffuser/PMMA						
	Operating voltage =140 V to 270 V, AC supply or better.						
	Input frequency =50 Hz + 1 Hz						

	Power factor =Minimum 0.90				
	Luminaire efficacy => 100 lm/w				
	Color rendering index=CRI shall be greater than 80				
	Working/ operating temperature =00 to + 450c or better				
	Color temperature =60000K + 10%				
	Electronic Driver				
	Drive current (LED)=As per OEM.				
	Operating voltage =140 V to 270 V, AC supply or better.				
	Type of driver =Constant current output driver				
	THD =Less than 10%				
	Surge Protection =2.5 KV minimum				
	Efficiency Driver=>85%				
	Protection=Shall have under voltage and over voltage protection.				
	Guarantee of LED fittings including LED driver =2 years against manufacturing defect.				
	Fixture =Should comply with LM 79 test from UL/NABL lab.				
	LED Type/ Make/ Model-Power CREE/ OSRAM/ NICHIA/ Philips LUMILED with life more than 25,000 burning hours @70% lumen maintenance complying with LM 80 test report from the manufacturer.				
	Life of LED=25000 burning hours at 70% lumen maintenance				
a	Lumen output of the fitting=>2000 Lumens	12	631	Each	7572
9	S/E of LED bulk head IP 66 rated with aluminium body/PDC housing The fitting should be installed on existing surface The job includes carriage, erection, making connections testing and commissioning of the fittings. Wattage of LED fittings-As per following parameter. Total lumens of the fittings.-as below Diffuser - Polycarbonate diffuser/PMMA Operating voltage =140 V to 270 V, AC supply or better. Input frequency =50 Hz + 1 Hz Power factor =Minimum 0.90 Luminaire efficacy =>80 lm/w Color rendering index=CRI shall be greater than 80 Working/ operating temperature =00 to + 450c or better Color temperature =60000K + 10% Electronic Driver				

Drive current (LED)=As per OEM.					
Operating voltage = 140 V to 270 V, AC supply or better.					
Type of driver =Constant current output driver					
THD =Less than 10%					
Surge Protection =2 KV minimum					
Efficiency Driver=>85%					
Protection=Shall have under voltage and over voltage protection.					
Guarantee of LED fittings including LED driver =2 years against manufacturing defect.					
Fixture =Should comply with LM 79 test from UL/NABL lab.					
LED Type/ Make/ Model-Power CREE/ OSRAM/ NICHIA/ Philips LUMILED with life more than 50,000 burning hours @70% lumen maintenance complying with LM 80 test report from the manufacturer.					
Life of LED=50000 burning hours at 70% lumen maintenance					
a Lumen output of the fitting=>800 Lumens	4	1126	Each	4504	
			Total:-		98961

It is certified that the tender is being called on emergency basis in emergency of public interest.

Draft Schedule of Quantity approved for Rs. 98,961/-
(Rupees; ninety eight thousand nine hundred sixty one) only


Assistant Engineer
Electrical Sub-Division
HPPWD Solan


Executive Engineer,
Electrical Division No-1,
HPPWD, Kasumpti, Shimla-9

Estimated Cost Rs.99681/=
Earnest Money Rs.2000/=
Time Period . 2 month

SCHEDULE OF QUANTITY

Name of Work :- Providing electrical wiring and electrical accessories in various N/R buildings under ESD HPPWD Solan (Section Solan), District Solan HP.

Sr.	Description of items	Qty.	Rate	Unit	Amount
1	Wiring for light point/ fan point/ exhaust fan point/ call bell point with 1.5 sq.mm FRLS PVC insulated copper conductor single core cable in surface / recessed medium class PVC conduit, with modular switch, modular plate, suitable GI box and earthing the point with 1.5 sq.mm FRLS PVC insulated copper conductor single core cable etc.Group C	20	1283	Each	25660
2	Wiring for circuit/ submain wiring alongwith earth wire with the following sizes of FRLS PVC insulated copper conductor, single core cable in surface/ recessed medium class PVC conduit as required.				
a	2 X 1.5 sq. mm + 1 X 1.5 sq. mm earth wire	100	209	P/mtr	20900
b	2 X 4 sq. mm + 1 X 4 sq. mm earth wire	35	315	P/mtr	11025
c	2 X 10 sq. mm + 1 X 6 sq. mm earth wire	20	558	P/mtr	11160
3	Supplying and drawing following sizes of FRLS PVC insulated copper conductor, single core cable in the existing surface/ recessed steel/ PVC conduit as required.				
a	3x1.5 Sq. mm.	20	93	P/mtr	1860
b	3x4.0 Sq. mm.	20	205	P/mtr	4100
4	Supplying and fixing of following sizes of medium class PVC conduit along with accessories in surface/recess including cutting the wall and making good the same in case of recessed conduit as required.:-25 mm. dia	40	125	P/mtr	5000
5	Supplying and fixing suitable size GI box with modular plate and cover in front on surface or in recess, including providing and fixing 3 pin 5/6 A modular socket outlet and 5/6 A modular switch, connections etc. as required.	10	431	Each	4310
6	Supplying and fixing suitable size GI box with modular plate and cover in front on surface or in recess, including providing and fixing 6 pin 5/6 & 15/16 A modular socket outlet and 15/16 A modular switch, connections etc. as required.	5	544	Each	2720
7	S/E of LED Downlighter surface square with CRC/APDC body and diffuser The fitting should be installed on existing surface The job includes carriage, erection, making connections testing and commissioning of the fittings.				
	Wattage of LED fittings-As per following parameter.				


	Total lumens of the fittings.-as below				
	Diffuser - Polycarbonate diffuser/PMMA				
	Operating voltage =140 V to 270 V, AC supply or better.				
	Input frequency =50 Hz + 1 Hz				
	Power factor =Minimum 0.90				
	Luminaire efficacy =>85 lm/w				
	Color rendering index=CRI shall be greater than 80				
	Working/ operating temperature =0 o to + 45 oc or better				
	Color temperature =6000K + 10%				
	Electronic Driver				
	Drive current (LED)=As per OEM.				
	Operating voltage =140 V to 270 V, AC supply or better.				
	Type of driver =Constant current output driver				
	THD =Less than 10%				
	Surge Protection =2.5 KV minimum				
	Efficiency Driver=>85%				
	Protection=Shall have under voltage and over voltage protection.				
	Guarantee of LED fittings including LED driver =2 years against manufacturing defect.				
	Fixture =Should comply with LM 79 test from UL/NABL lab.				
	LED Type/ Make/ Model-Power CREE/ OSRAM/ NICHIA/ Philips LUMILED with life more than 50,000 burning hours @70% lumen maintenance complying with LM 80 test report from the manufacturer.				
	Life of LED=50000 burning hours at 70% lumen maintenance				
a	Lumen output of the fitting=> 1200 Lumens	4	1659	Each	6636
8	S/E of LED Batten with polycarboante body and diffuser The fitting should be installed on existing surface/recess The job includes carriage, erection, making connections testing and commissioning of the fittings.Specification of LED fittings:				
	Wattage of LED fittings-As per following parameter.				
	Total lumens of the fittings.-as below				
	Diffuser - Polycarbonate diffuser/PMMA				
	Operating voltage =140 V to 270 V, AC supply or better.				
	Input frequency =50 Hz + 1 Hz				
	Power factor =Minimum 0.90				

Luminaire efficacy =>100 lm/w					
Color rendering index=CRI shall be greater than 80					
Working/ operating temperature =00 to + 450c or better					
Color temperature =60000K + 10%					
Electronic Driver					
Drive current (LED)=As per OEM.					
Operating voltage =140 V to 270 V, AC supply or better.					
Type of driver =Constant current output driver					
THD =Less than 10%					
Surge Protection =2.5 KV minimum					
Efficiency Driver=>85%					
Protection=Shall have under voltage and over voltage protection.					
Guarantee of LED fittings including LED driver =2 years against manufacturing defect.					
Fixture =Should comply with LM 79 test from UL/NABL lab.					
LED Type/ Make/ Model-Power CREE/ OSRAM/ NICHIA/ Philips LUMILED with life more than 25,000 burning hours @70% lumen maintenance complying with LM 80 test report from the manufacturer.					
Life of LED=25000 burning hours at 70% lumen maintenance					
Lumen output of the fitting=>2000 Lumens	10			631	6310
a					
				TOTAL :-	99681

I am certify that the tender is being called on emergency nature

in urgency of public interest.

Draft schedule of quantity approved for Rs. 99681/-
(Rupees; Ninety nine thousand six hundred eighty one) only.


Assistant Engineer
Electrical Sub-Division
HPPWD Solan


Executive Engineer,
Electrical Division No-1,
HPPWD, Kasumpti, Shimla-9

Estimated Cost Rs 99620/=
 Earnest Money Rs 2000/=
 Time Period 1 month


SCHEDULE OF QUANTITY


Name of Work :- Providing electrical wiring & accessories in Rajasav Sadan at Kotla Nala Tehsil & Distt. Solan (H.P)						
Sr.No	Description of items	Quantity	Rate	Unit	Amount	Remarks
1	Wiring for light point/ fan point/ exhaust fan point/ call bell point with 1.5 sq.mm FRLS PVC insulated copper conductor single core cable in surface / recessed medium class PVC conduit, with modular switch, modular plate, suitable GI box and earthing the point with 1.5 sq.mm FRLS PVC insulated copper conductor single core cable etc. as required..Group C	10	1283	Each	12830	A.R
2	Wiring for circuit/ submain wiring alongwith earth wire with the following sizes of FRLS PVC insulated copper conductor, single core cable in surface/ recessed medium class PVC conduit as required.					
a	2 X 1.5 sq. mm + 1 X 1.5 sq. mm earth wire	140	209	P/mtr	29260	A.R
b	2 X 4 sq. mm + 1 X 4 sq. mm earth wire	80	315	P/mtr	25200	A.R
3	Supplying and drawing following sizes of FRLS PVC insulated copper conductor, single core cable in the existing surface/ recessed steel/ PVC conduit as required.					
a	3x1.5 Sq. mm.	20	93	P/mtr	1860	A.R
b	3x4.0 Sq. mm.	10	205	P/mtr	2050	A.R
4	Supplying and fixing of following sizes of medium class PVC conduit along with accessories in surface/recess including cutting the wall and making good the same in case of recessed conduit as required.:-25 mm. dia	80	125	P/mtr	10000	A.R
5	Supplying and fixing suitable size GI box with modular plate and cover in front on surface or in recess, including providing and fixing 3 pin 5/6 A modular socket outlet and 5/6 A modular switch, connections etc. as required.	18	431	Each	7758	A.R
6	Supplying and fixing suitable size GI box with modular plate and cover in front on surface or in recess, including providing and fixing 6 pin 5/6 & 15/16 A modular socket outlet and 15/16 A modular switch, connections etc. as required.	8	544	Each	4352	A.R
7	S/E of LED Batten with polycarboante body and diffuser The fitting should be installed on existing surface/recess The job includes carriage, erection, making connections testing and commissioning of the fittings.Specification of LED fittings:					
	Wattage of LED fittings-As per following parameter.					
	Total lumens of the fittings.-as below					

	Diffuser - Polycarbonate diffuser/PMMA				
	Operating voltage =140 V to 270 V, AC supply or better.				
	Input frequency =50 Hz + 1 Hz				
	Power factor =Minimum 0.90				
	Luminaire efficacy =>100 lm/w				
	Color rendering index=CRI shall be greater than 80				
	Working/ operating temperature =00 to + 450c or better				
	Color temperature =60000K + 10%				
	Electronic Driver				
	Drive current (LED)=As per OEM.				
	Operating voltage =140 V to 270 V, AC supply or better.				
	Type of driver =Constant current output driver				
	THD =Less than 10%				
	Surge Protection =2.5 KV minimum				
	Efficiency Driver=>85%				
	Protection=Shall have under voltage and over voltage protection.				
	Guarantee of LED fittings including LED driver =2 years against manufacturing defect.				
	Fixture =Should comply with LM 79 test from UL/NABL lab.				
	LED Type/ Make/ Model-Power CREE/ OSRAM/ NICHIA/ Philips LUMILED with life more than 25,000 burning hours @70% lumen maintenance complying with LM 80 test report from the manufacturer.				
	Life of LED=25000 burning hours at 70% lumen maintenance				
a	Lumen output of the fitting=>2000 Lumens	10	631	Each	6310
	Total				99620

It is certify that the tender is being called on emergency basis in exigency of public interest.

Draft schedule of Quantity ³²⁵ approved for Rs. 99620/-
(Rupees: ninety nine thousand six hundred twenty) only


Assistant Engineer
Electrical Sub-Division
HPPWD Solan


Executive Engineer,
Electrical Division No-1,
HPPWD, Kasumpti, Shimla-9