

INSPECTION NOTE

CONSTRUCTION OF SIYUHNI TO CHANDANI ROAD KM. 0/0 TO 3/420. (SH: - CONSTRUCTION OF 5/7 METRE WIDE FORMATION CUTTING INCLUDING PASSING PLACES AND R/WALLS, BREAST WALLS AND CRATE WORK, SIDE DRAIN, PARAPETS, METALLING/TARRING, ROAD FURNITURE, PMGSY LOGO AND INFORMATORY BOARDS ETC.) UNDER PMGSY BATCH-I 2017-18 PACKAGE NO.HP-04-230.

DATE OF INSPECTION :- 20.03.2020.

The work of construction of Siyuhni to Chandani road km. 0/0 to 3/420

package No.HP-04-230 was inspected with following staff: -

- | | |
|-----------------------|-----------------------------|
| 1. Executive Engineer | HP:PWD. Division Jawali |
| 2. Assistant Engineer | HP:PWD. Sub Division Kotla |
| 3. Junior Engineer | HP:PWD. Sub Division Kotla |
| 4. Contractor | M/S V.S. Saini Contractors. |

I. BRIEF FEATURES OF THE WORK :-

Sanctioned cost as per DPR:	Rs. 232.13 Lacs
Amount of award:	Rs.144.87 Lacs Part-I + 17.66 Lacs Part-II
Date of award:	04.04.2018
Date of start:	14.04.2018
Date of completion as per Agreement	13.04.2019

II. PRESENT STATUS OF WORK :-

The work was inspected at site alongwith Executive Engineer, Junior Engineer and Contractor. Following achievement has been made:

Scope of work		Achievement
Formation cutting	3.420 kms	3.420 kms
Cross Drainage	3.420 kms	3.420 kms
GSB	2.813 kms	3.420 kms

F.R
2.E (PMGSY)
S.E (PMGSY)
E.E (PMGSY)
19/20

15/9/2020

1092
15/9/20

WBM-II	2.813 kms	3.420 kms
WBM-III	2.813 Kms	3.420 kms
Metalling/Tarring	2.813 kms	1.000 kms
C.C. pavement	0.570 kms	-
Drain	0.247 kms	0.634 kms

III. OBSERVATIONS :-

1. Tarring work on the road may be started on already laid base course after rainy season immediately.
2. Balance work of WBM G II and WBM G III may be completed immediately.
3. The work is delayed more than year, it should be completed immediately.
4. Quality Control registers were not shown during inspection.
5. Site order book and cement consumption registers may be maintained. These should be shown during next inspection.

The Executive Engineer, Jawali Division, HP:PWD, Jawali is directed to attend above observations and may be shown to undersigned during next inspection.

Superintending Engineer,
9th Circle, HP.PWD.,
Nurpur.

Endst. No. SE-IX/WS/WA-II/Inspection Note/2019-2020- 1988-92

Dated:- 5/9/2020

1. Copy to the Engineer-in-Chief, HP:PWD, Shimla for favour of information please.
2. Copy to the Chief Engineer (KZ), HP.PWD. Dharamshala for favour of information please.
3. Copy to the Executive Engineer, Jawali Divn. HP.PWD, Jawali for information, necessary action and compliance to this office immediately.
4. Copy to Guard File & T.A. Bill.

Superintending Engineer,
9th Circle, HP.PWD.,
Nurpur.