HIMACHAL PRADESH PUBLIC WORKS DEPARTMENT

No.: PW/EDP/CB/TA/CONT/2024-25/- L/315-23

Dated: 12 11) 24

To

The Executive Engineer (IT Cell).

Nigam Vihar, Shimla-2.

Subject:

Publishing of Tondor Notice.

Jai Hind

Enclosed please find herewith the Tender Notice of works as given in the Notice Inviting Tenders along with Schedule of Quantities for uploading on departmental website as per Notification Pr. SEC(PW) to the Govt. of HP letter No. PBW(B)A9(3)1/2020 dated Shimla-26th July 2021.

It is certified that the works mentioned in the Notice Inviting Tenders are urgent in nature and in public Interest

DA/NIT.SQs

Executive Engineer Electrical Division HP PWD Palampus

Copy forwarded to the following for information and necessary action please:

1. The Superintending Engineer, 2nd Electrical Circle, HP PWD Dharamshala.

2 The Drawing Branch in this office.

3. All the Assistant Engineers working under this Division.

HIMACHAL PRADESH PUBLIC WORKS DEPARTMENT "Notice Inviting Tenders"

Sealed percentage rate tenders on form 6&8 are hereby invited by the Executive Engineer, Electrical Division, HP PWD Palampur on behalf of the Governor of HP, for the following work from the approved and eligible contractors enlisted in HP PWD, (Elect.) whose registration stood renewed as per revised rules and also registered under the H.P. General Sales Tax Act. 1968 so as to reach in his office on or before 30-11-2024 up to 11 00 AM, and the same shall be opened on the same day at 11 30 A M in the presence of intending contractors or their authorized representatives. The tender documents can be had from his office against cash payment (Non-refundable) on 29-11-2024 up to 4.00 P.M. and the application for issue of tender form shall be received on 28-11-2024 up to 12 00 noon

The contractor should have the EPF registration certificate should be attached with application

The GST registration certificate.

The contractor should produce a copy of latest enlistment/renewal.

The latest ITR filed should be attached with application.

- The bidders enlisted in a particular class shall be eligible to tender for his own class or one step below.
- The bidder should attach authorization and work done certificate with application for Specialized Jobs.

The FDR duly pledged should be attached separately with each tender.

8. Only two number tender forms will be issued to the eligible contractor.

The Executive Engineer, Electrical Division, HP PWD Palampur reserves the right to reject any tender without assigning any reasons.

10. Conditional/ incomplete tenders & tender without earnest money will be summarily rejected.

Sr. No	Name of Work	Estimated Cost	Earnest Money	Time Limit	Form No.	Cost of
1	R/M of E.I. in Govt. N/R building under ESD Dharamshala in Distt. Kangra (H.P.)(SH-Dismantling and Re-installation of Split type AC unit in Chief office. Rest House and Circuit House therein)	128660/-	2600/-	One Month	8	350/-
2	Construction of Ayurvedic Health Centre at Bhalei in Tehsil Salooni Distt Chamba (H P)(SH - Providing E.I therein)	363763/-	7300/-	One Year	8	350/-
3	C/O Govt Sr. Sec School Building at Awan in Tehsil Bhattiyat and District Chamba (H.P) Under RMSA (SH:-Providing E.I. therein).	220650/-	4500/-	One Year	8	350/-
4	R/M of E.I.in Various Govt. Non-Residential Building under ESD Chamba in Tehsil Bharmour Distt. Chamba (H.P)(Under B&R Division Bharmour).	105415/-	2200/-	Three Months	8	350/-
5	R/M of E.I.in Various Govt. Non-Residential Building under ESD Chamba in Tehsil Dalhousie Distt Chamba (H.P)(SH - Repair of E.I. in PWD Rest House under B&R Division Dalhousie and Chowari in Distt. Chamba (H.P).	196843/-	4000/-	Six Months	8	350/-

6	C/O Govt. High School at Sarad Dogn in Tehsil Rakkar Distt. Kangra (H.P)(3 Rooms in Ground Floor and 3 Rooms in First floor along with Verandah)(SH - Providing E Litherein).	432624/-	8700/-	One Year	В	350/-
7.	C/O 3 Nos. classrooms with veranda at Govt. High School Upper Bhalwal, Distt. Kangra (H.P)(SH - Providing E.I. therein).	158177/-	3200/-	One Year	8	350/-
8	Construction of Government Ayurvedic Dispensary Building at Batot in Tehsil Bharmour Distt Chamba (H.P)(SH Providing E.I. therein).	94203/-	1900/-	Six Months	8	350/-
9	Providing Point wiring, Power wiring and Computer wiring in HP PWD B&R Division Office Building Shahpur Distt Kangra (H.P).	304997/-	6100/-	Three Months	8	350/-
10	C/O War Museum at Dharamshala Distt. Kangra (H.P)(SH - Damaged report of AC Units)	205037/-	4200/-	Six Months	8	350/-
11	C/O War Museum at Dharamshala Distr. Kangra (H.P)(SH -Damaged report of Surveillance System)	86159/-	1800/-	Six Months	8	3501-
12	C/O War Museum at Dharamshala Distt. Kangra (H.P)(SH:-Damaged report of Fire Fighting System) (Specialized Job)	57942/-	1200/-	Six Months	8	350/-
13	C/O Additional accommodation in Govt. Sr. Sec. School Daulatpur in Distt. Kangra (H.P.) (SH:-Providing E.I. to 2 Nos. classrooms therein).	145751/-	3000/-	One Year	8	350/-
14	R/M of E.I. of VidhanSabha complex at Tapovan Dharamshala Distt. Kangra (H.P)(SH:-Repair of E.I. in Main Building and Minister block therein).	498129/-	10000/-	Six Months	8	350/-
15	C/O Type –V Residence of SE (Mechanical) 2 nd Circle Dharamshala (SH - Providing wiring Switches, Fan, LED's therein)	459054/-	9200/-	Six Months	8	350/-
16	Additional Alteration in DEIC (District Early Intervention Center) OPD 11 at 500 Bedded Hospital at Dr. RPGMC Tanda at Kangra (SH:-Providing light points; LED fixture, Power Wiring and AC points therein).	180175/-	3700/-	Two Months	8	350/-
17	C/O School of Nursing at Dr RPGMC Kangra at Tanda in Distt. Kangra (H.P)(SH - Providing Air-Conditioning units to Conference Room, Faculty Room, Director Room, Emergency Room, Store, Maternal & Newborn PICU of Critical Care Skill Lab/Simulation Lab therein).	496307/-	10000/-	Three Months	8	350/
18	C/O School of Nursing at Dr. RPGMC Kangra at Tanda in Distt. Kangra (H.P)(SH:- Providing Air-Conditioning units to ICU. In-Patient Ward. Skill Room and Pantry of Critical Care Skill Lab/Simulation Lab therein)	495952/-	10000/-	Three Months	8	350

19	Repair and Maintenance of E.I. to 500 Bedded Hospital Dr RPGMC Kangra at Tanda (SH-Rewinding of ceiling fans, replacement of fan condensers, fan regulators and extra down fan road etc. in various Wards of ground floor to fourth floor and OPD area therein)	236185/-	4800/-	Six Months	8	350/-
20	Replacement of old and damaged ceiling fans of various wards at 3rd floor (Male and Female) surgical wards, Children ICU, Anesthesia ICU of 500 Bedded Hospital Dr. RPGMC Tanda	293156/-	5900/-	Three Months	8	350/-
21	Repair & Maintenance of HVAC System, 500 bedded hospital Dr RPGMC Kangra at Tanda.(SH:- Replacement of burnt out/damaged chiller pump cable, 5 H.P. motor etc. and overhauling of AHU for CSSD area thereof).	297987/-	6000/-	Three Months	8	350/-
22	R/M of HVAC System in Super Specialty Block Dr. RPGMC Kangra at Tanda (SH- Replacement of damaged water storage tank, butterfly valves, iron net etc for chiller plant and provide new water storage tank for condenser motor and chiller motor therein)	249680/-	5000/-	Three Months	8	350/-
23	Providing Installation Testing & Commissioning Main Control Panel in the office of CMO Chamba in Tehsil & Distt Chamba (H.P.)	222017/-	4500/-	Three Months	8	350/-
24	Replacement of Electrical accessories and old damaged fittings into new one in HPPWD 1st Class Rest-House at Chamba in Tehsil & Distt. Chamba H P Ground Floor & First Floor.	387234/-	7800/-	Three Months	8	350/-
25	C/O Rajeev Gandhi Govt. Engineering College Kangra at Nagrota Bagwari Distt. Kangra (H P)(SH - Providing E.I. to Architecture block therein)(SH:-Supplying one no Computer System in Division office therein)	48490/-	1000/-	Three Months	8	350/-
26	Repair and Maintenance of Mini-Secretariat Building at Dehra in Tehsil Dehra Distt. Kangra (H.P)(SH-Providing LAN UPS,AC's in CM Office herein).	384171/-	7700/-	One Month	8	350/-
27	Replacement of burnt and damaged AMF Controller for 250 KVA D.G. Set Installed in the Complex of H.P. Board of School Education Dharamshala in District Kangra (H.P.)	64731/-	1300/-	Three Months	8	350/-
28	C/O Centre of Excellence in Mental Health for Dr. RPGMC Kangra at Tanda (SH:-Providing and fixing steel work, Aluminum work, Plastering and Painting work in Lift room area of staff lift and Patient lift therein).	280072/-	5700/-	One Month	8	350/-
29	C/O Centre of Excellence in Mental Health for Dr. RPGMC Kangra at Tanda (SH -Providing and fixing steel and grill work in Fire Fighting	220912/-	4500/-	One Month	8	350/-

	Pump Room at Basement floor therein)					
30	Repair and Maintenance of E.I. to Vivekanand Hostel, Dr. RPGMC Kangra at Tanda (SH- Replacement of old and damaged switch- socket LEDs fans etc (room no 201 to 216) and campus lights thereof)	223492/-	4500/-	Three Months	8	350/-
31	Annual repair and comprehensive Maintenance contract of 1 No 13 Passenger lift (Johnson make) in Administration Block of Rajeev Gandhi Govt. Engineering college Nagrota Bagwan in Distt Kangra (HP) (M/C No. L-08066) for three years	483594/-	9700/-	Three Years	8	350
32	Providing wiring for AE residence converted to Superintending Engineer Office (B&R) (First Floor) at Dehra, Tehsil Dehra Distr. Kangra (H.P)	197927/-	4000/-	Two Year	8	350/-
33	Replacement of old accessory to modular accessory. LED fittings, exhaust fan. ceiling fan etc at Court Complex building and Civil Judge – cum- JMFC residence, Indora, Distt Kangra (HP)	167520/-	3400/-	One Year	8	350/-
34	Providing replacement of E.I. to Civil Judge- cum-JMFC at Indora. LED fittings etc. to Civil Judge-cum-JMFC residence (No. II) and providing of DG supply to Additional District and Sessions Court at Nurpur, Distr. Kangra (HP)	997371-	2000/-	Two Years	8	350/-
35	Providing and fixing Split type 1.5 Ton Air Conditioner (Hot & Cold type) in the office of Assistant Director Fisheries, Division Pong Dam in Tehsil Fatehpur Distt. Kangra HP.	248597/-	5000/-	Three Months	8	350/-
36	Providing & Fixing power wiring, Geyser, Exhaust fan etc. in OT Room (3rd Floor) in Additional Block in Civil Hospital at Palampur Tehsil Palampur Distt. Kangra (H.P)	270950/-	5500/-	Two Months	8	350/-
				A STATE OF THE STA	Line man	

HIM SUCHNA AVAM JAN SAMPARK VIBH

	Ot .	4	w	N	-	NO.	in Distt.	NAME
Total	Dismantling, Re-installation, testing and commissioning of 1.5/2 Ton capacity split type air-conditioning outdoor units as required complete in all respects and as per directions of Engineer-in-charge.	Supplying and Fixing of PVC Drain pipe of size 1" Dia. (25 mm) complete with elbows, tees, socket etc. of superior quality as per satisfaction of Engineer-in-charge.	Supply and replerishment/charging/topping -up of refrigerant R-32 Gas as required complete in all respects as per the direction and to the best satisfaction of Engineer-in-charge.	Providing and Fixing of extra copper tubes for refrigerant and condensate (1/4" x 1/2") for 1.5 T.R, split type A.C. units and wiring with suitable size of HRFRLS copper conductor single core cables, including the cost of insulation etc. as required complete in all respects.	Supplying and Fixing of MS outdoor heavy duty stand powder coated suitable to hang 1.5/2.0 TR split type AC with six nos anchor bolts as required complete in all respects and as per the direction of Engineer in charge.	DESCRIPTION	in Distt. Kangra (H.P)(SH:- Dismantling and Re-installation of Split type AC unit in Chief office, Rest House and Circuit House therein).	SCHEDULE OF QUANT
	11	32	đ	48	N	QTY.	ų.	NAUG
	3000.00	220.00	2500,00	1200.00	1100.00	FIGURES	Job No .	YTIT
	Rupees Three Thousand Only	Rupees Two Hundred Twenty Only	Rupees Two Thousand Five Hundred Only	Rupees One Thousand Two Hundred Only	Rupees One Thousand One Hundred Only	WORDS	ESTIMATED COST: Rs. 1,28,660/-only. EARNEST MONEY: Rs.2600/-only TIME ALLOWED: One Months	
	Each	Per Meter	Each	Per Meter	Each	UNIT	.1,28,660/-only 2600/-only Months	
128660	33000	8360	27500	57600	2200	AMOUNT	nly.	

Schoolide of greently chief and soul product find 128660 and of

2	N			-	3	S SR	Tehsil
Make:- Legrand (Myrius)Schneider(Livia)/Anchor Roma (Plus)	Wiring for twin control light point with 1.5 Sq. mm. PVC insulated heat resistant flame retardant (HRFR) and low smoke single core (flexible) copper conductor cable in surface/recessed steel conduit with 2-way, 5/6 amps. modular switch, modular plates, suitable G.I. box and earthing the light point with 1.5 Sq.mm. HRFRLS/PVC insulated single core copper conductor cable as required.	Group C.	Group A.	Sq. mm. PVC insulated heat resistant flame retardant (HRFR) and low smoke single core (flexible) copper conductor cable in surface/recessed steel conduit with modular switch, modular plates, suitable G.I. box and earthing the light point with 1.5 Sq.mm. HRFRLS/PVC insulated single core copper conductor cable as required.Make:- Legrand (Myrlus)/Schnolder(Livia)/Anchor Roma (Plus)		DESCRIPTION	Tehsil Salooni Distt. Chamba (H.P) (S.HProvidic Health Centre at Bhalei In
		2	28		מדץ.	د	QUAN
		1893	1323		FIGURES	Job No 2	TITY
		Rupees One Thousand Eight Hundred Ninety Three Only	Rupees One Thousand Three Hundred Twenty Three Only	WORDS	RATES	EARNEST MONEY: Rs.73001-only TIME ALLOWED: One Year	ESTIMATED COST
		Per point	Per point		TINU	3,63,763/-only -7300/-only Year	
		45432	37044		AMOUNT	ïy.	

			1					
0	-	cn cn	4	=	=:	-	ω	
Supplying and fixing G.I. Modular box of (140mmx78mmx50mm) size with modular plate and cover in recess including providing and fixing 5 pin 5/6 amps modular socket outlet and 5/6 amps, modular switch,	3x2.5 Sq. mm.	Supplying and drawing following size of PVC insulated, heat resistant, flame retardant (HRFR) and low smoke single core (flexible) copper conductor cable in existing surface / recessed, Steel/PVC conduit as required. Make: Finolex/ KEI/ Anchor.	resistant flame retardant (HRFR) and low smoke single core (flexible) copper conductor cable in surface/recessed steel conduit along with 2 No.4 Sq.mm. (4X4+2X4)HRFRLS/PVC insulated single core copper conductor cable for earthing as required.Make:-KEl/Anchar/Finolex	2 X 10 sq. mm + 1 X 6 sq. mm earth wire	2 X 4 sq. mm + 1 X 4 sq. mm earth wire	2 X 2.5 sq. mm + 1 X 2.5 sq. mm earth wire	t flame retardant (HRFR) conductor cable in surface RLS/PVC insulated single earthing as required. Make	
3	18		#	6	68	58	- 10 - 10 - 1	2
601	173		786	808	482	406		1533
Rupees Six Hundred One Only	Rupees One Hundred Seventy Three Only		Rupees Seven Hundred Eighty Six Only	Rupees Eight Hundred Eight Only	Rupees Four Hundred Eighty Two Only	Rupees Four Hundred Six Only		Rupees One Thousand Five Hundred Thirty Three Only
Each	Per metre		Per metre	Per metre	Per metre	Per metre	14	Per point
6611	3114		34584	4848	32776	23548	8	3066

Г	Г					_		,				_	_
L		===			10			9		8		7	
1 Pair	Make:-Anchor/KEl/Finolex	Supplying and drawing co-axial TV cable, RG-6 grade, 0.7mm (75 Ohms) copper conductor PE insulated, shielded with fine tinned copper braid and protected with PVC sheath in the existing surface / recessed, steel / PVC conduit as required.	Telephone Socket outlet, modular.	Makes:- Legrand (Myrius)/Schneider(Livia)/Anchor Roma (Plus)	existing switch box / cover plate including connections etc. as required.	Supplying and fixing following rating Modular switch /socket in the	Make:- Legrand (Myrius)/Schneider(Livia)/Anchor Roma (Plus)	Supplying and fixing suitable size GI box with modular plate and cover in front on surface or in recess, including providing and fixing 2 nos. 3 pin 5/6 amps modular socket outlets and 2 nos 5/6 amps modular switches, connection etc. as required. (For light plugs to be used in non residential buildings).	Make:- Legrand (Myrius)/Schneider(Livia)/Anchor Roma (Plus)	Supplying and fixing suitable size GI box with modular plate and cover in front on surface or in recess, including providing and fixing 3 nos. 3 pin 5/6 amps modular socket outlets and 3 nos 5/6 amps modular switches, connection etc. as required. (For light plugs to be used in non residential buildings).	Make:- Legrand (Myrius)Schneider(Livia)/ /Anchor Roma (Plus)	supplying and fixing G.I. Modular box of (140mmx78mmx50mm) size with modular plate and cover in recess including providing and fixing 6 pin 15/16 amps modular socket outlet and 15/16 amps, modular switch, connections etc. as required.	Make:- Legrand (Myrius)/Schneider(Livia) /Anchor Roma (Plus)
-		25					2	10		N		9	
		37					949			1385		769	
		Rupees Thirty Seven Only					Rupees Nine Hundred Forty Nine Only			Rupees One Thousand Three Hundred Eighty Five Only		Rupees Seven Hundred Sixty Nine Only	
		Per mtr					Each			Each		Each	
		925					1898			2770		6921	

	17	6	-	15	4		ಪ		73
Exhaust Fan, Light duty, (Domestic) 300 mm sweep	Providing and Installation of exhaust fan of following sizes in the existing opening, including making the hole to suit the size of the above fan, making good the damages, connections, testing and commissioning etc. as required:- Make:- Usha/Bajaj/Crompton	Supplying and fixing call bell / buzzer, suitable for D.C./A.C. single phase,230 volts complete as required:- Make: Anchor (Panta)/ SSK(Touch)	25 mm. dia	Supplying and fixing of following sizes of medium class PVC conduit along with accessories in surface/recess including cutting the wall and making good the same in case of recessed conduit as required.Make: BEC/ Diplast/ Anchor.	Supplying and drawing LAN cable CAT 6, solid copper conductor protected with PVC sheath in the existing surface / recessed, steel / PVC conduit as required.Make:- KEl/Anchar/Finolex	RJ 45 Jack with cat 6 (1 moudule) Makes:- Legrand (Myrius)/Schneider(Livia)/Anchor Roma (Plus)	Supplying and fixing RJ 45 Jack with cat 6 in the existing switch box / cover plate including connections etc. as required.	2 modules (78mmx78mmx50mm)	Supplying & fixing of G.I. modular boxes of following sizes along with modular base and cover plate for modular switches in recess as required.
4.		2	45		30	N		2	
2309		199	120		50	490		293	
Rupees Two Thousand Three Hundred Nine Only		Rupees One Hundred Ninety Nine Only	Rupees One Hundred Twenty Only		Rupees Fiffy Only	Rupees Four Hundred Ninety Only		Rupees Two Hundred Ninety Three Only	
Each		Each	Per mtr		Per mtr	Each		Each	
9236		398	5400		1500	980		586	

_							
	20				19		8
Make:-Panasonic/ BAJAJ/Wipro	Supplying and fixing surface mounting following size LED solution suitable for surface application with the use of the latest technology 42 Watt (4200 lumen) 6000K and it should be compatible with specifications i.e. power factor ≥ 0.9, harmonic distortion ≤ 10% and efficacy ≥ 100 lumens per watt, CRI > 80, suitable for input voltage AC 220-240V, 50/60 Hz complete with all accessories, connections, testing and commissioning etc. as required.with 5 year warranty.	Cat No: BCLAB 20W LED P	LED Tube Fixture 20Watt (L x W:1135 x22mmHeight:37mm)	Make:-Panasonic/Bajaj/Wipro.	Providing and fixing decorative extruded tube fixture having high quality design suitable for LED tube up to 20Watt (2000 lumen) 6500K and it should be compatible with specifications i.e. power factor ≥ 0.9, harmonic distortion ≤ 10% and efficacy ≥ 100 lumens per watt, CRI > 80, suitable for input voltage AC 220-240V, 50/60 Hz, including one no, tube rod 20 Watt complete with all accessories, connections, testing and commissioning etc. as required with 5 year warranty.	1200 mm sweep Make:-Usha(Technoair BLDC without Remote Star/ Bajaj/Crompton (Warranty Five year)	with step electronic fan regulator paino type, including wiring the down rod of standred length (up to 30 Cm) with 16/0.20 mm twin twisted flixible, cotton braided cable, including providing and fixing phenolic laminated sheet cover on the fan box and earthing etc. as required.
		4				60	2
		981			*	4397	
	8	Rupees Nine Hundred Eighty One Only				Rupees Four Thousand Three Hundred Ninety Seven Only	
		Each				Each	
		3924				35176	

=	-		12			2		
LED 18 Watt Square (L x W: 175 mm x 175MM. Height: 35 mm)	LED 12 Watt Square (L x W: 175 mm x 175MM. Height: 35 mm)	Make:-Panasonic/Bajaj/ Wipro/	Supplying and fixing surface mounting following size LED solution sultable for surface application with the use of the latest technology 12/18 Watt (1200/1800 lumen) 6500K and it should be compatible with specifications i.e. power factor > 0.9, harmonic distortion < 10% and efficacy > 100 lumens per watt, CRI > 80, sultable for input voltage AC 220-240V, 50/60 Hz complete with all accessories, connections, testing and commissioning etc.including 5 year warrenty as required.	LED 12 Watt Round	Make:-Panasonic/Bajaj/ Wipro/	Supplying and fixing surface mounting following size LED solution suitable for surface application with the use of the latest technology 12/18 Watt (1200/1800 lumen) 6500K and it should be compatible with specifications i.e. power factor > 0.9, harmonic distortion < 10% and efficacy > 100 lumens per watt, CRI > 80, suitable for input voltage AC 220-240V, 50/60 Hz complete with all accessories, connections, testing and commissioning etc.including 5 year warrenty as required.	Cat No:LSVR003S042XC	Sauver (Surface)-36W/1ft.x4ft.
4	4			12				12
1157	781			787				5549
Rupees One Thousand One Hundred Fifty Seven Only	Rupees Seven Hundred Eighty One Only			Rupees Seven Hundred Eighty Seven Only			Uniy	Rupees Five Thousand Five Hundred Forty Nine
Each	Each			Each				Each
4628	3124			9444			-	11098

26	25			24		23
Providing and errection of LED 45 watt Street light luminaries powder coated pressure die-cast aluminium Make:-Jaquar/Panasonic/ WiproMDLED Street light with heat resistant toughened glass including connections, testing and commisioning etc; as required complete in all respects. With 5 year waranty Make:-Panasonic/ Wipro/Bajaj/	Supplying and fixing bakelite batten/angle holder including connections etc. as required:- Make:- GoldMedal/Anchor/SSK	Cat No: LL20-111-111-XXX-65NE3	Mirror lightLED 10Watt	design suitable for LED tube up to 10Watt (Mirror Light)(1000 lumen) 6500K and it should be compatible with specifications i.e. power factor ≥ 0.9, harmonic distortion ≤ 10% and efficacy ≥ 100 lumens per watt, CRI > 80, suitable for input voltage AC 220-240V, 50/80 Hz, including one no. tube rod 20 Watt complete with all accessories, connections, testing and commissioning etc. as required with 5 year warranty. Make-Panasonic,Bajaj/Wipro	LED Bulk head 10Watt Cat No: BIBWP 10W LED	(1000 lumen) 6500K and it should be compatible with specifications i.e. power factor ≥ 0.9, harmonic distortion ≤ 10% and efficacy ≥ 100 lumens per watt, CRI > 80, suitable for input voltage AC 220-240V, 50/60 Hz, connections, testing and commissioning etc. including 5 year warrenty as required as .Make:-Jaquar/Panasonic/ Wipro,Philips
	ယ		_		80	
į.	87		537	-	1327	
	Rupees Eighty Seven Only		Rupees Five Hundred Thirty Seven Only		Rupees One Thousand Three Hundred Twenty Seven Only	
	Each		Each		Each	
	261		537		10616	

1-6	29	28			27		152
15 Liter capacity water heater (Cat-A)	Providing and installation of stationary storage type Electric water heater (Geyser) of various sizes by means of Expansion-bolts with nuts and washers, including embedding of expansion-bolts in the wall, providing and fixing of Non-return valve, Dead weight safety valve, 2 No C.P. connection rods 18" long, making good the damages, electrical connections, safety valve connections, testing and commissioning etc. as required:- Make:-Usha /Recold/Bajaj	Supplying & fixing suitable size GI box with modular plate and cover in front on surface or in recess i/c providing and fixing 25 amp modular socket outlet and 25 Amps modular SP MCB, "C" curve including connection, painting etc. as required: Make:- Legrand (Myrlus)Schneider(Livia)/Anchor Roma (Plus)	Makes:- Tisva (Cat.No.AL916611R 9W/ B22) /Panasonic / Osram.	9 Watt LED, B-22	Supplying and fixing LED retrofit lamp suitable for B-22 holder base fittings with polycarbonate diffuser and aluminium heat sink as required complete in all respects. Make:- Philips/Bajaj/Osram	Cat No: PSTM27458	LED Street Light, 45 Watt
-		N		w			N
9149		794	1	199			6155
Rupees Nine Thousand One Hundred Forty Nine		Rupees Seven Hundred Ninely Four Only		Rupees One Hundred Ninety Nine Only			Rupees Six Thousand One Hundred Fifty Five Only
Each		Each		Each			Each
9149		1588	I	597			12310

Si Si	32	3			30	
Supplying and fixing 63 Amps rating, double pole, 240 volts, isolator in the existing MCB DB complete with connections, testing and commissioning etc. as required. (Make:-L&T/Legrand/Schneider)	Supplying and fixing 63 Amps. rating, double pole (single phase & neutral) 240 volts, residual current circuit breaker (RCCB), having a sensitivity current up to 300 miliampers in the existing MCB DB complete with connections, testing and commissioning etc. as required (Make:-L&T/ Legrand/ Schneider)	supplying and fixing 6 amps to 32 amps rating, 240/415 volts, 10 kA, "C" curve, miniature circuit breaker suitable for inductive load of following poles in the miniature circuit breaker suitable for inductive load of following poles in the existing MCB DB complete with connections, testing and commissioning etc. as required.Make: L&T, Legrand, Schneider.	Double door-12 way	Double door-4 way	with tinned copper bus- bar, wire-set, neutral link, earth bar, din-bar, detachable gland plate, blanking plate, cable, identification labels interconnections, phosphatized and powder painted, including earthing etc. as required:- Make: L&T, Legrand, Schneider.	Supplying and fixing of following way, single pole and name as steel MCB distriction of following way, single pole and name as the steel MCB distriction of following way, single pole and name as the steel MCB distriction of following way, single pole and name as the steel MCB distriction of following way, single pole and name as the steel MCB distriction of following way, single pole and name as the steel MCB distriction of following way, single pole and name as the steel MCB distriction of following way, single pole and name as the steel MCB distriction of following way, single pole and name as the steel MCB distriction of following way, single pole and name as the steel MCB distriction of following way, single pole and name as the steel MCB distriction of following way, single pole and fixed as the steel MCB distriction of following way, single pole and fixed as the steel MCB distriction of following way, single pole and fixed as the steel MCB distriction of following way, single pole and fixed as the steel MCB distriction of the steel MCB di
N	ю	17	N	4		-
494	3625	272	2343	1511		10345
Rupees Four Hundred Ninety Four Only	Rupees Three Thousand Six Hundred Twenty Five Only	Rupees Two Hundred Seventy Two Only	Rupees Two Thousand Three Hundred Forty Three Only	Rupees One Thousand Five Hundred Eleven Only		Rupees Ten Thousand Three Hundred Forty Five Only
Each	Each	Each	Each	Each		Each
988	7250	4624	4686	1511		10345

Total	35 for c	34 locki
ai	Supplying and laying 6 SWG G.I. wire at 0.50 metre below ground level for conductor earth electrode, including connection/ termination with GI thimble etc. as required	accessories and providing masonry enclosure with cover plate having locking arrangement and watering pipe etc. (but without charcoal or coke and salt) complete as required.
	30	
	48	8830
	Rupees Forty Eight Only	Rupees Eight Thousand Eight Hundred Thirty Only
	Per metre	Set
363763	1440	8830

Schooling of greentity checkles and approved for 2 363763 which

	SCHEDULE OF QUANTITY	NAUG	=			
Bhattiy	NAME OF WORK :-C/O Govt. SR. SEC. School Building at Awan in Tehsil Bhattiyat and District Chamba (H.P).Under RMSA (Sh:- Providing E.I.therein)	, Jo	Job No 13	ESTIMATED COST: Rs.2,20,650/-only. EARNEST MONEY: Rs.4500/-only TIME ALLOWED: One Year	s.2,20,650/-6 s.4500/-only Year	ıly.
SR.	DESCRIPTION	YTO		RATES	TINU	AMOUNT
NO.		1	FIGURES	WORDS		
-	Wining for light point/ fan point/ exhaust fan point/ call bell point with 1.5 sq.mm FRLS PVC insulated copper conductor single core cable in surface / recessed steel conduit, with piano type switch, phenolic laminated sheet, suitable size MS box and earthing the point with 1.5 sq.mm. FRLS PVC insulated copper conductor single core cable etc as required.Make: Anchor (Panta)/ SSK(Touch)					1.1-
	Group C.	39	1746	Rupees One Thousand Seven Hundred Forty Six Only	Per point	68094
ю	Wiring for twin control light point with 1.5 Sq.mm. PVC insulated heat resistant flame retardant (HRFR) and low smoke single core (flexible) copper conductor cable in surface / recessed PVC conduit, with 2-way, 5/6 amps plano type switch and earthing the light point with 1.5 Sq.mm. HRFRLS/PVC insulated single core copper conductor cable as required.Make: Anchor (Panta)/ SSK(Touch)					
	Group C.	<	1766	Rupees One Thousand Seven Hundred Sixty Six Only	Per point	
ω 	Wiring for circuit/sub-main with following size PVC insulated heat resistant flame retardant (HRFR) and low smoke single core (flexible) copper conductor cable in surface/recessed steel conduit along with 1 No.HRFRLS/PVC insulated single core copper conductor cable of same size for earthing as required. Make: Havells/Plaza/Anchor		-			

	7	o	ن. ن	T	4	=	1 =	T
1200 mm sweep Make:- Usha (Technix BLDC without Remote / (Bajaj /Crompton with 5 year waranty.	Providing installation, Testing and commissioning of Ceiling Fan BLDC with step electronic fan regulator paino type, including wiring the down rod of standred length (up to 30 Cm) with 16/0.20 mm twin twisted flixible, cotton braided cable, including providing and fixing phenolic laminated sheet cover on the fan box and earthing etc. as required.	Supplying and fixing metal box of 180mm X 100mm X 60mm deep (nominal size) on surface or in recess with suitable size of phenolic laminated sheet cover in FRLSont including providing and fixing 6 pin 5/6 & 15/16 amps socket outlet and 15/16 amps piano type switch, connection, painting etc. as required.Make: Anchor (Panta)/ SSK(Touch)	(nominal size) on surface or in recess with suitable size of phenolic laminated sheet cover in FRLSont including providing and fixing 3 pin 5/6 amps socket outlet and 5/6 amps piano type switch, connection, painting etc. as required.Make: Anchor (Panta)/ SSK(Touch)	3x2.5 Sq. mm.	flame retardant (HRFR) and low smoke single core (flexible) copper conductor cable in existing surface / recessed, Steel/PVC conduit as required. Make:Havells/Plaza/Anchor		2 X 4 sq. mm + 1 X 4 sq. mm earth wire	sq. mm + 1 x 2.5 sq. mm earth wire
12		\ ω	\ w	8		7,	36	34
4386	C44	494	300	172		664	477	401
Rupees Four Thousand Three Hundred Eighty Six Only		Rupees Four Hundred Ninety Four Only	Rupees Three Hundred Only	Rupees One Hundred Seventy Two Only		Rupees Six Hundred Sixty Four Only	Rupees Four Hundred Seventy Seven Only	Rupees Four Hundred One Only
Each		Each	Each	Per metre		Per metre	Per metre	Per metre
52632		1482	900	1376	N	4648	17172	13634

10		-		ro.		-		œ
Providing and fixing LED Street light luminaire with the use of the lattest technology 45 Watt (4500 lumens)6500k made of CRCA housing and it should be compatible with specification i.e. Power Factor ≥ 0.9, Harmonic Distortion <20% and efficacy ≥ 100 Lumens per watt, CRI rating> 70 suitable for input voltage: 220-240 V, 50 Hz, complete with all accessories, connections, testing and commissioning etc. as required, with 5 year warranty Make- Bajaj, Panasonic, Wipro	Cat No: PPAM17127R1	LED 12 Watt Round	Make:-Bajaj/Panasonic/ Wipro	suitable for surface application with the use of the latest technology 6/12/18 Watt (600/1200/1800 lumen) 6500K and it should be compatible with specifications i.e. power factor ≥ 0.9, harmonic distortion ≤ 10% and efficacy ≥ 100 lumens per watt, CRI > 80, suitable for input voltage AC 220-240V, 50/60 Hz complete with all accessories, connections, testing and commissioning etc. as required.with 5 year warranty.	Cat No: BCLAB 20W LED P	LED Tube Fixture 20Watt	Make:-Bajaj/Panasonic/Wipro.	design suitable for LED tube up to 20Watt (2000 lumen) 6500K and it should be compatible with specifications i.e. power factor ≥ 0.9, harmonic for input voltage AC 220-240V, 50/60 Hz, including one no, tube rod 20 watt complete with all accessories, connections, testing and commissioning etc. as required.with 5 year warranty.
7	8	60			18	15		
		784				978		
		Rupees Seven Hundred Eighty Four Only			Eight Only	Rupees Nine Hundred Seventy		
		Each			i i	Each		
		4704			X	15848		

ದ	===	-	12		_	3	1	-
Supplying and erection of 6 amps. to 32 amps. rating, 10 KA breaking capacity, 240 volts, 'C' curves, miniature circuit breaker of Single pole in the existing MCB DB complete with connections etc. as required:- Cat-A. (Make:- L&T/ Legrand/ Schneider)	Double door-6 way	Double door-6 way	Supplying and fixing of following way, single pale and neutral sheet steel MCB distribution board, 240 volts, on surface / recess, complete with tinned copper bus- bar, wire-set, neutral link, earth bar, din-bar, detachable gland plate, blanking plate, cable, identification labels interconnections, phosphatized and powder painted, including earthing etc. as required:- (Make:-L&T/ Legrand/ Schneider)	Cat No: PSTM27458	LED Bulk head 10Watt Cat No: BIBWP 10W LED	Providing and fixing LED Bulk head of following rating with pressure die casting aluminium housing and it should be compatible with specification i.e. Power Factor ≥ 0.9, Harmonic Distortion <20% and efficacy ≥ 100 Lumens per watt, CRI rating> 70 suitable for input voltage: 220-240 V, 50 Hz. complete with all accessories, connections, testing and commissioning etc. as required.with 5 year warranty. Make-Baja),Panasonic,Wipro	Cat No: PSTM27458	LED Street Light, 45 Watt
(m	1/-	11			4		-	2
268	1914	1754			1324			5503
Rupees Two Hundred Sixty Eight Only	Rupees One Thousand Nine Hundred Fourteen Only	Rupees One Thousand Seven Hundred Fifty Four Only			Rupees One Thousand Three Hundred Twenty Four Only		Hundred Three Only	Rupees Five Thousand Five
Each	Each	Each			Each			Each
21,44	1914	1754			5296			11006

				and a second as required.	17
Per metre	Conly Only	41	30	Supplying and laying 6 SWG G.I. wire at 0.50 mtr. below ground level for	
	Coch One			charcoal/ coke and sall) as required.	
Set	Rupees Eight Thousand Eight Hundred Thirty Only	8830	4	Earthing with G.I. earth plate 600 mmx600 mmx 6 mm thick, including accessories and providing masonry enclosure with cover plate having accessories and providing masonry enclosure with cover plate having locking arrangement and watering pipe of 2.7 metre long etc. with	6
1				Schneider.	
Each	Hundred Ninety One Only	491	12	the existing MCB DB complete with connections, testing and commissioning etc. as required: Cat-A.Make: L&T, Legrand,	5
	Dinaps Four			L&T/ Legrand/ Schneider)	
Each	Rupees Two Thousand Seven Hundred Nineteen Only	2719	N	Supplying and fixing 40 Amps. rating, double pole (single phase & neutral) 240 volts, residual current circuit breaker (RCCB), having a sensitivity current up to 30 millampers in the existing MCB DB complete with connections, testing and commissioning etc. as required. (Make:-	4

Total Salvalue of rundy charles and approved for 220651-12

ONEY: Rs. 2200/-onty/ED: Three Months UNIT DS I Hundred P/Mtr No Only S One enty Three P/Mtr S Three P/Mtr S Three phteen Only S Three phteen Only S Three phteen Only		66 No 49 FIGURE 406 482 482 318	40 15 28 36 QTY.	Building under ESD Chamba in Tehsil Bharmour Distt. Chamba H.P (Under B&R Division Bharmour). DESCRIPTION Wiring for circuit submain wiring alongwith earth wire with the following sizes of FRLS PVC insulated copper conductor, single core cable in surface/ recessed medium class PVC conduit as required.Make: KEI/Polycab/Anchor/Grandlay 1 2x4.0 Sq. mm. W 2x16 Sq. mm. Make: KEI/Polycab/BEC/Grandlay Providing and laying of one No. aluminium conductor, PVC insulated and PVC sheathed, armoured/XLPE power cable, working voltage 1100 volts grade direct in ground; to be laid 1 meter below the ground level including excavation and refilling the trench etc.as required, but excluding sand cushioning and protective covering:-
	ED: Three Months ED: Three Months UNIT INIT One One One One Three Three P/Mtr P/Mtr			Job No 44 QTY. FIGURES 48 406 48 408 28 808 15 1123 16 318

105415					Total	
9236	Each	Rupees Two Thousand Three Hundred Nine Only	2309	4	Exhaust Fan, Light duty, (Domestic) 300 mm sweep	-
					Providing and installation exhaust fan of following sizes in the existing opening, including making the hole to suit the size of the above fan, making good the damages, connections testing and commissioning elc. as required: of Approved Make	4
					Makes :Bajal/ Panasonic/wipro	
7962	Each	Rupees One Thousand Three Hundred Twenty Seven Only	1327	0)	LED Bulk Head Light 10W	
					Wall Mounted with minimum lumen efficacy of 100 lm/W with Pressure Die Cast Aluminum housing, Polycarbonate Opal Diffuser and P.F.>0.95 with THD<10%, CRI 80. The LED shall be tested with LM80-08 standard with Useful life of 50000 Hrs at L70 with five years warranty. The LEDs used in the luminaire shall have CCT of ANSI Bin 5700 K only with CRI of minimum 80. The Input voltage range shall be 140V to 280V, 50/60 Hz complete with all accessories, including connections, testing and commissioning etc.as required complete in all respects.	ω

July 1816501 4 Lynn Achievan Stanons Hade

	SCHEDULE OF QUANTITY	QUAN	YTITY			
NAME Buildi (Sub-J Dalho	NAME OF WORK :- R/M of E.I in Various Govt. Non Residential Building under ESD Chamba in Tehsil Dalhousie Distt. Chamba H.P (Sub-Head:- Repair of PWD Rest House under B&R Division Dalhousie and Chowari in Distt. Chamba H.P.	Jo	Job No Da	ESTIMATED COST: Rs. 1,96,843/-only. EARNEST MONEY: Rs. 4000/-only TIME ALLOWED: Six Months	1,96,843/-on 4000/-only inths	ķ
	DESCRIPTION	QTY.		RATES	TINU	AMOUNT
			FIGURES	WORDS		
_	Supplying and drawing following size of PVC insulated, heat resistant, flame retardant (HRFR) and low smoke single core (flexible) copper conductor cable in existing surface / recessed, Steel/PVC conduit as required.Make:- KEl/Anchar/Polycab					
	PVC insulated HRFR LS Copper conductor 1.5 Sq. mm.					П
0	3x2.5 Sq. mm.	114	151	Rupees One Hundred Fifty One Only	P/Rmt	17214
3	3x4.0 Sq. mm.	80	220	Rupees Two Hundred Twenty Only	P/Rmt.	17600
3	3x10.0 Sq. mm.	82	538	Rupees Five Hundred Thirty Eight Only	P/Rmt	44116
13	Supplying and fixing following rating Piano-type switch /socket on the existing switch box / cover including connections etc. as required. Make-:Anchor(Penta)SSK(Touch					
-	S.P. 5/6 Amps one way switch, piano type.	62	42	Rupees Forty Two Only	Each	2604
21	5 pin 5/ 6 Amps socket outlet, porcelain base/ piano type.	36	57	Rupees Fiffy Seven Only	Each	2052
=======================================	S.P. 15/16 Amps one way switch, porcelain base/ piano type.	35	116	Rupees One Hundred Sixteen Only	Each	4060

		,			
-	On		4	ω	;
Single pole. Cat-A.	Supplying and erection of 6 amps. to 32 amps. rating, 10 KA breaking capacity, 240 volts, 'C' curves, miniature circuit breaker of following poles in the existing MCB DB complete with connections etc. as required: Make:-L&T/Legrand/Schneider	Double door-12 way	supplying and fixing of following way, single pole and neutral sheet steel MCB distribution board, 240 volts, on surface / recess, complete with tinned copper bus- bar, wire-set, neutral link, earth bar, din-bar, detachable gland plate, blanking plate, cable, identification labels interconnections, phosphatized and powder painted, including earthing etc. as required:-Make:- L&T/ Legrand/ Schneider	Die Cast Aluminum system lumen efficacy of 100 lm/W with Pressure with THD<10%, CRI 80. The LED shall be tested with LM80-08 standard with Useful life of 50000 Hrs at L70. The LEDs used in the luminaire shall have CCT of ANSI Bin 5700 K only with CRI of minimum 80. The Input voltage range shall be 140V to 280V, 50/60 HZ complete with all accessories, including connections, testing and commissioning etc.as required With 5 year Warranty. Make - Panasonic /Wipro/Philips	Providing and fixing of IP65 Bulkhead led fixture 10 W +/- 1 W Wall
35		æ		4	32
239		2055		1420	123
Rupees Two Hundred Thirty Nine Only		Rupees Two Thousand Fifty Five Only		Rupees One Thousand Four Hundred Twenty Only	Rupees One Hundred Twenty Three Only
Each		Each		Each	Each
8365		16440		19880	3936

		=	-	Ø
The Dismental metrial deducted from the contractor that is Rs. 1000/- in the Final will	Total	63 Amps. Cat-A.	40 Amps. Cat-A.	Supplying and fixing following rating, double pole (single phase & neutral) 240 volts, residual current circuit breaker (RCCB), having a sensitivity current up to 300 miliampers in the existing MCB DB complete with connections, testing and commissioning etc. as required. Make:-L&T/ Legrand/ Schneider
-		10	13	
		3104	2272	
A II CI Site Clava by cheeted		Rupees Three Thousand One Hundred Four Only	Rupees Two Thousand Two Hundred Seventy Two Only	
Sych		Each	Each	
T	19684	3104	29536	

Chartedale descripty char

-	-	ω	-	N	-	_	a c	First SR.
Makes: KEl/Anchor/Finolex/GrandLay.	2X1.5Sq.mm+1X1.5Sq.mm Earth wire	Wiring for circuit/ submain wiring alongwith earth wire with the following sizes of FRLS PVC insulated copper conductor, single core cable in surface/ recessed steel conduit as required	Group C. Makes:- Legrand(Myrius),Schiender(Livia),Anchor Roma(Plus),L&T(Entice).	copper conductor single core cable in surface / recessed steel conduit, with 2 Way modular switch, modular plate, suitable GI box and earthing the point with 1.5 sq.mm. FRLS PVC insulated copper conductor single core cable etc as required.	Group C. Makes:-Legrand(Myrius),Schiender(Livia),Anchor Roma(Plus),L&T(Entice).	sq.mm Wiring for light point/ exhaust fan point/ call bell point with 1.5 with 1.5 sq.mm FRLS PVC insulated copper conductor single core cable in surface / recessed steel conduit, with modular switch, modular plate, suitable GI box and earthing the point with 1.5 sq.mm. FRLS PVC insulated copper conductor single core cable etc as required.		Rakkar Distt. Kangra (HP)(3 rooms in Ground Floor and 3 Rooms in First floor alongwith Verandah) (SH: Providing E.I there in). SR. DESCRIPTION
40			2		22		QTY.	
282			1692		1650		FIGURES	job Na
Rupees Two Hundred Eighty Two Only			Rupees One Thousand Six Hundred Ninety Two Only		Rupees One Thousand Six Hundred Fifty Only		RATES	ESTIMATED COST: Rs.4,32,6241-9nly. EARNEST MONEY: Rs.87001-only TIME ALLOWED: One Year
P/Mtr			P/Pt		P/Pt		UNIT	4,32,524/- 3.8700/-only Year
11280			3384		138600		AMOUNT	only.

œ		7		=:	-	6		-	Cn		-	4
Supplying and erection of 6 amps. to 32 amps. rating, 10 KA breaking capacity, 240 volts, 'C' curves, miniature circuit breaker of following poles in the existing MCB DB complete with connections etc. as required:	Makes: Legrand(Myrius),Schiender(Livia),Anchor Roma(Plus)	Supplying and fixing suitable size GI box with modular plate and cover in front on surface or in recess, including providing and fixing 3 pin 5/6 amps modular switch, connection etc. as required.	Makes: KEl/Anchor/Finolex/GrandLay	3X2.5Sq.mm	3X1.5 Sq.mm	Supplying and drawing following sizes of FRLS PVC insulated copper conductor, single core cable in the existing surface/ recessed steel/ PVC conduit as required.	Make:- Havells, Polycab, Finolex, GrandLay.	Armoured cable 10Sqmm on surface	Providing & Laying of one number aluminium conductor, PVC insulated and PVC sheathed armoured/ XLPE power cable, 1.1 KV grade of following sizes on wall surface as required.	Makes: KEl/Anchor/Finolex/GrandLay.	ZXZ-5Sq.mm+1X2.5Sq.mm Earth wire	sizes of FRLS PVC insulated copper conductor, single core cable in surface/ recessed steel conduit as required.
	Q			4	15			20 /		90		
	469			161	100			255		332		
	Rupees Four Hundred Sixty Nine Only			Rupees One Hundred Fifty One Only	Rupees One Hundred Only			Rupees Two Hundred Fifty Five Only		Rupees Three Hundred Thirty Two Only		
	Each		h	P/Mtr	P/Mtr			P/mtr		PMtr		
	2814			6040	1500			5,000		29880		

12		-22	±			8		-	φ		-
Earthing with G.I. earth pipe 4.5 metre long, 40 mm dia including accessories, and providing masonry enclosure with cover plate having locking arrangement and watering pipe etc. (but with charcoal/ coke and salt) as required.	Makes: L&T, Legrand,Schenider	Double door-12 way	Supplying and fixing of following way, single pole and neutral sheet steel MCB distribution board, 240 volts, on surface / recess, complete with tinned copper bus- bar, wire-set, neutral link, earth bar, din-bar, detachable gland plate, blanking plate, cable, identification labels interconnections, phosphatized and powder painted, including earthing etc. as required (But without MCB/RCCB/Isolator).	Makes: L&T, Legrand, Schenider	40 Amps. Cat-A.	Supplying and fixing following rating, double pole, (single phase and neutral), 240 volts, residual current circuit breaker (RCCB), having a sensitivity current 30 milli amperes in the existing MCB DB complete with connections, testing and commissioning etc. as required.	Makes: L&T, Legrand,Schenider	40 Amps. Cat-A.	commissioning etc. as required.	Makes: L&T, Legrand, Schenider	Single pole. Cat-A.
×		, y ,			710			In			13
5819		2055			2272			426			239
Rupees Five Thousand Eight Hundred Nineteen Only		Rupees Two Thousand Fifty Five Only			Rupees Two Thousand Two Hundred Seventy Two Only			Rupees Four Hundred Twenty Six Only			Rupees Two Hundred Thirty Nine Only
P/Set		Each			Each			Each			Each
5819		4110			4544			852			2868

==		5		-	4	13
MakasiMinra Baini & Banasania	LED Round Downlighter (Surface) 18Watts	Providing and Fixing of IP20 LED fixture of 18 watt +/- 1 W LED Surface Mounted Downlighter Round Shape with minimum system lumen efficacy of 100 lm/W with Polycarbonate housing pressure die cast heat sink and P.F.>0.95 with THD<10% CRI 80.The LED shall be tested with LM80-08 standard with Useful life of 50000 Hrs at L70. The LEDs used in the luminaire shall have CCT of ANSI Bin 5700 K with CRI of minimum 80.The Input voltage range shall be 150V to 270V, 50/60 HZ complete with all accessories, including connections, testing and commissioning etc.as required complete in all respects. With 5 Years Warranty	Makes: Havells, Bajaj & wipro.	LED fixture 1x18 Watt Surface Mounted 4 Feet Ultra Bright LED Tubelight	Providing and Fixing of IP20 LED Surface mounted CRCA Powder Coated Box Type Channel with Pro LED Lamp Suitable for mounting 1 X 18 W LED Tube T8 type having minimum system efficacy of 100 lm/W, P.F.>0.95 with THD<10%, CCT 6500 K,CRI 80,Surge Protection 2 Kv.The LED with Useful life of 50000 Hrs at L70. The Input voltage range shall be 150V to 270V, 50/60 HZ complete with all accessories, including connections, testing and commissioning etc.as required complete in all respects. With 5 Years Warranty	for conductor earth electrode, including connection/ termination with GI thimble etc. as required.
	10		38			25
	1821		867			33
	Rupees One Thousand Eight Hundred Twenty One Only		Rupees Eight Hundred Sixty Seven Only			Rupees Thirty Three Only
	Each		Each			P/Mtr
	18210		32946			825

Ī	=	-	4	=	-	क
Total	Make; Usha(BLDC),Bajaj,Crompton.	Ceiling Fan 1200 mm sweep, Category-A	Providing, Installation, testing and commissioning of BLDC ceiling fan (5 star rating), including wiring the down rods of standard length (up to 30 cm) with 16/0.20 mm twin twisted flexible, cotton braided, copper cable, including providing and fixing phenolic laminated sheet cover on the fan box and earthing etc. as required:	makes: Havells, Wipro & Panasonic.	LED Street Light-30 Watts	aluminium housing with high power LED as lighting source and lens aluminium housing with high power LED as lighting source and lens embedded PC cover having iP65 protection and impact resistance of IK07 with 10 kV Built-in surge Protection Device. The luminaire shall have CCT of 5700K and CRI of minimum 80, PF>0.95 and THD>10% LED shall be compliant with Useful L70 life of 50000 Hrs. Driver efficiency should be 85% to operate in input voltage range of 100V to 270V. (With 5 Years Warranty)
	36			N.	N	
	4323				4112	
	Rupees Four Thousand Three Hundred Twenty Three Only				Rupees Four Thousand One Hundred Twelve Only	
	Each				Each	
432624	155628				8224	

salvalue of quantity absoluted and approved for 2, 432 624 to land

-1	Ch		~	4			ω		-	N	-	_	П	No.	Uppe	MAN
3X1.5 Sq.mm	Supplying and drawing following sizes of FRLS PVC insulated copper conductor, single core cable in the existing surface/ recessed steel/ PVC conduit as required.	Makes: Plaza/KEI/SCI	2 X 10 sq. mm + 1 X 6 sq. mm earth wire	Wiring for circuit/ submain wiring alongwith earth wire with the following sizes of FRLS PVC insulated copper conductor, single core cable in surface/ recessed steel conduit as required	Makes: Plaza/KEI/SCI	2X2.5Sq.mm+1X2.5Sq.mm Earth wire	Wiring for circuit/ submain wiring alongwith earth wire with the following sizes of FRLS PVC insulated copper conductor, single core cable in surface/ recessed steel conduit as required.	Makes: Plaza/KEI/SCI	2X1.5Sq.mm+1X1.5Sq.mm Earth wire	Wiring for circuit/ submain wiring alongwith earth wire with the following sizes of FRLS PVC insulated copper conductor, single core cable in surface/ recessed steel conduit as required.	Group C Makes:- Legrand(Myrius), Schiender(Livia), Anchor Roma(Plus).	Wiring for light point / fan point / exhaust fan / call bell point with 1.5 Sq. mm. PVC insulated heat resistant flame retardant (HRFR) and low smoke single core (flexible) copper conductor cable in surface/recessed steel conduit with modular switch, modular plates, suitable G.I. box and earthing the light point with 1.5 Sq.mm. HRFRLS/PVC insulated single core copper conductor cable as required Make:- KEI/SCI/Plaza		DESCRIPTION	Upper Bhalwal, Distt Kangra(HP)(SH: Providing E.I there in).	E OF WORK: C/O 3 NOS CISCONOS SCHEDULE OF QUANT
10			œ		35			20			34	8 60 7 60 7	1	QTY.		TNAUS
111			793		395			361			1824		FIGURES		ob No. Be	YTI
Rupees One Hundred			Rupees Seven Hundred Ninety Three Only		Rupees Three Hundred Ninety Five Only			Rupees Three Hundred Sixty One Only			Rupees One Thousand Eight Hundred Twenty Four Only		WORDS	RATES	EARNEST MONEY: Rs.1,58,1771-6nly. TIME ALLOWED: One Year	
P/Mtr			P/Mtr		P/Mir			P/Mtr			P/Pt			UNIT	1,58,1771-6r 32001-only ear	
1110			6344		13825	,	,	7220	1		62016			AMOUNT	ıly.	

-		10		-	9			œ		-	7		σ		=
Double door-12 way	Makes: Legrand, Schiender, L&T	Supplying and fixing of following way, single pole and neutral sheet steel MCB distribution board, 240 volts, on surface / recess, complete with tinned copper bus- bar, wire-set, neutral link, earth bar, din-bar, detachable gland plate, blanking plate, cable, identification labels interconnections, phosphatized and powder painted, including earthing etc. as required.(But without MCB/RCCB/Isolator).	Makes: Legrand, Schiender, L&T	40Amps. Cat-A.	Supplying and fixing following rating, double pole (single phase & neutral) 240 volts, residual current circuit breaker (RCCB), having a sensitivity current up to 300 miliampers in the existing MCB DB complete with connections, testing and commissioning etc. as required.	Makes:- Legrand, Schlender, L&T	40 Amps. Cat-A.	Supplying and fixing following rating, double pole, 240 volts, isolator in the existing MCB DB complete with connections, testing and commissioning etc. as required.	Makes: Legrand, Schiender, L&T	Single pole. Cat-A.	Supplying and erection of 6 amps. to 32 amps. rating, 10 KA breaking capacity, 240 volts, 'C' curves, miniature circuit breaker of following poles in the existing MCB DB complete with connections etc. as required:-	Makes: Legrand(Myrius),Schiender(Livia),Anchor Roma(Plus)	Supplying and fixing suitable size GI box with modular plate and cover in front on surface or in recess, including providing and fixing 3 pin 5/6 amps modular socket outlet and 5/6 amps modular switch, connection etc. as required.	Makes: Plaza/KEI/SCI	3x2.5Sq.mm
n.				_			1			5		3			ਰੀ
1943				2238			409			226		502		٠	171
Rupees One Thousand Nine Hundred Forty Three				Rupees Two Thousand Two Hundred Thirty Eight Only			Rupees Four Hundred Nine Only			Rupees Two Hundred Twenty Six Only		Rupees Five Hundred Two Only			Seventy One Only
Each				Each			Each			Each		Each			P/Mir
1943				2238			409			1130/		1506			2565

	-			T	T	4			13	12	3
	ii Make:- Usha(Technix Plus),Bajaj,Havells with 3 rated star	i Ceiling Fan 1200 mm sweep, Category-A	Providing, Installation, testing and commissioning of ceiling fan without regulator, including wiring the down rods of standard length (up to 30 cm) with 16/0.20 mm/win twisted flexible, cotton braided, copper cable, including providing and fixing phenolic laminated sheet cover on the fan box and earthing etc. as required. (With Five years warranty)	Makes: Bajaj(Cat No- BPSLR Surface 18W LED WH RD SD)/Panasonic/Havells ,wipro	i LED Downlighter 18Watts	Providing and installation of following type of surface mounting squarefround type LED panel Light with aluminium die cast housing in white finish with anti-glare polycarbonate diffuser and seprated energy efficient constant current, nonintegral, electronic driver, suitable for input voltage: AC 220-240 V, 50/60Hz, complete with all accessories, connections, testing etc. as required (With Five years warranty).	Makes: Jaquar, Havells, wipro	LED Tube Light 4Feet Long	Supplying and fixing of LED Tube Light 22watts ,5700K ,(Five YEAR WARRANTY) and it should be compatible with specification e.i. Power Factor > .9,Harmonic Distortion<10% and efficacy >100 Lumens per watt, suitable for input voltage. AC 220-240 V, 50/60Hz, complete with all accessories, connections, testing and commissioning etc as required.(With Five years warranty)	Supplying and laying 6 SWG G1, wire at 0.50 metre below ground level for conductor earth electrode, including connection/ termination with GI thimble etclass required.	Earthing with G.I. earth pipe 4.5 metre long, 40 mm dia including accessories, and providing masonry enclosure with cover plate having locking arrangement and watering pipe etc. (but with charcoal/ coke and salt.) as required
	12			4			18	;		25	-
	2869	1		1254	-		121	4		33	4624
	Eight Hundred Sixty Nine Only	Rupees Two Thousand		Two Hundred Fifty Four Only	Ruppes One Thousand		Twenty One Only	Rupees Seven Hundred		Rupees Thirty Three Only	Rupees Four Thousand Six Hundred Twenty Four Only
7	Each	4		Each			1	Each		P/Mir	P/Set
158171	34428			5016	,			12978		825	4624

Schoolide of Twombilly ahertand and approved for a 158177 of body

2.3	2.2	2	2		-	NO	SR.	Disp (Sub	
2 X 6 sq. mm + 1 X 6 sq. mm earth wire	2 X 4.0 sq. mm + 1 X 4.0 sq. mm earth wire	2 X 2.5 sq. mm + 1 X 2.5 sq. mm earth wire	Wiring for circuit/sub-main with following size PVC insulated heat resistant flame retardant (HRFR) and low smoke single core (flexible) copper conductor cable in surface/recessed steel conduit along with 1 No.HRFRLS/PVC insulated single core copper conductor cable of same size for earthing as required.Make:-KEI/Anchar/Polycab/Finolex/Grandlay	Group C.	Winng for light point/ fan point/ exhaust fan point/ call bell point with 1.5 sq.mm FRLS PVC insulated copper conductor single core cable in surface / recessed steel conduit, with piano type switch, phenolic larminated sheet, suitable size MS box and earthing the point with 1.5 sq.mm. FRLS PVC insulated copper conductor single core cable etc as required.Make: Anchor (Panta)/ SSK(Touch)		DESCRIPTION	NAME OF WORK: Construction of Government Ayurvedic Dispensary Building at Batot in Tehsil Bharmour Distt. Chamba H.P (Sub-Head:- Providing E.I therein.)	SCHEDULE OF QUAN
N	30	20			16	100	אום.	ų.	QUAN
564	395	332			1588	FIGURES		80 on 40	TITY
Rupees Five Hundred Sixty Four Only	Rupees Three Hundred Ninety Five Only	Rupees Three Hundred Thirty Two Only			Rupees One Thousand Five Hundred Eighty Eight Only	WORDS	RATES	ESTIMATED COST: Rs. 94,203/-only. EARNEST MONEY: Rs.1900/-only TIME ALLOWED: Six Months	
P/rmt	P/rmt	P/rmt			P/Point		UNIT	94,203/-on .1900/-only onths	
1128	11850	6640			25408	1	AMOUNT	ķ	

6.1	o	oı	4	4	ů.	ω
Supplying and fixing Ding Dong bell suitable for single phase, 230 volts, complete as required Make: - Anchor/GoldMedal/SSK	Supplying and fixing metal box of 180mm X 100mm X 60mm deep (nominal size) on surface or in recess with suitable size of phenolic laminated sheet cover in FRLSont including providing and fixing 6 pin 5/6. & 15/16 amps socket outlet and 15/16 amps piano type switch, connection, painting etc. as required.Make: Anchor (Panta)/ SSK(Touch)	Supplying and fixing metal box of 150mm X 75mm X 60mm deep (nominal size) on surface or in recess with sultable size of phenolic laminated sheet cover in FRLSont including providing and fixing 3 pin 5/6 amps socket outlet and 5/6 amps plano type switch, connection, painting etc. as required.Make: Anchor (Panta)/ SSK(Touch)	4 X 4 sq. mm	Winng for light/ power plug with 4X4 sq. mm FRLS PVC insulated copper conductor single core cable in surface/ recessed steel conduit alongwith 1 No 4 sq.mm FRLS PVC insulated copper conductor single core cable for loop earthing as required Make:- KEl/Anchar/Polycab/Finolex/Grandlay	S/D 3 X 2.5 sq. mm	Supplying and drawing following sizes of FRLS PVC insulated copper conductor, single core cable in the existing surface/ recessed steel/ PVCconduit as required. Make:- KEI/Anchar/Polycab/Finolex/Grandlay
	4	N	12		10	
206	621	469	703		151	11
Rupees Two Hundred Six Only	Rupees Six Hundred Twenty One Only	Rupees Four Hundred Sixty Nine Only	Rupees Seven Hundred Three Onty		Rupees One Hundred Fifty One Only	
Each	Each	Each	Phrot		Pirmt	
206	2484	938	8436		1510	

8.1		·co	7,2	7.1	7
LED 12 Watt Square	Make:-Panasonic/ Wipro/Philips	Providing and Fixing of IP20 LED fixture of 12 watt +/- 1 W LED Surface Mounted Downlighter Square Shape with minimum system lumen efficacy of 100 lm/W with Polycarbonate housing pressure die cast heat sink and P.F.>0.95 with THD<10% ,CRI 80.The LED shall be tested with LM80-08 standard with Useful life of 50000 Hrs at L70 . The LEDs used in the luminaire shall have CCT of ANSI Bin 5700 K with CRI of minimum 80.The Input voltage range shall be 150V to 270V, 50/60 HZ complete with all accessories, including connections, testing and commissioning etc. as required complete in all respects with 5- years warranty	Cat No: LGLZU1X0Z2XC	LED Tube Fixture 22Watt	Supplying & tixing following type of Surface mounted luminaires Aluminium Batten Tubes, white power coated CRCA housing diffusser to avoid glaire, it should be compatible with specification i.e. Power Factor > 0.9. Harmonic Distortion < 20% and efficacy > 100 Lumens per watt, CRI rating> 70 suitable for input voltage: AC 220-240 V, 50 Hz, complete with all accessories, connections, testing and commissioning etc. as required with 5- years warranty. Make- Jaquar, Panasonic, Wipro
2			4		W 10 2 7 7 0
1412			639		
Rupees One Thousand Four Hundred Twelve Only			Rupees Six Hundred Thirty Nine Only		
Each			Each		
2824			2556		

73	11.3	3.	t	9	ω
Providing and fixing of IP65 Bulkhead led fixture 10 W +/- 1 W Wall Mounted with minimum system lumen efficacy of 100 lm/W with Pressure Die Cast Aluminum housing. Polycarbonate Opal Diffuser and P.F.>0.95 with THD<10% ,CRI 80. The LED shall be tested with LM80-08 standard with Useful life of 50000 Hrs at L70. The LEDs used in the luminaire shall have CCT of ANSI Bin 5700 K only with CRI of minimum 80. The Input voltage range shall be 140V to 280V, 50/60 HZ complete with all accessories, including connections, testing and commissioning etc.as required complete in all respects, with 5- years warranty. Make-Panasonic, Wipro, Philips.	9 Watt LED, B-22	Supplying and fixing LED retrofit lamp suitable for 8-22 holder base fittings with polycarbonate diffuser and aluminium heat sink as required complete in all respects.Make- Tisva,Panasonic,Wipro	Supplying and fixing batten/ angle holder including connection etc. as required.Make :- Anchor/SSK/GoldMedal	LED Panel Light 36 watt 1'x4' ,cat no. CRCO18S036HP57 (Make: /Wipro/Panasonic/Philips).	Providing and installation of LED fixture 1200mmX300mm 36 W+/- 1W Surface Mounted with PMMA diffuser with having minimum system lumen efficacy > 110lm/W with CRCA Housing and PMMA Diffuser with P.F.>0.95,THD<10%,CCT 5700 K ,CRI 80.The LED shall be tested with LM80-08 standard with Useful life of 50000 Hrs at L70, with 5- years warranty. The Input voltage range shall be 150V to 270V, 50/60 HZ complete with all accessories, including connections, testing and commissioning etc.as required complete in all respects
	2		2	N	
	66		88	3934	
	Rupees Ninety Nine Only		Rupees Eighty Eight Only	Rupees Three Thousand Nine Hundred Thirty Four Only	
	Each		Each	Each	
	198		176	7868	

15.1	5	4	4	13.1	ä	12.1
Single pole	Supplying and fixing 6 amps to 32 amps rating, 240/415 volts, 10 kA, "C" curve, miniature circuit breaker suitable for inductive load of following poles in the miniature circuit breaker suitable for inductive load of following poles in the existing MCB DB complete with connections, testing and commissioning etc. as required.Make:- L&T/ Legrand/ Schneider	12 way, Double door	Supplying and fixing following way, single pole and neutral, sheet steel, MCB distribution board, 240 volts, on surface/ recess, complete with tinned copper bus bar, neutral bus bar, earth bar, din bar, interconnections, powder painted including earthing etc. as required. (But without MCB/RCCB/Isolator) Make :- L&T/Legrand/Schenider	Exhaust Fan, Light duty, (Domestic)	opening, including making the hole to suit the size of the above fan, making good the damages, connections, testing and commissioning etc. as required: Make:-Crompton/Bajaj/Havells	LED Bulk Head Light 10W Makes:- Wipro
o		4		-		4
239		2055		2567		1420
Rupees Two Hundred Thirty Nine Only		Rupees Two Thousand Fifty Five Only		Rupees Two Thousand Five Hundred Sixty Seven Only		Rupees One Thousand Four Hundred Twenty Only
Each		Each		Each		Each
1434		2055		2567		5680

	19	100	17.1	17	16.1	र्क
Total	Supplying and laying 8 SWG G.I. wire at 0.50 mtr. below ground level for earth electrode conductor, including soldering etc. as required.	Earthing with G.I. earth plate 600 mmx600 mmx 6 mm thick, including accessories and providing masonry enclosure with cover plate having locking arrangement and watering pipe of 2.7 metre long etc. with charcoall coke and sait) as required.	40 Amps	Supplying and fixing following rating, double pole, (single phase and neutral), 240 volts, residual current circuit breaker (RCCB), having a sensitivity current 30 milli amperes in the existing MCB DB complete with connections, testing and commissioning etc. as required.Make:- L&T/Legrand/ Schnelder	40 Amps	Supplying and fixing following rating, double pole, 240 volts, isolator in the existing MCB DB complete with connections, testing and commissioning etc. as required.Make:- L&T/ Legrand/ Schneider
	20	4	4		4	
	53	6487	2272		426	
	Rupees Fifty Three Only	Rupees Six Thousand Four Hundred Eighty Seven Only	Rupees Two Thousand Two Hundred Seventy Two Only		Rupees Four Hundred Twenty Six Only	
	P/Set	P/Set	Each		Each	
94203	1060	6487	2272		426	

Charles to the cherche

Executive Engineer
Electridal Division
HPPWD Palampur

	2.4	23	2.2	21	N			÷	NO.	SR.	wiring	Name
	2×10sq.mm	2x4 Sq. mm.	2x2.5 Sq. mm.	2x1.5 Sq. mm.	Wiring for circuit/ submain wiring alongwith earth wire with the following sizes of FRLS PVC insulated copper conductor, single core cable in surface/ recessed medium class PVC conduit as required.	Makes:- (KEl/Anchor/Plaza , L&T(Entice)/Legrand(Myrius)/Schneider(Livia)	Group C	Wining for light point fan point exhaust fan point call bell point with 1.5 sq.mm FRLS PVC insulated copper conductor single core cable in surface recessed medium class PVC conduit, with modular switch, modular plate, suitable GI box and earthing the point with 1.5 sq.mm. FRLS PVC insulated copper conductor single core cable etc. as required.		DESCRIPTION	wiring in HP PWD B&R Division Office Building Shahpur, Distt. Kangra (H.P.)	SCHEDULE OF QUAN
-	43,367	190	180	500			18			OTY.	J.	QUAN
	678	353	277	217			1345		FIGURES		JOB NO Q.G	TITY
	Rupees Six Hundred Seventy Eight Only	Rupees Three Hundred Fifty Three Only	Rupees Two Hundred Seventy Seven Only	Rupees Two Hundred Seventeen Only			Rupees One Thousand Three Hundred Forty Five Only		WORDS	RATES	ESTIMATED COST: Rs.3,04,997/-pnly. EARNEST MONEY: Rs.6100/-only TIME ALLOWED: Three Months	
	Meter	Per Meter	Per Meter	Per Meter			Per Point		The state of the s	UNIT	1.3,04,997/-or 1.6100/-only 9 Months	
,	29403	67070	49860	10850			29590			AMOUNT	ıly.	

Y ...

	Rupees Six Hundred Sixty Seven Only	667	8	8 Module	tn .
-	Rupees Five Hundred Forty Five Only	545	u	6 Module	4
	Rupees Four Hundred Forty Seven Only	447	6	4 Module	ů.
-	Rupees Four Hundred Six Only	406	22	3 Module	4 20
	Rupees Three Hundred Eighty Five Only	385	Ch .	2 Module	4.1
				Supplying and fixing following size/ modules, GI box alongwith modular base & cover plate for modular switches in recess etc as required.	4
				Marcon 1977 amond/Cohmoidor	
	Rupees Two Hundred Thirty Four Only	234	10	Bell push	3.5
	Rupees Three Hundred Forty Three Only	343	25	15/16 amp modular socket outlet	34
	Rupees One Hundred Eighty Nine Only	189	65	5/6 amp modular socket outlet	3
	Rupees Two Hundred Twenty Eight Only	228	25	15/20 Amps. Modular switch	3.2
_	Rupees One Hundred Thirty Three Only	133	75	5/10 Amps. Modular switch	ü
			F	Supplying and fixing following modular switch/socket on the existing modular plate & switch box including connections but excluding modular plate etc. as required.	ω

									- 11	_	- 3
7.2	7.1	7		6.2	6.1	o			5 1		4 6
Double door-6 way	Double door-4 way	Supplying and fixing of following way, single pole and neutral sheet steel MCB distribution board, 240 volts, on surface / recess, complete with tinned copper bus- bar, wire-set, neutral link, earth bar, din-bar, detachable gland plate, blanking plate, cable, identification labels interconnections, phosphatized and powder painted, including earthing etc. as required:-	Makes:- L&T/Legrand/Schneider.	MCB DP 63 Amp.	Single pole. 6 Amp - 32 Amp. Cat-A.	Supplying and erection of MCB of following rating, 10 KA breaking capacity, 240 volts / 415 volts, 'C' curves, miniature circuit breaker of following poles in the existing MCB DB complete with connections etc. as required.	Makes:- L&T/Legrand/Schneider.	Stepped type Modular Fan regulator (2 module)	Supplying and fixing following modular switch/ socket on the existing modular plate & switch box including connections but excluding modular plate etc. as required.	Makes:- L&T/Legrand/Schneider.	12 Module
_	7	12		ω	27			6			4
1878	1548			1426	268			740			813
Rupees One Thousand Eight Hundred Seventy Eight Only	Rupees One Thousand Five Hundred Forty Eight Only			Rupees One Thousand Four Hundred Twenty Six Only	Rupees Two Hundred Sixty Eight Only			Rupees Seven Hundred Forty Only			Rupees Eight Hundred Thirteen Only
Each	Each			Each	Each			Each			Each
1878	1548			4278	7236			4440			3252

		10		00		7.4	i
Makes: Philips/ Wipro/ Bajaj	18 Watt LED Tube fixture with pro LED lamp	Providing and fixing of IP20 LED Surface mounted CRCA Powder Coated Box type Channel system with Pro LED Lamp Suitable for mounting 1 X 18 W LED Tube T8 type having minimum efficacy of 100 lm/W, P.F.>0.95 with THD<10%, CCT 6500 K,CRI 80,Surge Protection range 2 KV.The LED with Useful life of 50000 Hrs at L70 with five years warranty. The Input voltage shall be 150V to 270V, 50/60 HZ complete with all accessories, including connections etc. as required.	Makes:- Anchor/Goldmedal /SSK	Supplying and fixing call bell/buzzer suitable for single phase, 230 volts, complete as required.	manes Loi / Legrand/Schneider.	Double door-16 way	Double door-8 way
	o			10		уш.	-
	1512			228		2971	1914
	Rupees One Thousand Five Hundred Twelve Only			Rupees Two Hundred Twenty Eighl Only		Rupees Two Thousand Nine Hundred Seventy One Only	Rupees One Thousand Nine Hundred Fourteen Only
	Each			Each		Each	Each
	9072		1	2280		2971	1914

			1			6
Total	Makes:- Usha/Anchor/Bajaj	Wall Mounting Fan 400mm	Providing, installation, testing and commissioning of wall fan, including wiring with 1.5 sq. mm FRLS PVC insulated, copper conductor, single core cable etc. as required.	Makes: Philips/ Wipro/ Bajaj	LED Mirror Light 10 Watt	Surface Mounted 2 feet with Polycarbonate diffuser with extruded aluminium housing having minimum system lumen output 1000 lumens and system lumen efficacy of 100 lm/W with P.F.>0.95 with THD 20%, CRI 80. The LED with Useful life of 50000 Hrs at L70 with five years warranty. The LEDs used in the luminaire shall have CCT of ANSI Bin 6500 K with CRI of minimum 80. The Input voltage range shall be 150V to 270V, 50/60 HZ complete with all accessories, including connections, testing and commissioning etc.as required complete in all respects.
		4			2	
		3042			566	
		Rupees Three Thousand Forty Two Only			Rupees Five Hundred Sixty Six Only	
		Each			Each	
304997		12168			1132	

School of quantity chalcol and opposed for 304 997 rolay

Executive Engineer Electrical Division HPPWO Palampur

	SCHEDULE OF QUANTITY	QUA	NITY			
(H.P)	NAME OF WORK :- C/O War Museum at Dharamshala Distt Kangra (H.P) (SH: Damaged report of AC Units).	Je	O ON doL	ESTIMATED COST: Rs. 2,05,037/-only. EARNEST MONEY: Rs. 4200/-only TIME ALLOWED: Six Months	. 2,05,037/-or . 4200/-only lonths	rily.
	DESCRIPTION	QTY.		RATES	TINU	AMOUNT
		P	FIGURES	WORDS		
1.00	Providing and installation of outdoor Unit with Power Supply 1 Phase 50 Hz, 230 V, ODU Dimension (H X W X D) (595 X 845 X 300), Breaker Size 20A, with piping size 12.7-6.4 MM, Operating Ambient Temperature Range Cooling 20-54*CDB, Heating Range -10 -24* CDB with swing compressor, making connections, testing etc.complete in all Respect with best satisfaction of engineer -in- Charge, Makes:- Daikin/ O-General/Mitusubhishi					
1.01	1.8 TR Split AC Hot and Cold ODU	ω	54049	Rupees Fifty Four Thousand Forty Nine Only	Each	162147
2.00	Providing and fixing of copper tube for refrigrent size (15.8 mm -9.52mm) for 1.8/ 2.0 T.R. Split AC unit as required complete in all respects and as per direction and satisfaction of Engineer in charge.	50	1350	Rupees One Thousand Three Hundred Fifty Only	Per metre	8100
3.00	Providing and fixing of Nitrile Tubular Insulation ac indoor to outdoor for COPPER PIPING as required complete in all respects and as per direction and satisfaction of Engineer in charge.	00	480	Rupees Four Hundred Eighty Only	Per metre	2880
4.00	Providing and laying of communication wire 2.5 Sq.mm. (4 core) as required complete in all respects and as per direction and satisfaction of Engineer in charge.	5	225	Rupees Two Hundred Twenty Five Only	Per metre	2250
5.00	Supplying and fixing of 25mm dia of PVC drain pipe along with the accessories in surface/recess including cutting the wall and making good the same in case of recessed conduit as required complete in all respects and as per direction and satisfaction of Engineer in charge.	15	180	Rupees One Hundred Eighty Only	Per metre	2700

	Tota	7.00 resp	6,00 and
		Providing Refrigerant R-32 for Out door Unit as required complete in all respects and as per direction and satisfaction of Engineer in charge.	Providing and fixing of Drain Pump as required complete in all respects and as per direction and satisfaction of Engineer in charge.
		89	22
hoe		1420	7800
The training of the training		Rupees One Thousand Four Hundred Twenty Only	Rupees Seven Thousand Eight Hundred Only
といって		Per Kg	Each
class on	205037	11360	15600

Phenos y menselp

Executive Engineer
Electrical Division
HPPWD Palampur

NAME OF WOR		NAUG	ΠTY	ESTIMATED COST: Rs. 86,159/-only.	86,159/-only	
NAME OF WORK :- (H.P) (SH: Damaged	NAME OF WORK :- C/O War Museum at Dharamshala Distt Kangra (H.P) (SH: Damaged report of Surveillance System).	jo	job No\\	ESTIMATED COST: Rs. 86,159/-on EARNEST MONEY: Rs.1800/-only TIME ALLOWED: Six Months	86,159/-only 1800/-only onths	
SR	DESCRIPTION	QTY.		RATES	UNIT	AMOUNT
NO.			FIGURES	WORDS		
Supplying, Network C Sensor: 1/2 1920 x 108 ON),0Lux v 120db; IR Distance: Interface: Detection; ICMP, HT UPnP, SM 1.00 SFTP, AR PROFILE 1/100000 H.265+/H.2 Streams: M 10°C ~ +50 PoE (IEEEE be available 1/UL etc. Axis/Avigile	Supplying, installation, testing and commissioning of 3MP IP Dome/Bullet Network Camera with Face Detection Specifications as follow: Image Sensor: 1/2.7" 3 Megapixel Progressive Scan CMOS; Image Pixels: Max: 1920 x 1080 Pixels (3.0 MP); Min. Illumination: 0.003 Lux@ (F1.2,AGC ON),0Lux with IR; Day/Night Auto (ICR) / Color / Black & White; WDR 120db; IR Led: 4 Pcs High Power LED Array; Digital Zoom 16X; IR Distance: 30~40 Meters; Lens Mount: 3.6MM fixed Lens; Network Interface: 10/100 MBPS RJ45 Connector; Intelligent Al Feature: Face Detection; Line Crossing; Active Deterrence; Network Protocol: TCP/IP, ICMP, HTTP, HTTPS, FTP, DHCP, DNS,DDNS, RTP,RTSP, NTP, UPnP, SMTP, IGMP, 802.1X, QoS, IPv4, IPv6,UDP, SSL/TLS, PPPoE, SFTP, ARP, SNMP,Open Network Video Interface (PROFILE S, PROFILE T), ISAPI; Electronic Shutter Speed: Manual/Auto (1/25~1/100000 S); Should support ONVIF; Video Encoding: H.265Al/ H.265+/H.264+/H.264; Video Bitrate: 128kbps ~ 8Mbps; Video Streams: Main Stream: 25 FPS, 1920 x 1080; Operation Temperature: -10°C ~ +50°C; Operation Humidity 0% ~ 90%; Power Supply: DC12V, PoE (IEEE802.3af) (Class 0) 25%; IP Rating: IP67; SD Card Slot should be available(256GB); Certifications: CE,FCC, RoHS, BIS & IEC 60950-1/UL etc. as required complete in all respects. (Make: Axis/Avigilon/Securus/Panasonic)	N.	13605	Rupees Thirteen Thousand Six Hundred Five Only	Each	27210

4.00	3.00	2.00				
Hard Disk etc. as required complete in all respects. (Makes: WD/Seagate)	Commissioning of corts POE 10/100 M IEEE802.3 af/at Sind; Power Wattagrod; Power Wattagrod; Power Wattagrod be supported for Meters; Power On Meters; Power Should support extraction as requires/Cisco)	Supplying, installation, testing and commissioning of 4 Channel NVR with Face Detection Feature; Embedded Linux Operating System; Preview, Record, Playback, Backup, Network; 1 x HDMI; Supports upto 5 Megapixel Network Camera Input; Supports 4 Channels Network Cameras; Audio Compression - G.711a; Audio I/O - 1CH RCA In / 1CH RCA Out; Support H.265AI, H.265+, H.265, H.264 Video Compression; Always/Schedule/Alarm recording/Motion Detection Recording/Face Detection & Vehicle Detection; Supports 1 SATA HDD upto 8 TB on; 1 x RJ45 10M/100M /1000M; 1 x USB 2.0; 1 x USB 3.0 for Faster Backup; Supports Line Crossing, Face Detection, Vehicle Detection & Active Deterrence; Supports Blacklist/Whitelist to prevent unauthorized Network Access; Certifications - CE,FCC, ROHS, BIS etc. as required complete in all respects. (Make: Axis/ Avigilon/ Securus /Panasonic)				
_	_					
8969.00	11085	12093				
Rupees Eight Thousand Nine Hundred Sixty Nine Only	Rupees Eleven Thousand Eighty Five Only	Rupees Twelve Thousand Ninety Three Only				
Each	Each	Each				
8969	11085	12093				

	7.00	6.00	5.00
Total	Supplying and fixing of 25mm dia medium class PVC conduit along with accessories in surface/recess including cutting the wall and making good the same in case of recessed conduit as required. (Make: AKG/Kalinga/Diplast/BEC)	Supplying, Installation, Testing & Commissioning of HDMI Cable of Length 3 Metre etc. as required complete in all respects. (Make: Kramer/Manhattan/Crestron)	Supplying and drawing of UTP 4 Pair CAT-6 cable in existing PVC conduit etc. as required complete in all respects, (Make: Molex/Dlink/Beldon)
	120	4	200
	99	2922	60
	Rupees Ninety Nine Only	Rupees Two Thousand Nine Hundred Twenty Two Only	Rupees Sixty Only
	Per metre	Each	Per metre
86159	11880	2922	12000

Executive Engineer Electrical Division HPPWD Palampur

9laz glaz arra 3.00 shac span	2.00 inst of E	1.00 typ	NO.	(H.P) (SH:	NAME OF
Providing and Fixing Weather proof standard fire hose cabinet made of 18 SWG powder coated fibre, sheet having single or double opening glazed (3.0 mm thick glass) shutter including necessary locking arrangement by allan key, stove enamelled Fire red finish (as per IS: 5, shade no. 536) with "Fire Hose" marked on front, suitable for housing 2 nos. 15m long 63 mm dia Hose pipe, 1 No. branch pipe & nozzle spanner as required complete in all respects and to the best satisfaction of Engineer-in-charge, Make: Minimax/OMEX/ Padmini	Providing & Fixing of 63 mm dia 15 m long non-percolating flexible hose (RRL- type A) as per IS: 636. Type A with Gun Metal male & female instantaneous type coupling (IS 903) (For internal and External hydrant system) as required complete in all respects and to the best satisfaction of Engineer-in-charge. Make: Minimax/OMEX/ Padmini	with 80 mm N.B. flanged inlet, s.s spindle controlled 63 mm dia female instantaneous outlet type. SS coupling, blank cap, chain, twist release type lug & all accessories Conforming to IS standards as required complete in all respects and to the best satisfaction of Engineer-in-charge. Make: Minimax/OMEX/ Padmini	oviding & fixing Gun matal for historia	(H.P) (SH: Damaged report of Fire Fighting System).	NAME OF WORK :- C/O War MISSING SCHEDULE OF QUANTITY
	2	_	QTY.	1	QUAN
7305.00	11045.00	17979.00	FIGURES	job No ∴ 2	YTITI
Rupees Seven Thousand Three Hundred Five Only	Rupees Eleven Thousand Forty Five Only	Rupees Seventeen Thousand Nine Hundred Seventy Nine Only	RATES WORDS	ESTIMATED COST: Rs. 57,942/-only. EARNEST MONEY: Rs.1200/-only TIME ALLOWED: Six Month	
Each	Each	Each	TINU	. 57,942/-on :.1200/-only lonth	
7305	22090	17979	AMOUNT	ıly.	

		4.01	4.00
	Total	4.01 80 mm Dia	Providing Cast iron /steel Butterfly Valve Confirming to type P.N 1.6 of I.S 13095-1991 Complete with Flanges bolt, nuts, gasket etc. As per table 'E' specification complete in all respect hydraulically test to 20 K./sqcm. as required complete in all respects and to the best satisfaction of Engineer-in-charge, Makes:-Zoloto/Sant/Audco
		N	
a		5284.00	1
からないできない		Rupees Five Thousand Two Hundred Eighty Four Only	
411		Each	
checke	57942	10568	

3 Sur flan	Ma	2.2 2x	2.1 2x	2 re co	C 3	a	= W W W =	200	SR.	Daulatpu therein)	
Supplying and drawing following size of PVC insulated, heat resistant, flame retardant (HRFR) and low smoke single core (flexible) copper conductor cable in existing surface / recessed, Steel/PVC conduit as required.	Makes:- KEI / Anchor / Plaza/SCI	2x10 Sq. mm.	2x1.5 Sq. mm.	Wiring for circuit/sub-main with following size PVC insulated heat resistant flame retardant (HRFR) and low smoke single core (flexible) copper conductor cable in surface/recessed steel conduit along with 1 No.HRFRLS/PVC insulated single core copper conductor cable of same size for earthing as required.	Makes:- (KEl/Anchor/Plaza , L&T(Entice)/Legrand(Myrius)/Schneider(Livia)/SCI	Group C.	Wiring for light point/ fan point/ exhaust fan point/ call bell point with 1.5 sq.mm FRLS PVC insulated copper conductor single core cable in surface / recessed steel conduit, with modular switch, modular plate, suitable GI box and earthing the point with 1.5 sq.mm. FRLS PVC insulated copper conductor single core cable etc as required.		DESCRIPTION	NAME OF WORK :-C/O Additional accomodation in Govt. Sr. Sec. School Daulatpur in Distt. Kangra (H.P.)(SH: Providing E.I. to 2 Nos. classrooms therein)	SCHEDULE OF QU
			35			27	Vr. 3 0		QTY.		QUAN
		793	335			1823		FIGURES		Job No 13	ANTITY
		Rupees Seven Hundred Ninely Three Only	Rupees Three Hundred Thirty Five Only			Rupees One Thousand Eight Hundred Twenty Three Only		WORDS	RATES	EARNEST MONEY: Rs.1,45,751/-only. TIME ALLOWED: One Year	
		Per Meter	Per Meter			Per Point			TINU	Rs.1,45,751/ Rs.3000/-on ne Year	
		793	11725			49221			AMOUNT	-only. ly	

œ			7			6			on.		4		9
Supplying and fixing of following way, single pole and neutral sheet steel MCB distribution board, 240 volts, on surface / recess, complete with tinned copper bus- bar, wire-set, neutral link, earth bar, din-bar, detachable gland plate, blanking plate, cable, identification labels interconnections, phosphatized and powder painted, including earthing	Makes:- Legrand/L&T/Schneider.	40 Amps. Cat-A.	Supplying and fixing following rating, double pole (single phase & neutral) 240 volts, residual current circuit breaker (RCCB), having a sensitivity current up to 300 miliampers in the existing MCB DB complete with connections, testing and commissioning etc. as required.	Makes:- L&T / Legrand / Scheneider	40 Amp. Double pole. Cat-A.	Supplying and fixing following rating, double pole, 240 volts, isolator in the existing MCB DB complete with connections, testing and commissioning etc. as required.	Makes:- L&T / Legrand / Schenelder	Single Pole. Cat-A.	Supplying and erection of 6 amps. to 32 amps. rating, 10 KA breaking capacity, 240 volts, 'C' curves, miniature circuit breaker of following poles in the existing MCB DB complete with connections etc. as required:	Makes:- L&T / Legrand / Schenelder	Supplying and fixing G.I. Modular box of (140mmx78mmx50mm) size with modular plate and cover in recess including providing and fixing 5 pin 5/6 amps modular socket outlet and 5/6 amps, modular switch, connections etc. as required.	Makes:- KEI / Anchor / Plaza/SCI	3x1.5 Sq. mm.
		1			_				6		œ		10
		2715			488				265		582		111
		Rupees Two Thousand Seven Hundred Fifteen Only			Rupees Four Hundred Eighty Eight Only				Rupees Two Hundred Sixty Five Only		Rupees Five Hundred Eighty Two Only		Rupees One Hundred Eleven Only
		Each			Each				Each		Each		Per Meter
		2715			488				1590		4658		1110

13			73	4		= =	ě		0	
Supplying and fixing two module stepped type electronic fan regulator on the existing modular plate switch box including connections but excluding modular plate etc. as required.	Makes:- Usha/ Bajaj / Crompton	Ceiling Fan 1200 mm sweep, Cat-A	Providing, Installation, testing and commissioning of ceiling fan with step type electronic regulator, including witing the down rods of standard length (up to 30 cm) with 16/0.20 mm twin twisted flexible, cotton braided, including providing and fixing phenolic laminated sheet cover on the fan box and earthing etc. as required:- with Not Less than 3 rated star	Makes:- Panasonic (Cat No. PBHM01107) /Bajaj/Wipro	LED Bulkhead, 10Watt	Supplying and fixing of LED Bulkhead with a nominal system output of 1000 lumens, CCT 6500K Ceiling and wall mount LED bulk head serves as an excellent energy efficient alternative to CFL/incandescent bulkhead luminaires suitable for surface and wall mounting application as required complete with all accessories, connections, testing and commissioning etc with 5 year waranty.	Supplying and laying 6 SWG G.I. wire at 0.50 metre below ground level for conductor earth electrode, including connection/ termination with GI thimble etc. as required.	carming with G.I. earth plate 600 mm X 600 mm X 6 mm thick including accessories, and providing masonry enclosure with cover plate having locking arrangement and watering pipe of 2.7 metre long etc. with charcoal/ coke and salt as required.	Makes:- L&T/ Legrand / Schenelder	Double door-12 way
		00		2			15	4		Ą
		3191		1432			30	10244		2309
		Rupees Three Thousand One Hundred Ninety One Only		Rupees One Thousand Four Hundred Thirty Two Only			Rupees Thirty Only	Rupees Ten Thousand Two Hundred Forty Four Only	Hundred Nine Unly	Thousand Three
		Each		Each			Per Meter	Per Set		Each
		25528		2864			450	10244		2309

1 1

					_		
			ਰ				Ä
Total	Makes:- Havells/Wipro/Bajaj	45W LED Street Light	Supplying and fixing 45W LED street light made up of die cast aluminium housing with LED street optic LENS, offering uniform light distribution and individual LEDs with IP66 protection including connections, testing etc. as required complete in all respects with 5 years warranty.	Makes:-Philips/Wipro/Bajaj	LED 18 Watt Tube fixture	Coated Box type channel system with Pro LED Lamp suitable for mounting 1 x 18 W LED Tube T8 type having minimum efficacy of 100 lm/W, P.F.>0.95 with THD<10%, CCT 6500 K,CRI 80, Surge Protection range 2 kV. The LED with useful life of 50000 Hrs. at L70 with five years warranty. The Input voltage shall be 150V to 270V, 50/60 HZ along with all accessories, including connections, testing etc. as required complete in all respects.	Stepped Type Modular Fan regulator (2 Module)Make:- L&T/Legrand/Schenider.
		4		16			4
		4982		1508			737
		Rupees Four Thousand Nine Hundred Eighty Two Only		Rupees One Thousand Five Hundred Eight Only			Rupees Seven Hundred Thirty Seven Only
		Each		Each			Each
145751		4982		24128			2948

Schoolik of grandity choles and opposed for 2 145751700 10087

Executive Engineer
Electrical Division
HPPWD Palampur

MAN	NAME OF WORK :- R/M of E.I of VIDHAN SABHA Complex at Tapovan	NAUC	Y		ESTIMATED COST: Rs.4,98,129/-only.
01 DI TT	NAME OF WORK:- R/M of E.I of VIDHAN SABHA Complex at Tapovan Dharamshala Distt Kangra (H.P) (SH: Repair of E.I in Main Building and Minister block therein).	De J		OB NO 14	job No / TIME ALLOWED: Six Months
	DESCRIPTION	QTY.	T		RATE
Wiring for circuit/ sub of FRLS PVC insulting	Wiring for circuit/ submain wiring alongwith earth wire with the following sizes of FRLS PVC insulated copper conductor, single core cable in surface/ recessed steel conduit as required, Make: KEI/Plaza/Anchor.		FIG	FIGURES	WORDS
1.01 2 X 4 sq. mr	2 X 4 sq. mm + 1 X 4 sq. mm earth wire	18	4	477	Rupees Four Hundred Seventy Seven Only
1.02 2 X 6 sq.	2 X 6 sq. mm + 1 X 6 sq. mm earth wire	21	664	7	Rupees Six Hundred Sixty Four Only
Suppl Condu	Supplying and drawing following sizes of FRLS PVC insulated copper conductor, single core cable in the existing surface/ recessed steel/ PVC conduit as required. Make: KEI/Plaza/Anchor.				
2.01 3 X 1	3 X 1.5 sq. mm	25	112	N	Rupees One Hundred Twelve Only
	3 X 4 sq. mm	27	N	254	Rupees Two Hundred Fifty Four Only
Supp	Supplying and fixing following plane type switch/ socket on the existing switch box/ cover including connections etc. as required. Make:-				
2 5	S.P. 5/ 6 Amps one way switch, piano type. Make:- L&T/Anchor/Legrand	10	45	51	
D 0	Bell gush, piano type.Make:- L&T/Anchor/Legrand	22	64		Rupees Sixty Four Only
S.P.	S.P. 15/16 Amps one way switch, porcelain base/ piano type.Make:-	10	138		Rupees One Hundred Thirty Eight

9.02 S	9.01 S	9.00	8.00 8	7.00	6.00 P. (9	5.00	4.03	4.00	3.05	3.04
Single pole 16/32 Amp (Make:- Schneider/ Legrand/L&T)	Single pole 6 Amp (Make:- Schneider/ Legrand/L&T)	Supplying and fixing 6 A to 32 A rating, 240/415 V, 10 kA, "C" curve, miniature circuit breaker suitable for inductive load of following poles in the existing MCB DB complete with connections, testing and commissioning etc. as required.	Supplying and fixing Ding-Dong / Electronic musical bell, suitable for D.C./A.C. single phase, 230 volts complete as required:- Make:-GoldMedal/Anchor/SSK	Supplying and fixing call bell/ buzzer suitable for single phase, 230 volts, complete as required Make:- GoldMedal/Anchor/SSK	Supplying and fixing suitable size GI box with modular plate and cover in FRLSont on surface or in recess, including providing and fixing 6 pin 5/6 & 15/16 amps modular socket outlet and 15/16 amps modular switch, connection etc. as required. Make: Schneider (Livia)/ Legrand (Myrius)/L&T(Entice).	Supplying and fixing suitable size GI box with modular plate and cover in front on surface or in recess, including providing and fixing 3 pin 5/6 amps modular socket outlet and 5/6 amps modular switch, connection etc. as required. Make: L&T (Entice)/Schneider (Livia)/ Legrand (Myrius).	Bell push, Modular.	Supplying and fixing following modular switch/ socket on the existing modular plate & switch box including connections but excluding modular plate etc. as required.	6 pin 15/16 Amps socket outlet, porcelain base/ plano type.Make:- L&T/Anchor/Legrand	L&T/Anchor/Legrand
6	5		ω.	5	cn	5	5		10	10
268	268		189	119	760	591	209		149	73
Rupees Two Hundred Sixty Eight Only	Rupees Two Hundred Sixty Eight Only		Rupees One Hundred Eighty Nine Only	Rupees One Hundred Nineteen Only	Rupees Seven Hundred Sixty Only	Rupees Five Hundred Ninety One Only	Rupees Two Hundred Nine Only		Rupees One Hundred Forty Nine Only	Three Only
Each	Each		Each	Each	Each	Each	Each		Each	Each
2680	1340		567	595	3800	2955	1045		1490	730

12.01	12.00	11.0	11.02	#	11.00	10	10	10
		22	22	9		.02	10.01	10.00
Exhaust Fan, Light duty, (Domestic) 300 mm sweep Makes: Bajaj/Usha/Crompton	Providing and installation exhaust fan of following sizes in the existing opening, including making the hole to suit the size of the above fan, making good the damages, connections, testing and commissioning etc. as required.	11.03 25 Liter capacity water heater (Cat-A) Makes: Usha/Bajaj/Racold	15 Liter capacity water heater (Cat-A) Makes: Usha/Bajaj/Racold	11.01 10 Liter capacity water heater (Cat-A) Makes: Usha/Bajaj/Racold	Providing and installation of stationary storage type Electric water heater (Geyser) of various sizes by means of Expansion-bolts with nuts and washers, including embedding of expansion-bolts in the wall, providing and fixing of Non-return valve, Dead weight safety valve, 2 No C.P. connection rods 18" long, making good the damages, electrical connections, safety valve connections, testing and commissioning etc. as required:-	10.02 63 Amps. (Make:- Schneider/ Legrand/L&T)	40 Amps. (Make:- Schneider/ Legrand/L&T)	Supplying and fixing following rating, double pole, 240 V, isolator in the existing MCB DB complete with connections, testing and commissioning etc. as required.
2		241	4	2	* y	2	22	the etc.
2289		10298	9101	8366		620	491	
Rupees Two Thousand Two Hundred Eighty Nine Only		Rupees Ten Thousand Two Hundred Ninety Eight Only	Rupees Nine Thousand One Hundred One Only	Rupees Eight Thousand Three Hundred Sixty Six Only		Rupees Six Hundred Twenty Only	Rupees Four Hundred Ninety One Only	
Each		Each	Each	Each		Each	le Each	
4578		10298	9101	16732		1240	982	

17.02	17.01	17.00	5		4		
	_	-	.01	16.00	15.00	14.00	13.00
LED Lamp 12 watt Makes: Havells/Wipro/Philips	LED Lamp 0.5 watt (Red and Green) Makes: Havells/Wipro/Philips	Supplying and fixing LED lamps of following watt with polycarbonate diffuser on the existing light point as required complete in all respect.	16.01 Double door 4 way (Make:- Schneider/ Legrand/L&T)	Supplying and fixing of following way, single pole and neutral sheet steel MCB distribution board, 240 volts, on surface / recess, complete with tinned copper bus- bar, wire-set, neutral link, earth bar, din-bar, detachable gland plate, blanking plate, cable, identification labels interconnections, phosphatized and powder painted, including earthing etc. as required:-	Providing and fixing LED Mirror Light 10 W+/- 1W with Surface Mounted 2 Feet with Polycarbonate diffuser complete with all accessories, including connections, testing and commissioning etc.as required complete in all respects, with 5 year waranty.Makes:- Panasonic/Wipro/Bajaj.	Providing and fixing surface/recess mounting Square/Round LED downlighter suitable for surface application with the use of the latest technology 18/20 watt (1800 Lumen) 6000K and it should be compatible with specification i.e. Power Factor ≥ 0.9, Harmonic Distortion ≤10% and efficacy ≥ 100 Lumens per watt. CRI rating> 80 suitable for input voltage: AC 220-240 V, 50 Hz, complete with all accessories, connections, testing and commissioning etc. as required. with 5 year waranty Makes: Panasonic/ Philips/ Bajaj/Wipro.	Providing and fixing LED tube fixture (including the cost of Batten/channel and LED Lamp) suitable for surface application with the use of the latest technology 18 watt (1800 Lumen) 6000K and it should be compatible with specification i.e. Power Factor ≥ 0.9, Harmonic Distortion ≤10% and efficacy ≥ 100 Lumens per watt, CRI rating> 80 suitable for input voltage: AC 220-240 V. 50 Hz, complete with all accessories, connections, testing and commissioning etc. as required. with 5 year waranty Makes: Havells/ Bajaj/ Philips /Wipro.
20	10				ω	25	ő
203	62		1589		566	1564	949
Rupees Two Hundred Three Only	Rupees Sixty Two Only		Rupees One Thousand Five Hundred Eighty Nine Only		Rupees Five Hundred Sixty Six Only	Rupees One Thousand Five Hundred Sixty Four Only	Rupees Nine Hundred Forty Nine Only
Each	Each		Each		Each	Each	Each
4060	620		1589		1698	39100	9490

24.00	23.01	23.00	22 00	21.	20.02	20.01	20	19	19	70	<u></u>	16	#
			8 0 E	00 8			20.00	19.02	19.01	19.00	.02	18.01	18.00
Providing and Fixing of Following material for repair of Water Heater of Different Capacity as required complete in all respects	Heat Pillar Rod 750 watt	Providing and Fixing of Following type Rods for Heat Pillar and Room Heater as required complete in all respects.	Providing skilled Electrician-II and unskilled Team-mate for electrical maintenance during H.P. Vidhan Sabha session during January 2023.	and fixing wireless door bell	16 amps 3 Pin Plug Top	6 amps 3 Pin Plug Top	Supplying and fixing following type Plug Top on the existing Light Point, Heat Pillar, Room Heater including connections etc. as required complete in all respects.	Two core 1.0 sqmm	Three core 1.5 sqmm	Supplying and drawing copper conductor, multicore cable in the existing surface/ recessed steel/ PVC conduit as required complete in all respects.	18.02 Lead Acid Battery 12 Volt 26 Ah Makes: Exide/Quanta/Microtek	Tubular Battery 12 Volt 160 Ah Makes: Exide/Quanta/Microtek	capacity for UPS System etc. as required complete in all respects and to the best satisfaction of Engineer-in-Charge.
	10		4	ω	10	10		50	50		16	r.	_ ñ ŭ
	440		20052	1166	99	76		66	104		4349	17000	
	Rupees Four Hundred Forty Only		Rupees Twenty Thousand Fifty Two Only	Rupees One Thousand One Hundred Sixty Six Only	Rupees Ninety Nine Only	Rupees Seventy Six Only		Rupees Sixty Six Only	Rupees One Hundred Four Only		Rupees Four Thousand Three Hundred Forty Nine Only	Rupees Seventeen Thousand Only	
	Each		Per Job	Each	Each	Each		Each	Each		Each	Each	
	4400		20052	3498	990	760		3300	5200		69584	85000	

	27.01	27.00	26.01	26.00	25.00	24.01
Total	27,01 50 mm. dia	Supplying and fixing of following sizes of PVC conduit of medium class with 1.4 mm thickness along with the accessories in surface / recess including cutting the wall and making good the same in case of recessed conduit as required:-(Make: BEC Plast/Anchor/PolyFit)	26.01 Armoured cable 10 sq. mm (twin core) Makes: KEI/Havells/Plaza	Providing and laying of one No. aluminium conductor, PVC insulated and PVC sheathed, armoured/XLPE power cable, working voltage 1100 volts grade direct in ground; to be laid 1 meter below the ground level including excavation and refilling the trench etc.as required, but excluding sand cushioning and protective covering:- (Make:- KEII Plaza/Havells)	it should be compatible with specification i.e. Power Factor > 0.9, Harmonic Distortion <10% and efficacy > 100 Lumens per watt, CRI rating> 80 suitable for input voltage: AC 220-240 V, 50 Hz, complete with all accessories, connections, testing and commissioning etc. as required, with 5 year waranty Makes: Panasonic/Philips/ Bajaj/Wipro.	Providing and arration Watt Triangular Type
	180		200		ω	co
1 7 1	265		361		10443	880
	Rupees Two Hundred Sixty Five Only		Rupees Three Hundred Sixty One Only		Rupees Ten Thousand Four Hundred Forty Three Only	Rupees Eight Hundred Eighty Only
	Per Metre		Per Metre		Each	Each
498129	47700		72200		31329	5280

cyproxed +-11 47 81 29 2.

Executive Engineer Electrical Division HPPWD Palampur

2.01	2.00	1.01	1.00	NO.	SR.	Dharm	
Group C.	Wiring for light point/ fan point/ exhaust fan point/ call bell point with 1.5 sq.mm FRLS PVC insulated copper conductor single core cable in surface / recessed steel conduit, with modular switch, modular plate, suitable GI box and earthing the point with 1.5 sq.mm FRLS PVC insulated copper conductor single core cable etc. as required. Make for wires: KEI/Plaza/Anchor Make for Switches: Schneider (Livia)/Legrand (Myrius) /L&T(Entice).	Group C.	Re-wiring for light point / fan point / exhaust fan / call bell point with 1.5 Sq. mm. FRLS PVC insulated copper conductor cable single core cable and 1.5 square mm FRLS PVC insulated copper conductor single core cable as earth wire wire in existing surface/recessed Steel / PVC conduit including dismantling of the existing wiring as required. (including Modular switch, modular plate, suitable GI box etc.)		DESCRIPTION	NAME OF WORK :- C/O Type-V residence of SE (Mechanical) 2nd Circle Dharmshala(Sh:- Providing wiring Switches,Fan,LED's, therein)	SCHEDULE OF QUANTITY
4		46			QTY.	Jo	QUAN
1333		558		FIGURES		Job No 15	YTIT
Rupees One Thousand Three Hundred Thirty Three Only		Rupees Five Hundred Fifty Eight Only		WORDS	RATES	ESTIMATED COST: Rs 4,59,054/-only. EARNEST MONEY: Rs.9200/-only TIME ALLOWED: Six Months	
Per Point		Per Point			TINU	4,59,054/2only .9200/2only	
14663		25668			AMOUNT	y.	

5,03	5.02	5.01	5,00	4.04	4.03	4.02	4.01	4 00	3.00
4 x 6.0 sq. mm	3 x 4.0 sq. mm	3 x 1.5 sq. mm	Supplying and drawing following sizes of FRLS PVC insulated copper conductor, single core cable in the existing surface/ recessed steel/ PVC conduit as required. Make: KEI/Plaza/Anchor.	4 X 4 sq. mm + 2 X 4 sq. mm earth wire	2 X 6 sq. mm + 1 X 6 sq. mm earth wire	2 X 4 sq. mm + 1 X 4 sq. mm earth wire	2 X 2.5 sq. mm + 1 X 2.5 sq. mm earth wire	Wiring for circuit/ submain wiring alongwith earth wire with the following sizes of FRLS: PVC insulated copper conductor, single core cable in surface/ recessed steel conduit as required. Make: KEI/SSK/Anchor./SCI	Witing for two way light point/ fan point/ exhaust fan point/ call bell point/ with 1,5 sq.mm FRLS PVC insulated copper conductor single core cable in surface / recessed steel conduit, with modular switch, modular plate, suitable GI box and earthing the point with 1.5 sq.mm FRLS PVC insulated copper conductor single core cable etc. as required. Make for wires: KEI/Plaza/Anchor Make for Switches: Schneider (Livia)/Legrand (Myrius) /L&T(Entice).
24	244	322		66	100	81	90		th .
340	220	100		293	564	395	332	-1	766
Rupees Three Hundred Forty Only	Rupees Two Hundred Twenty Only	Rupees One Hundred Only		Rupees Two Hundred Ninety Three Only	Rupees Five Hundred Sixty Four Only	Rupees Three Hundred Ninety Five Only	Rupees Three Hundred Thirty Two Only		Rupees Seven Hundred Sixty Six Only
Per Metre	Per Metre	Per Metre		Per Metre	Per Metre	Per Metre	Per Metre		Per Point
8160	53580	32200		19338	56400	31995	29880		3830

10.01	10.00	9.00	8.00	7.00	6.05	6.04	6.03	6,02	6.01	6.00
100 Amp 18KA	Providing and fixing following rating and breaking capacity MCCB with thermomagnetic release and terminal spreaders in existing cubicle panel board including drilling holes in cubicle panel, making connections, etc. as required. Make: Schneider/ Legrand/L&T.	Supplying and fixing Ding-Dong / Electronic musical bell, suitable for D.C./A.C. single phase, 230 volts complete as required: Make: Anchor/Goldmedal /Cona	Supplying and fixing suitable size GI box with modular plate and cover in FRLSont on surface or in recess, including providing and fixing 6 pin 5/6 & 15/16 amps modular socket outlet and 15/16 amps modular switch, connection etc. as required. Make: Schneider (Livia)/ Legrand (Myrius) /L&T(Entice).	Supplying and fixing suitable size GI box with modular plate and cover in front on surface or in recess, including providing and fixing 3 nos. 3 pin 5/6 amps modular socket outlets and 3 nos 5/6 amps modular switches, connection etc. as required. (For light plugs to be used in non residential buildings).	S.P.Tv socket	S.P. 15/1 6 Amps Modular socket.	S.P. 15/16 Amps one way Modular switch.	S.P. 5/ 6 Amps Modular socket.	S.P. 5/6 Amps one way Modular switch.	Supplying and fixing following rating Modular switch /socket in the existing switch box excluding cover plate connections etc. as required.
4		4	ED.	13	4	15	d	24	24	
6868		206	621	469	203	306	214	155	115	
Rupees Six Thousand Eight Hundred Sixty		Rupees Two Hundred Six Only	Rupees Six Hundred Twenty One Only	Rupees Four Hundred Sixty Nine Only	Rupees Two Hundred Three Only	Rupees Three Hundred Six Only	Rupees Two Hundred Fourteen Only	Rupees One Hundred Fifty Five Only	Rupees One Hundred Fifteen Only	
Each		Each	Each	Each	Each	Each	Each	Each	Each	
6868		206	5589	6097	812	4590	3210	3720	2760	

15.01	15.00	14.01	14.00	13.01	13.00	12.01	12.00	11.00
Double door-4 way (Make:- Schneider/ Legrand/L&T)	MCB distribution board, 240 V, on surface/ recess, complete with tinned copper bus bar, neutral bus bar, earth bar, din bar, interconnections, powder painted including earthing etc. as required. (But without MCB/RCCB/Isolator).	63 Amps. (Make:- Schneider/ Legrand/L&T)	neutral), 240 V, residual current circuit breaker (RCCB), having a sensitivity current 30 mA in the existing MCB DB complete with connections, testing and commissioning etc. as required.	63 Amps. (Make:- Schneider/ Legrand/L&T)	existing MCB DB complete with connections, testing and commissioning etc. as required.		1	
4		4		(J)		36		7
1425		3104		530		239	111	729
Rupees One Thousand Four Hundred Twenty Five Only		Rupees Three Thousand One Hundred Four Only		Rupees Five Hundred Thirty Only		Rupees Two Hundred Thirty Nine Only		Rupses Seven Hundred Twenty Nine Only
Each		Each		Each		Each		Each
1425		12416		2650		8604		5103

20.01	20.00	19.01	19.00	18.01	18.00	17.01	16.00
LED Mirror Light 10 watt Makes:- Philips /Wipro/ Panasonic/ Crompton.	Providing and fixing LED Mirror Light of 10 W+/- 1W with Polycarbonate diffuser having P.F.>0.95 with THD<20%, CRI 80. The LED with Useful life of 50000 Hrs with five years warranty. The LEDs used in the luminaire shall have CRI of minimum 80. The Input voltage range shall be 150V to 270V, 50/60 HZ complete with all accessories, including connections, testing and commissioning etc.as required complete in all respects.		Providing, Installation, testing and commissioning of wall fan of following size by means of suitable rag-boll/ nuts, connections, testing and commissioning etc. as required complete in all respects to the best satisfaction of Engineer-in-charge.		opening, including making the hole to suit the size of the above fan, making good the damages, connections, testing and commissioning etc. as required:		with step type two module electronic fan regulator, including wiring the down rods of standard length (up to 30 cm) with 16/0.20 mm twin twisted flexible, cotton braided, copper cable, including providing and fixing phenolic laminated sheet cover on the fan box and earthing etc. as required.
4		4		Ċn		8	
679		3041		2567		2513	
Rupees Six Hundred Seventy Nine Only		Rupees Three Thousand Forty One Only		Rupees Two Thousand Five Hundred Sixty Seven Only		Rupees Two Thousand Five Hundred Thirteen Only	
Each		Each		Each		Each	
2716		3041		12835		20104	

_	22.01	22.00	21.01	21.00
Total	LED Surface mounting round downlighter 18 watt Makes:- Philips //Wipro/ Panasonic/ Crompton.	Surface Mounted Downlighter of following watt +/- 1 W LED Surface Mounted Downlighter Round Shape with minimum system lumen efficacy of 100 Im/W with Polycarbonate housing.pressure die cast heat sink and P.F.>0.95 with THD<10% ,CRI 80.The LED shall be tested with LM80-08 standard with Useful life of 50000 Hrs at L70 with five years warranty. The LEDs used in the luminaire shall have CCT of ANSI Bin 5700 K with CRI of minimum 80.The Input voltage range shall be 150V to 270V, 50/60 HZ complete with all accessories, including connections, testing and commissioning etc.as required complete in all respects:	LED Surface mounting round downlighter 12 watt Makes:- Philips Wipro/ Panasonic/ Crompton.	Providing and Fixing LED Downlighter of following watt +/- 1 W LED Surface Mounted Downlighter Round Shape with minimum system cast heat sink and P.F.>0.95 with Polycarbonate housing, pressure die tested with LM80-08 standard with Useful life of 50000 Hrs at L70 with five years warranty. The LEDs used in the luminaire shall have CCT of ANSI Bin 5700 K with CRI of minimum 80. The Input voltage range shall be 150V to 270V, 50/60 HZ complete with all accessories, including connections, testing and commissioning etc.as required complete in all respects.
	38		00	
	1821		1412	
	Rupees One Thousand Eight Hundred Twenty One Only		Rupees One Thousand Four Hundred Twelve Only	
	Each		Each	
459054	69198		11296	

Be Schoolabe of guentily cheesed and opposed for 3450 05 Your

Executive Engineer
Electrical Division
HPPWD Palampur

											-		179
	2.8	2.5	23	2.1	2		4			7	(0)	Vi Ta	Z
(Make:-KEI / Anchor / Plaza)	4x4 Sq. mm.	2x10 Sq. mm.	2x4 Sq. mm.	2x1.5 Sq. mm.	Wiring for circuit/ submain wiring alongwith earth wire with the following sizes of FRLS PVC insulated copper conductor, single core cable in surface/ recessed medium class PVC conduit as required.	Schneider(Livia) Schneider(Livia)		sq.mm FRLS PVC insulated copper conductor single core cable in surface frecessed medium class PVC conduit and earthing the point with 1.5 sq.mm. FRLS PVC insulated copper conductor single core cable etc as required.	1 Wiring for light point fan point exhaust fan point call bell soint with 1 s	NO.	SR. DESCRIPTION	Intervention center) OPD 11 at 500 bedded hospital at Dr. RPGMC Tanda at Kangra .(SH:- Providing light points, LED fixture, Power wiring and AC points therein).	Name of Work :- Additional Alteration in DEIC (District Ed.)
1	28	26	40	36			16			ary.			
	612.00	678.00	353.00	217.00			1345.00		FIGURES	Т		9 on do	QUANTITY
	Rupees Six Hundred Twelve Only	Rupees Six Hundred Seventy Eight Only	Rupees Three Hundred Fifty Three Only	Rupees Two Hundred Seventeen Only			Rupees One Thousand Three Hundred Forty Five Only		WORDS	RATES		ESTIMATED COST: Rs. 1,80,175/-only. EARNEST MONEY: Rs.3700/-only TIME ALLOWED: Two Months	
	P/Mtr	P/Mtr	P/Mtr	PMtr			P/Pt		200000	UNIT	\	s. 1,80,175/4 s.3700/-only Months	
	17136	17628	14120	7812			21520			AMOUNT		only.	

South a party of the

											4/1957
6.1	. 6		5.4	5.3	52	5.1	Ch	4.1	4	3.1	ω
Single pole. Cat-A.	Supplying and erection of 6 amps. to 32 amps. rating, 10 KA breaking capacity, 240 volts, 'C' curves, miniature circuit breaker of following poles in the existing MCB DB complete with connections etc. as required:	Makes:- L&T/Legrand/Schneider.	Socket shuttered 6 / 16 Amp 3 Pin	Switch - 20 Amp 1 way 2 Module	Socket shuttered 6 Amp 2/3 Pin	Switch - 6A SP (1 Way) - 1 module	Makes:- L&T/Legrand (cat. No. 5734 01) / Schneider. Supplying and fixing following rating Modular switch /socket in the existing switch box / cover plate including connections etc. as required.	6 Modules	(Make:-KEI / Anchor / Plaza) Supplying & fixing of G.I. modular boxes of following sizes along with modular base and cover plate for modular switches in recess as required:-	3x1.5 Sq. mm.	Supplying and drawing following size of PVC insulated, heat resistant, flame retardant (HRFR) and low smoke single core (flexible) copper conductor cable in existing surface / recessed, Steel/PVC conduit as required.
16			15	36	5 \	55		. 8		10	
268.00			343.00	228.00	189.00	133.00		545.00		112.00	
Rupees Two Hundred Sixty Eight Only			Rupees Three Hundred Forty Three Only	Rupees Two Hundred Twenty Eight Only	Rupees One Hundred Eighty Nine Only	Rupees One Hundred Thirty Three Only		Rupees Five Hundred Forty Five Only		Rupees One Hundred Twelve Only	
Each			Each	Each	Each	Each		Each		P/Mtr	
4288			5145	3420	2835	1995		4360	,	1120	

4.0

	7	7.1		œ	8.2		6	9.1		10
Makes:- Legrand/L&T/Schneider.	Supplying and fixing following rating, following pole, 240/415 volts, isolator in the existing MCB DB complete with connections, testing and commissioning etc. as required.	63 Amps. Double Pole	Makes:-Legrand/L&T/Schneider.	Supplying and fixing following rating, double pole (single phase & neutral) 240 volts, residual current circuit breaker (RCCB), having a sensitivity current up to 300 miliampers in the existing MCB DB complete with connections, testing and commissioning etc. as required.	63 Amps. Cat-A.	Makes:-L/&T / Legrand/Schneider.	Providing, Installation, testing and commissioning of ceiling fan BLDC with two module modular step type electronic fan regulator, including wiring the down rods of standard length (up to 30 cm) with 16/0.20 mm twint twisted flexible, cotton braided, copper cable, including providing and fixing phenolic laminated sheet cover on the fan box and earthing etc. as required.	Ceiling Fan 1200 mm sweep, Category-A	Makes:- Usha / Bajaj/ Crompton.	Supplying and fixing of following way, single pole and neutral sheet steel MCB distribution board, 240 volts, on surface / recess, complete with tinned copper bus- bar, wire-set, neutral link, earth bar, din-bar, detachable gland plate, blanking plate, cable, identification labels interconnections, phosphatized and powder painted, including earthing etc. as required:-
		N			~ 2			4		ω w . τ ω
		531.00			2981.00			4386.00		
		Rupees Five Hundred Thirty One Only			Rupees Two Thousand Nine Hundred Eighty One Only			Rupees Four Thousand Three Hundred Eighty Six Only		
		Each			Each			Each		,
		1062	1		5962			17544		

		121	12		11.1	3		100
Total	Makes: Wiprol Havells/ Panasonic	1 36 Watt LED 2'x2' Recess panel	Providing and fixing of LED fixture 600mm x 600mm 36Watt +/- 1W recess mounted having minimum system lumen efficacy of 100lm/W with with CRCA housing and PMMA diffuser with P.F. >0.95, THD<10%, CCT 5700K, CRI 80. The LED shall be tested with LM80-08 standard with useful life of 50000 hrs. at L70. The input voltage range shall be 150V as required complete with connections, testing etc.with 5 year waranty.	Make; Wipro / Havells/ Bajaj	18 Watt LED, fixture round / square	Providing and istallation of LED fixtures 18 W+/- 1 W LED round/Square surface mounted downlighter with minimum system lumenefficacy of 85 lm/W with and PF >095 with THD <20%, CCT 6000K, CRI 80 the LED with useful life of 500000Hrs. At L70. The input voltage range shall be 150 V as required complete with connections testing elc.with 5 year waranty.	Makes:- L&T/Legrand/Schneider.	Double door-12 way
		8	U Z		4			N
		5415.00			1,564.00			2326.00
		Rupees Five Thousand Four Hundred Fifteen Only			Rupees One Thousand Five Hundred Sixty Four Only			Rupees Two Thousand Three Hundred Twenty Six Only
		Each			Each			Each
180175		43320			6256			4652

Executive Engineer Electrical Division HPPWD Palampur

	SCHEDULE OF QUANTITY	QUAN			
AME OF WOR	NAME OF WORK :- C/o School of Nursing at Dr. RPGMC Kangra at Tanda in Distt. Kangra (H.P.) (SH: Providing Air-conditioning units to Conference			ESTIMATED COST: Rs 4,96,3071-only EARNEST MONEY: Rs.10,0001-only	1,96,307/-only
ewborn PICU	Room, Faculty Room, Director Room, Emergency Room, Store, Maternal & Newborn PICU of Critical Care Skill Lab/Simulation Lab therein)	Jo	t on d	Job No. TIME ALLOWED: Three Months	Months
C	DESCRIPTION	QTY.		RATES	UNIT
2 2			FIGURES	WORDS	
Supplyi (Hot & make o (expect compre	Supplying, installation, testing and commissioning of following capacity (Hot & Cold) 3 star Inverter Split type Air-Conditioning unit of following make confirming to I.S.I1391 PART-1992 with ammendment No. 1 (expect power consumption norms) fitted with hermatically shielded air-compressor having one year standard warranty on machine, five years				
comple	complete in all respects.				
A.C. Un	A.C. Unit 2 Ton capacity (Split Inverter)	\sim $^{\circ}$	71432.00	Thousand Four Hundred Thirty Two Only	Each
Makes:-	LG (Model No. : RS-H24VNXE.ANLG (R-				
32)/Vol	32)/Voltas/Bluestar/O-General				
Supplyii with out volt and 2 surges	Supplying and fixing wall mounting voltage stabilizer of country of Supplying and fixing wall mounting voltage regulation range from 130 volt to 270 with output 240 volts with voltage regulation range from 130 volt to 270 with output 240 volts with voltage regulation range and time delay operation for the volt and auto cut off beyond this range and time delay operation for 1.5 TR capacity split type Airsurges and fluctuations suitable for 1.5 TR capacity split type Airsurges and fluctuations suitable for 1.5 TR capacity split type Airsurges and fluctuations suitable for 1.5 TR capacity split type Airsurges and fluctuations suitable for 1.5 TR capacity split type Airsurges and fluctuations suitable for 1.5 TR capacity split type Airsurges and fluctuations suitable for 1.5 TR capacity split type Airsurges and fluctuations suitable for 1.5 TR capacity split type Airsurges and fluctuations suitable for 1.5 TR capacity split type Airsurges and fluctuations suitable for 1.5 TR capacity split type Airsurges and fluctuations suitable for 1.5 TR capacity split type Airsurges and fluctuations suitable for 1.5 TR capacity split type Airsurges and fluctuations suitable for 1.5 TR capacity split type Airsurges and fluctuations suitable for 1.5 TR capacity split type Airsurges and fluctuations suitable for 1.5 TR capacity split type Airsurges and fluctuations suitable for 1.5 TR capacity split type Airsurges and fluctuations suitable for 1.5 TR capacity split type Airsurges and fluctuations suitable for 1.5 TR capacity split type Airsurges and fluctuations suitable fluctuations suitable fluctuations suitable fluctuations suitable fluctuations suitable fluctuations are suitable fluctuations.				
all respects	icts.			Rupees Five	n h
Automa	Automatic Voltage Stabilizer 5 kVA	0	5200.00	Thousand Iwo Hundred Only	T ac
	C. and/Godrei/Whirlphool				

	Ch		4	ယ
Total	Supplying and fixing of 25mm dia of PVC drain pipe along with the accessories in surface/recess including cutting the wall and making good the same in case of recessed conduit as required.	1/4" x 5/8" for 2 TR capacity AC Unit	Providing & fixing of extra copper tubes for refrigerant and condensate of following sizes different capacity split type A.C. units and wiring with suitable size of HRFRLS copper conductor single core cables, including the cost of insulation etc. as required complete in all respects.	Providing & fixing of M.S. Outdoor heavy duty stand powder coated suitable suitable to hang 1.5/2.0 TR Split type AC with six nos. anchor bolts as required complete in all respects and as per direction of Engineer in charge.
	177	22		7 00
	195.00	1250.00		950.00
	Rupees One Hundred Ninety Five Only	Rupees One Thousand Two Hundred Fifty Only		Rupees Nine Hundred Fifty Only
	Per Meter	Per Meter		Each
496307	3315	27500		5700

Sohehul of quentity chakes and yound for 2 49631700 los

	SCHEDULE OF QUANTITY	QUAN	YTIT		
NAME OF WOR Distt. Kangra (H Ward, Skill Roon therein)	NAME OF WORK :- C/o School of Nursing at Dr. RPGMC Kangra at Tanda in Distt. Kangra (H.P.) (SH: Providing Air-conditioning units to ICU, In-Patient Ward, Skill Room and Pantry of Critical Care Skill Lab/Simulation Lab therein)	٦	Job No 🔧	ESTIMATED COST: Rs 4,95,952/-oply EARNEST MONEY: Rs.10,000/-only TIME ALLOWED: Three Months	10,00 Mont
SR.	DESCRIPTION	QTY.		RATES	TINU
NO.			FIGURES	WORDS	
	Supplying, installation, testing and commissioning of following capacity (Hot & Cold) 3 star Inverter Split type Air-Conditioning unit of following make confirming to I.S.I1391 PART-1992 with ammendment No. 1 (expect power consumption norms) fitted with hermatically shielded air-compressor having one year standard warranty on machine, five years warranty on PCB and 10 years warranty on compressor as required complete in all respects.			1	
A.C. Un	A.C. Unit 2 Ton capacity (Split Inverter)	\	71432.00	Rupees Seventy One Thousand Four Hundred Thirty Two Only	Each
Makes:- 32)/Volta	Makes:- LG (Model No. : RS-H24VNXE.ANLG (R-32)/Voltas/Bluestar/O-General				
Supplying a with output with output volt and au surges and Conditioner all respects	Supplying and fixing wall mounting voltage stabilizer of following rating with output 240 volts with voltage regulation range from 130 volt to 270 volt and auto cut off beyond this range and time delay operation for the surges and fluctuations suitable for 1.5 TR capacity split type Air-Conditioner including making connections etc. as required complete in all respects.				Ξ
Automat	Automatic Voltage Stabilizer 5 kVA	\ °	5200.00	Rupees Five Thousand Two Hundred Only	Each
Makes:-	Makes:- V-Guard/Godrej/Whirlphool				1

	cn .		4	w
Total	Supplying and fixing of 25mm dia of PVC drain pipe along with the accessones in surface/recess including cutting the wall and making good the same in case of recessed conduit as required.	1/4" x 5/8" for 2 TR capacity AC Unit	Providing & fixing of extra copper tubes for refrigerant and condensate of following sizes different capacity split type A.C. units and wiring with suitable size of HRFRLS copper conductor single core cables, including the cost of insulation etc. as required complete in all respects.	Providing & fixing of M.S. Outdoor heavy duty stand powder coated suitable suitable to hang 1.5/2.0 TR Split type AC with six nos anchor bolts as required complete in all respects and as per direction of Engineer in charge.
	28	JA.		700
	06'561	1250.00		950,00
	Rupees One Hundred Ninety Five Only	Rupees One Thousand Two Hundred Fifty Only		Rupees Nine Hundred Fifty Only
	Per Meter	Per Meter		Each
495952	5460	25000		5700

Schedule of grandiffichertail and appropriate for 74958555018

ectrical Division

	SCHEDULE OF QUANTITY	NAUG	ΥTI			
NAMI Hosp repla rods area t	NAME OF WORK:- Repair and Maintenance of E.I. to 500 Bedded Hospital Dr. RPGMC Kangra at Tanda. (SH: Rewinding of celling fans, replacement of fan condensers, fan regulators and extra down fan rods etc. in various Wards of ground floor to fourth floor and OPD area therein)	Job	Job No) 9	ESTIMATED COST: Rs. 2,36,185/-only. EARNEST MONEY: Rs. 4800/-only TIME ALLOWED: Six Months	2,36,185/-oi 4800/-only inths	nly.
	DESCRIPTION	QTY.		RATES	TINU	AMOUNT
			FIGURES	WORDS		
	Rewinding of ceiling fan 1200/1400 mm sweep new model with copper insulated wire HTP-34 number including varnishing, capacitor, ball bearing etc. as required complete in all respects and to the best satisfaction of Engineer-in-charge.	272	670.00	Rupees Six Hundred Seventy Only	Each	182240
22	Providing and fixing extra conduit down rod of 20mm dia. x 60 cm with 16/0.20 mm twin twisted flexible, cotton braided, copper cable including painting, connections etc. as required:-	49	155.00	Rupees One Hundred Fifty Five Only	Each	7595
ω	Replacement of fan condenser 2.5 MFD suitable for 1200/1400 ceiling fans as required complete in all respects and to the best satisfaction of Engineer-in-charge.	248	75.00	Rupees Seventy Five Only	Each	18600
4	Supplying and fixing stepped type fan regulator on the existing modular box including making connections etc. as required.	75	370.00	Rupees Three Hundred Seventy Only	Each	27750
						28185

236/85 5 Execute of allowhity checked and opposered to

	SCHEDULE OF QUANTITY	LNAU	Ŧ			
lame o	Name of Work :- Replacement of old and damaged ceiling fans of various wards at 3rd floor (Male and Female) surgical wards. Children		Š.	ESTIMATED COST: Rs.2,93,156/-only. EARNEST MONEY: Rs.5900/-only	2,93,156/-on 5900/-only	ly.
CU, A	ICU, Anesthesia ICU of 500 Bedded Hospital Dr. RPGMC Tanda.	job 1	, No	TIME ALLOWED: Three Months	Months	
SR.	DESCRIPTION	QTY.		RATES	TINU	AMOUNT
NO.			FIGURES	WORDS		
_	Providing installation testing and commissioning of BLDC ceiling fan with socket type regulator, including wiring the down rods of standard length (yp to 30 cm) with 16/0.20 mm twin twisted flexible cotton braided copper cable including providing and fixing phenolic laminated sheet cover on the fan box and earthing etc. as required with five year warranty.	23	4386.00	Rupees Four Thousand Three Hundred Eighty Six Only	Each	271932
N	Providing installation testing and commissioning of wal fan of following size by means of Suiltable rag-boll/ nuts, connections, testing and commissioning etc. as required complete in all respects to the best cattlefaction of Engineer in Champ	7	3032.00	Rupees Three Thousand Thirty Two Only	Each	21224
	Total					293156
	The Dismental metrial deducted from the contractor that is Rs. 2932/- in the Final will					

Dealt Scholie Quantity checied and Approduct for Ps 293166 forty

		u			2			4		NO.	burnt overha	bedda
Makes:- L&T/Legrand/Schneider.	MCB 32 Amp., 4 pole "D" Curve	Supplying and fixing 5 amps to 32 amps rating, 240/415 volts, 10 kA, "D" curve, miniature circuit breaker suitable for inductive load of following poles in the existing MCB DB complete with connections, testing and commissioning etc. as required.	Make:- KEl/Finolex/Havells/Grandlay	Armoured copper cable 6 sq. mm (3 Core)	Providing & laying of one number copper conductor, PVC insulated and PVC sheathed un-armoured power cable, 1.1 KV grade of following sizes on wall surface as required.	Make:- KEl/Finolex/Havells/Grandlay	Armoured cable 10 sq. mm (3 Core)	and PVC sheat following sizes		DESCRIPTION	burnt out/damaged chiller pump cable, 5 H.P. motor etc. and overhauling of AHU for CSSD area thereof)	bedded board Repair & Maintenance of HVAC Sustan CO GUAN III Y
	1			18			160			OTY.	10	MAN
	1759.00			650,00			298.00		FIGURES		job No 21	YIII
	Rupees One Thousand Seven Hundred Fifty Nine Only			Rupees Six Hundred Fiffy Only			Rupees Two Hundred Ninety Eight Only		WORDS	RATES	EARNEST MONEY: Rs. 2,97,987/6nly EARNEST MONEY: Rs. 5000/-only TIME ALLOWED: Three Months	
	Each			Per Meler			Per Meter			TINU	. 2,97,987161 .50001-only	
	1759			52000		1	47680		Carried A	AMOUNT	nly.	

								_		
		7		on on			Ó			4
Makes:- Kirloskar/Siemens/Crompton	5 H.P. Monobloc Water Pump Motor	Supplying and fixing of 5 H.P. 2900 RPM clear water monobloc pump motor having gland packed arrangement, pump having 65 mm suction, 50 mm delivery, suitable for operation on 415V, 50 hz, 3 phase A.C. supply complete with testing, commissioning & installation as required.	20HP Water Pump condenser/head	Providing and fixing 20 HP condenser water pump head suitable for chiller/cooling tower of HVAC system including testing, commissioning and making connections etc. as required complete in all respects.	Makes:- Siemens/L&T/Schneider.	5 HP DOL Motor Starter	Providing and fixing 5 HP DOL motor starter suitable for AHUs etc. including testing, commissioning and making connections etc. as required complete in all respects.	Makes:- Legrand/L&T/Schneider.	Double door-4 way	Supplying and fixing following way, single pole and neutral, sheet steel, MCB distribution board, 240 volts, on surface/ recess, complete with tinned copper bus bar, neutral bus bar, earth bar, din bar, interconnections, powder painted including earthing etc. as required (But without MCB/RCCB/Isolator)
	-		3			\ ω			\-	
	68823.00		14800.00			13800.00			1425.00	
	Rupees Sixty Eight Thousand Eight Hundred Twenty Three Only		Rupees Fourteen Thousand Eight Hundred Only			Rupees Thirteen Thousand Eight Hundred Only			Rupees One Thousand Four Hundred Twenty Five Only	
	Each		Each			Each			Each	
_	68823		44400			41400			1425	

A CONTRACTOR OF THE PARTY OF TH

10	T					ω			œ
Sobrealist of quantity disabed and goproned for	Check the motor and fan bearing lubricant.	Check the access of AHU's door for easy operation.	Check the filter frame for proper sealing.	Check the operation of dampers.	Servicing consists of the following:-	Providing wet servicing/overhualing of Air Handling Unit (AHU) of Heating, Ventilation and Air Conditioning System (HVAC) as required complete in all respects and to the best satisfaction of Engineer in charge.	Makes:- Siemens/L&T/Schneider.	Rewinding of 5HP 3 Phase Motor	Rewinding of motor having following size/rating with SWG copper wire including warnishing and refitting etc. as required complete in all respects and to the best satisfation of Engineer-in-charge.
cell						-		4	
M				1		32300.00		8200.00	
8 297980w/w						Rupees Thirty Two Thousand Three Hundred Only		Rupees Eight Thousand Two Hundred Only	
Executive						Per Job		Each	
Executive Engineer Electrical Division	297987		-			32300		8200	

NAME	NAME OF WORK :- R/M of HVAC System in Single Schedule OF QUANTITY	QUAN	YTIT		
RPGM butterf tank fo	RPGMC Kangra at Tanda. (SH: Replacement of damaged water storage tank, butterfly valves, iron net etc. for chiller plant and provide new water storage tank for condensor motor and chiller motor therein)	٦	Job No	ESTIMATED COST: Rs 2,49,680/-only. EARNEST MONEY: Rs.5000/-only TIME ALLOWED: Three Months	2,49,6 5000/- Monti
SR.	DESCRIPTION	QTY.		RATES	UNIT
	Providing and installation		FIGURES	WORDS	
_	having and installation of water tank of following capacity and sizes having anti-bacterial layer, UV Sun shield layer and enahanced aesthetic layer protection and robust injection moulded threaded lid for secure sealing and certified by IAPMO under NSF/ANSI/CAN 61 standards complete with all accessories as required in all respect and to the best satisfaction of Engineer-in-Charge.				
1	1000 ltrs. capacity Water tank (1050mm dia. x 1220mm (H)	2	8200	Rupees Eight Thousand Two Hundred Only	Each
12	2000 ltrs. capacity Water tank (1325mm dia. x 1600mm (H)	ъ	16400	Rupees Sixteen Thousand Four Hundred Only	Each
	Make : Vectus/ Diplast/ Supreme				
N	Providing and fixing of iron stands suitable for water tanks and iron net for cooling tower as required complete in all respects and as per direction and satisfaction of Engineer in charge.	640	195	Rupees One Hundred Ninety Five Only	Per Kg.
ω	Providing & fixing brass float valve following size as required complete in all respects and to the best satisfaction of Engineer-in-charge.				
2	25mm dia.	4	1680	Rupees One Thousand Six Hundred Eighty Only	Each

whop/out

740590					Make: JindaVI ata/ACME	
47360	Weter	Rupees One Thousand Four Hundred Eighty Only	1480	ಜ	50 mm dia.	
					Providing & fixing of GT pipe following size as required complete in all respects and to the best satisfaction of Engineer-in-charge.	O
					Makes:-Zoloto/Sant/Audco	
21600	Each	Thousand Four Hundred Only	5400	4	80 mm dia.	
					Providing & fixing of Cast iron /steel Butterfly Valve confirming to type P.N.1.6 of I.S. 13095-1991 complete with flanges bolt nuts, gasket etc. As per table 'E' specification complete in all respect hydraulically test to 20 K./sqcm as required complete in all respects and to the best satisfaction of Engineer-in-charge.	4
					Make: Sant/Zoloto/Audico.	

1/02964 2 Hours

		N			SR	Distt.Ch	Name of Main Co	
Main Incomers -2	The Panel shall include the following Switchgear & accessories; as per the Make of L & T,Schneider,Legrand.	Make:- KEI/Polycab/ L&T Supplying, erection, testing & commissioning of following depth sheet metal cubical main L.T. pannel of suitable dimensions with plus-minus 5 cm variation, made from M.S. CRC 14/16G, Base Frame 75X40X3MM cm variation, made from M.S. CRC 14/16G, Base Frame 75X40X3MM cm variation, made from M.S. CRC 14/16G, Base Frame 75X40X3MM cm variation, made from M.S. CRC 14/16G, Base Frame 75X40X3MM cm variation, made from M.S. CRC 14/16G, Base Frame 75X40X3MM cm variation, made from M.S. CRC 14/16G, Base Frame 75X40X3MM cm variation & Drawings. Approximate Overall size H- 1200 X W-1500 X specification & Drawings. Approximate Overall size H- 1200 X W-1500 X space for fixing DPMCB's and Isolators, SPMCB's including providing space for fixing DPMCB's and Isolators, SPMCB's including providing and fixing pannel indicating lamps with base as per drawing including and fixing pannel indicating lamps with base as per drawing including control Wiring with Copper Flexible Wire (size of control wire shall be 2.5 sq. mm copper flexible for C.T. Circuit & 1.0 sq. mm for Scada Wiring) with thimbles printed sleeves, tie & belt etc. as required complete in all respects. Make:- M.R Power/Power system control/DB Electromatic Pvt. Ltd	Wiring for circuit / sub-main with 4x10 Sq. IIIII. 1997. Presistant flame retardant (HRFR) and low smoke single core (flexible) resistant flame retardant (HRFR) and low smoke single core with 2 copper conductor cable in surface/recessed steel conduit along with 2 No.10 Sq.mm. (4x10+2x10) HRFRLS/PVC insulated single core copper conductor cable for earthing as required.	PVC insulated heat	DESCRIPTION	Distt.Chamba (H.P).	Name of Work :- Providing Installation Testing & Commissioning Main Control Panel in the office of CMO Chamba in Tehsil &	SCHEDULE OF QUANTITY
		-	20			OTY	jo	NAUC
		163699	1300		FIGURES		Job No 23	TIY
		Rupees One Lacs Sixty Three Thousand Six Hundred Ninety Nine Only	Rupees One Thousand Three Hundred Only		WORDS	RATES	TIME ALLOWED: Three Months	ESTIMATED COST: Rs. 2,22,017/-only.
		Per Job	Per metre			TINU	Months	2,22,017/-only
		163699	26000			AMOUNT		nly.

ω									•
Supplying, erection, testing & commissioning of following depth sheet metal cubical main LT, pannel of suitable dimensions with plus-minus 5 cm variation, made from M.S. CRC 14/16G, Channel duly painted with Siemens Grey Powder Coated Paint as per specification & Drawings. Approximate Overall size H- 800 X W-700 X D-250MM. The cubical pedestal shall have cable entry box at one or two sides. The pannel should be complete with following accessories and space for fixing DPMCB's and Isolators, SPMCB's including providing and fixing pannel indicating lamps with base as per drawing including Control Wiring with Copper Flexible Wire (size of control wire shall be 2.5 sq. mm for Scada Wiring) with thimbles printed sleeves, tie & belt etc. as required complete in all respects.	Cubical Panel Powder Coated with CRCA Sheet -1No. 160A RYBN Busbar Aluminium (+/-50 Hz,440 V AC) -1No.Heat Shrinkable sleeves of coloured coded Red, Yellow, Blue & Black, Colour coded - 1No.SMC/DMC Insulator& Supports-1Nos.Power & Control wiring - 1No.Terminal Block Short links & PVC Channels -1Nos.Thimbles ferrules & Din ralls -1No.Rubber Gasket, Bakelites -1No.Engraving Name Plates 1No.Doorlocks & Hinges -1No Lifting hooks, Hardwares -1No.Labour Charges (i.e. Busbar fitting and wiring) -1No	Secondary Material	No.Spreader link - 1 No.Indicator MCCB On LED Type -1 Nos.	Outgoing Feeders -1	Indicator R Y B Led Type (3pcs)	160A On Load Changeover Switch	On Load Changeover Switch	MCCB 160A 4P, 36KA -1 No, Extended Rotary Handle Dsine-1 No, Spreader link-1 No. Digital VAF Meter 96sq.mm-1 No, Indicator RYB LED type (3 pcs)-1 No. Control MCB 6A SP 10KA-4 Nos, Current Transformer coil 200/5A CL-1 10 VA-3 Nos.	
-									
32318		T							
Rupees Thirty Two Thousand Three Hundred Eighteen Only									
Per Job								-1	
32318									

Total	100A MCCB 3P 25KA-1 No Cubical Panel Powder Coated with CRCA Sheet -1No 100A RYBN Busbar Aluminium (+/-50 Hz,440 V AC) -1No Heat Shrinkable sleeves of coloured coded Red, Yellow, Blue & Black. Colour coded -1No SMC/DMC Insulator Supports-1Nos Power & Control wring -1No Terminal Block Short links & PVC Channels -1Nos Thimbles femules & Din rails -1No Rubber Gasket, Bakelites -1No Engraving Name Plates 1No Doorlocks & Hinges, -1No Lifting hooks, Hardwares -1No Labour Charges (i.e. Busbar fitting and wring) -1No	Main Incomers	the Make of L&T,Schneider,Legrand.	The Size (600mm (high) x 700mm (wide) x 250mm (deep)
22201				

Schoole of quantity checked and Approved for 12.1. 2,22,017-1-1

	SCHEDULE OF	QUANTITY	YII			
Name o damag Chamb	Name of Work :- Replacement of Electrical accessories and old damaged fittings into new one in HPPWD lst Class Rest-House at Chamba in Tehsil & Distt. Chamba H.P Ground Floor & First Floor.	<u>_</u> .	job No Zby	ESTIMATED COST: Rs.3,87,234/-only EARNEST MONEY: Rs.7800/-only TIME ALLOWED: Three Months	s.3,87,234/-o s.7800/-only e Months	only.
SR.	DESCRIPTION	QTY.		RATES	UNIT	AMOUNT
NO.			FIGURES	WORDS		
_	Wiring for light point/ fan point/ exhaust fan point/ call bell point with 1.5 sq.mm FRLS PVC insulated copper conductor single core cable in surface /recessed steel conduit, with modular switch, modular plate, suitable GI box and earthing the point with 1.5 sq.mm. FRLS PVC insulated copper conductor single core cable etc as required.					,
5	Group C (Make : KEl/Plaza/Anchor/SCI	10	1823	Rupees One Thousand Eight Hundred Twenty Three Only	P/Point	18230
N	Wiring for circuit/ submain wiring alongwith earth wire with the following sizes of FRLS PVC insulated copper conductor, single core cable in surface/ recessed medium class PVC conduit as required. Make:					
2	KEI/Plaza/Anchor/SCI 2 X 2.5 sq. mm (For circuit wiring).	30	395	Rupees Three Hundred Ninety Five Only	P/Mtr	11850
2	2x4.0 Sq. mm.	60	471	Rupees Four Hundred Seventy One Only	P/Mtr	28260
ω	Supplying and drawing following sizes of FRLS PVC insulated copper conductor, single core cable in the existing surface/ recessed steel/ PVC conduit as required.Make: KEI/Plaza/Anchor/SCI					
2	Sold mm.	40	171	Rupees One Hundred Seventy One Only	P/Mtr	6840

							1	T	_	T
7.1	7		6.1	O	2	S)	4.3	4.2	4	4
Co-axial Tv cable	Supplying and drawing co-axial TV cable RG-6 grade, 0.7 mm solid copper conductor PE insulated, shielded with fine tinned copper braid and protected with PVC sheath in the existing surfacel recessed steell PVC conduit as required. Make:-Anchor/L&T/Schenider	Make :- Anchor/L&T/Schenider	TV antenna socket outlet	Supplying and fixing following modular switch/ socket on the existing modular plate & switch box including connections but excluding modular plate etc. as required.	Modular G.I box for 12 mudule	front on surface or in recess, including providing and fixing 3 Nos, 3 pin 5/6 Amps modular Socket outlet and 3 Nos, 5/6 Amps modular switches, connection etc. as required. For light plugs to be used in non residential building). Make:- Anchor/L&T/Schenider	6 module - Modular GI box with Modular base & cover plate	3 module - Modular GI box with Modular base & cover plate	2 module - Modular GI box with Modular base & cover plate	base & cover plate for modular switches in recess etc as required.Make: Anchor/L&T/Schenider
50			on .		2		17	62	13	
36			157		1366		750	582	276	
Rupees Thirty Six Only			Rupees One Hundred Fifty Seven Only		Rupees One Thousand Three Hundred Sixty Six Only		Rupees Seven Hundred Fifty Only	Rupees Five Hundred Eighty Two Only	Rupees Two Hundred Seventy Six Only	
x Each			Each		Each		Each	Each	Each	
h 1800			785		2732		12750	36084	3588	

₫.	3	10	9.1	9		8.1	œ
Exhaust Fan, Light duty, (Domestic) 300 mm sweep	Providing and installation exhaust fan of following sizes in the existing opening, including making the hole to suit the size of the above fan, making good the damages, connections testing and commissioning elc. as required: of Approved Make Usha/Bajaj/Crompton	nsurface or in recessile providing and fixing 25 amp modular socket oullet and 25 Amps modular SP MCB, 'C" curve including connection, painting etc. as required. Modular GI box for 3 module Make:- Anchor/Schenider/L&T	Steel conduit 25mm. Makes:- BEC Plast/Anchor/Diplast/Sidharth	Supplying and Fixing of following size of medium class Steel conduit along with accessories in surface/recess including cutting the wall and making good the same in case of recessed conduit as required.	Makes:- BEC Plast/Anchor/PolyFit	PVC conduit 25mm.	along with accessories in surface/recess including cutting the wall and making good the same in case of recessed conduit as required.
10		10	40			50	
2269		775	265			113	
Rupees Two Thousand Two Hundred Sixty Nine Only		Rupees Seven Hundred Seventy Five Only	Rupees Two Hundred Sixty Five Only		Only	Rupees One Hundred Thirteen	
Each		Each	P/Mtr			P/Mtr	
22690		7750	10600			5650	

4.	4	13.1	ಪ	12.1	zi.
Fancy wall bracket.	Wall light fixture, brushed nicke lifinish body, opal Glass diffuser, suitable for 7 Watt retrofit LED lamp E27 base. Make:- Philips/Decon/Bajaj	LED Mirror Light 10W Wipro/Bajaj	Providing and fixing LED Mirror Light of IP20 Feet Led fixture 10 W+/- 1W with Surface Mounted 2 with Polycarbonate diffuser with Extruded aluminium housing having minimum system lumen output 1000 lumens and system lumen efficacy of 100 lm/W with P.F.>0.95 with THD 20% CRI 80. The LED with Useful life of 50000 Hrs at L70 with five years warranty. The LEDs used in the luminaire shall have CCT of ANSI Bin 6500 K with CRI of minimum 80. The Input voltage range shall be 150V to 270V, 50/60 HZ complete with all accessories, including connections, testing and commissioning etc.as required complete in all respects.		Providing and fixing decorative extruded tube fixture having high quality design suitable for LED tube up to 20Watt (2000 lumen) 6500K and it should be compatible with specifications i.e. power factor ≥ 0.9, harmonic distortion ≤ 10% and efficacy ≥ 100 lumens per watt, CRI > 80, suitable for input voltage AC 220-240V, 50/60 Hz, including one no: tube rod 20 Watt complete with all accessories, connections, testing and commissioning etc. as required, with 5 year waranty. (Make Bajaj/wipro/Philips
50		20		10	
1645		665		975	
Rupees One Thousand Six Hundred Forty Five Only		Rupees Six Hundred Sixty Five Only		Rupees Nine Hundred Seventy Five Only	
Each		Each		Each	
82250		13300		9750	

						200
	17	16.1		6	15.1	5
PDLM11206BS)/Philips/ Bajaj/wipro.	Proviing and fixing surface/recess mounting Square/Round Leb downlighter suitaoe or srtace application with the use of the latest technology 18/20 watt (1800 Lumen) 6000K aESnould be compatible with specification i.e. Power Factor> 0.9, Harmonic Distortionaeficacy with specificacy and specification i.e. Power Factor> 0.9, Harmonic Distortionaeficacy with specificacy with specification i.e. Power Factor> 0.9, H	square LED panel Light 1x1 24Watt Surface.	NWH/Wipro/Bajaj. with 5 year waranty.	Providing and fixing recess mounting LED luminaire of following rating with powder coated CRCA housing with high power LEDs diffuser to avoid glaire, it should be compatible with specification i.e power Factor>0.9. Harmonic Distortion < 10% and eficacy> 100 Lumens per watt, CRI rating>70 suitable for input voltage AC 220-240 V, 50 Hz. complete with all accessories, connections, Testing and commissioning etc. as required Crompton Cat. No. CCR141-24-57-SL-	LED Panel 2'x2' 36 watt.	Providing and fixing of LED fixture 600mmx600mm36watt+/-1W surface mounted fixture with HET plastic diffuser with minimum system lumen efficacy of 100lm/W with CRCA housing having P.F.>0.95 with THD<10%, CRI 80. The LED with Useful life of 50000 Hrs at L70 with five years warranty. The LEDs used in the luminaire dhall have CCT of 2700 K with CRI of minimum 80. The Inpur voltage range shall be 150V to 270V, 50/60 HZ complete with all accessories, including connections, testing and commissioning etc. as required complete in all respects. (Make philips/Bajaj/Wipro.
		9			_	
		1570			4834	
		Thousand Five Hundred Seventy Only	Rupees One		Rupees Four Thousand Eight Hundred Thirty Four Only	
Bal		Each			Each	
		14130			4834	

17 1						
1	_	œ	2870	Rupees Two Thousand Eight	Each	22960
	Providing and installation of following type of surface mounting round			Only		
18	factor> 0.9, Harmonic Distortion <20% and efficacy>100 lumens per watt, CRI rating > 80, suitable for input voltage AC 220-240 V, 50/60 HZ complete with all accessories, including connections, testing and warranty.					
	Make:C&S./PanasonicAving					
	mana.custr anasonic/Wipro.					
18.1	Square/round LED Down light 12 Watt.	12	1050	Rupees One Thousand Fifty Only	Each	12600
19	Supplying and fixing call bell/Ding dong suitable for single phase, 230 volts, complete as required. Make:- SSK /Anchor/GoldMedal	10	117	Rupees One Hundred Seventeen Only	Each	1170
20	steel MCB distribution board, 240 volts, on surface / recess, complete with tinned copper bus- bar, wire-set, neutral link, earth bar, din-bar, interconnections, powder painted, including earthing etc. as required:- (But without MCB/RCCB/Isolator).Make:-L&T/Legrand/Schenider					
20.1	Double door-16 way	63	2954	Rupees Two Thousand Nine Hundred Fifty Four Only	Each	17724
22	Supplying and erection of 6 amps. to 32 amps. rating, 240/415 volts, 10 KA, 'C' curves, miniature circuit breaker suitable for inductive load: of following poles in the miniature circuit breaker suitable for inductive load of following poles in the existing MCB DB complete with connections testing and commissioning etc. as required:Make :- L&T/Legrand/Schenider					

		23.1	23	22.1	22	21.1
Total	Makes:-L&T/Legrand/Schneider	63 Amps.	Supplying and fixing following rating, double pole (single phase & neutral) 240 volts, residual current circuit breaker (RCCB), having a sensitivity current up to 300 miliampers in the existing MCB DB complete with connections, testing and commissioning etc. as requiredMake:-L&T/Legrand/Schenider	63 Amps.	the existing MCB DB complete with connections, testing and commissioning etc. as requiredMake:-L&T/Legrand/Schenider	Single pole.
1		6		6		51
		3616		616		265
387234		Rupees Three Thousand Six Hundred Sixteen Only		Rupees Six Hundred Sixteen Only		Rupees Two Hundred Sixty Five Only
)		Each		Each		Each
387234		21696		3696	111	13515

1/482138 444

3B,SSD 256G(Solid state drive),antiglare LED 3B0),integrated HD graphics,2Xusb 3.0,2Xusb Port,10/100/IPV6 Lan,USB Keyboard & USB 5peaker. One (01) Years onsite warranty.	RAM expandable upto 16GB,SSD 256G(Solid state drive),antiglare LED display with FHD(1920x1080),integrated HD graphics,2Xusb 3.0,2Xusb 2.0,Audio port/VGA/HDMI Port,10/100/IPV6 Lan,USB Keyboard & USB MOUSE USB Multimedia Speaker. One (01) Years onsite warranty. 650 VA Offine UPS system with (Make:-Vertiv Libert-ITON total: 168VAH)SMF batteries to provide 20 minutes battery backup (with 01 years warranty on UPS and batteries from delivery Date).
RAM expandable upto 16GB,SSD 256G(Solid state drive),antiglare LED display with FHD(1920x1080),integrated HD graphics,2Xusb 3.0,2Xusb 2.0,Audio port/VGA/HDMI Port,10/100/IPV6 Lan,USB Keyboard & USB MUltimedia Speaker. One (01) Years onsite warranty.	e LED 2Xusb 1 LUSB
	vith (Make:-Vertiv Libert-ITON total: vide 20 minutes battery backup (with 01 1 3000 atteries from delivery Date).

02-17 Schooling of Succentry chicales and

		SCHEDULE OF QUANTITY	QUAN	ATITA	207.00	2 04 171/-on	4
NAME (OF WORK :- Repair and g at Dehra in Tehsil Deh	tenance of Mini stt. Kangra(H.P	ö	Job No. 26	EARNEST MONEY: Rs.7700/-only TIME ALLOWED: One Month	.7700/-only	,
2 .0	AN OFS,AC S IN CM ONICE therein)	rein),	OTY	0	RATES	UNIT	AMOUNT
N 0		E GOOR TO LOW	4	FIGURES	WORDS		
	Supply, Installation, testin Online, DSP Controlled online,	Supply, Installation, testing and commissioning of 2KVA/2KW True Online, DSP Controlled online UPS with 1 phase AC input and 1 phase AC current with 60 min hanking with 12V SMF batteries Bank with Rack					
-	The UPS should be with IGBT Based Rectification both and with LCD Screen Display & LED in status along with same OEM make inbuilt is side. The job includes the cost of Supply, and testing charges including rack, connect required to complete the job Approved Make Emerson/EATON/ Legrand-Numeric Only.	The UPS should be with IGBT Based Rectifier and IGBT based Inverter both and with LCD Screen Display & LED indicators for monitoring of its status along with same OEM make inbuilt Isolation Transformer at input side. The job includes the cost of Supply, installation, commissioning and testing charges including rack, connecting and other petty material required to complete the job Approved Make: APC-Schneider/ Vertiv - Emerson/EATON/ Legrand-Numeric Only.	22	82239	Rupees Eighty Two Thousand Two Hundred Thirty Nine Only	P/Set	164478
	The UPS should have following specification.	wing specification.					
	Capacity in KVA/KW	2KVA/2KW					
	UPS System Description backup on SMF Batteries,M	UPS System Description 2 KVA True Online Pure Sine with 1 Hour backup on SMF Batteries,MS Rack, interconnection cable and wire from UPS to battery bank					
	input (Rectifier)						
	Primary source voltage	230 VAC 1 Phase					
	Input Voltage Range	180 - 290 V AC on 100% Load					
	Input Frequency Range	50-60Hz ± 5%					
	Input power factor	> 0 99					
	THDI rating	< 5% at full load					
	Output (Inverter)						
	DC volts	72 V /96 V as per OEM VDC Design					
20	Output voltage	230 VAC 1 Phase (adjustable to			-		
0	Output frequency	50 Hz /60 Hz (+/- 1%)		Ī			
0	Output Power Factor	Unity				-	
7	THD Voltage rating	< 2% for Linear load					

Supplying, erection, testing & commissioning of VRLA-AGM maintenance free Battery 12V SMF batteries for 60 Minutes back up VAH of 3200VAH (12VX8 No. of 34AH) extra lead acid battery with thicker tubes suitable for UPS (Including Battery rack) as required complete in	Supplying, erection, test maintenance free Batter of 3200VAH (12VX8 No. 2 tubes suitable for UPS () all respects and to the batter
Approved Make: APC- Schneider / Vertiv -Emerson/ Eaton/Legrand-Numeric Only for UPS & Exide, Quanta & Panasonic for SMF Batteries	Approved Make: APC Eaton/Legrand-Numeri for SMF Batteries
3 years on UPS & 3 years on Batteries	Warranty
Optional SNMP card for future up gradation	Network interface for web monitoring
Communications & other ports RS232 and USB and EPO feature	Communications & oth
EN-IEC 62040 1,2 & 3 certified product BIS – make in India & ROHS/PEP complied product	EN-IEC 62040 1,2 & 3 certifie ROHS/PEP complied product
0 to 40 Deg C	Ambient temperature
Mains Failure/Low battery /UPS Warning / s Mode etc.	Audible Alarm Mains F Overload/Fault & Bypass Mode etc
	display
Status on LED & LCD Normal Mode, Load on Battery, Load on Bypass, System Fault, load %age, output current, battery voltage	Status on LED & LCD Bypass, System Fault, lo
Min 1 Hour backup with atleast min	Back-up 3200VAH or higher
Should be inbuilt within the UPS System	Battery Management
Output Socket Min 2 no. of programmable IEC 6A socket & 2 Nos 6A Socket & 1No Terminal Block. The IEC output sockets can be programmed and configured to define load priority.	2 Nos 6A Socket & 1No Terminal Block The IEC programmed and configured to define load priority
CD display along with LED indicators	Display Panel
	Mode to battery mode)
Zero	Transfer Time (AC
Upto 94 %	ECO mode Efficiency
100 830%	-

4			cn-		O		۵	N	3.1	- Lai	2
Providing and patching CAT 6 patch cord UTP 2 meter of following colours as required complete in all respects matching specs given in Bidding Document	(Makes:- Belden /Panduit /Corning /Molex/Dlink)	White	Supplying, Installation and fixing information outlet of following colours as required complete in all respects matching specs given in Bidding Document.	(Makes:- Belden /Panduit /Corning /Molex/Dlink)	Providing and fixing Face plate Single Port, with plug in icons icon tree, write on labels in transparent plastic window- supplied with plate, should be UL listed, making connection, testing etc.as required complete in all respects.	(Makes:- Belden /Pandult /Corning /Molex/Dlink)	Providing and drawing LAN cable Cat 6, in existing PVC conduit casing and capping as required complete in all respects matching specs give in Bidding Document.	Makes:- Panasonic, Bajaj, Wipro	LED Panel 2'x2' 36 watt	Providing and Fixing of LED fixture 600mmX600mm 36 Watt +/- TW Surface/Recessed mounted fixture with HET Plastic diffuser with minimum system lumen efficacy of 100 lm/W with CRCA housing having P.F. > 0.95 with THD<10%, CRI 80. The LED with Useful life of 50000 Hrs at L70. The LEDs used in the luminaire shall have CCT of 5700 K with CRI of minimum 80. The Input voltage range shall be 150V to 270V, 50/60 HZ complete, with all accessories, including connections, testing and commissioning etc. as required complete in all respects.	Makes: Exide Power Safe/ Quanta 12V SMF (12VX8 No. of 34AH) Batteries for 60 Minutes backup or any other make approved by Engineer-in-Charge.
		cn .			CN CN		80		N		N
		315			130		65		5313		52035
		Rupees Three Hundred Fifteen Only			Rupees One Hundred Thirty Only		Rupees Sixty Five Only		Rupees Five Thousand Three Hundred Thirteen Only		Rupees Fifty Two Thousand Thirty Five Only
T		P/Set			P/Set		P/Mtr.		P/Set		P/Set
		1575			650		5200		10626		104070

		12		=		10		9	T	100		T
12				1.5%						æ		
Makes: Daikin (Model No. FTHT60 3* HOT & COLD INVERTER 1.8	A.C. Unit 1.8/2 Ton capacity	Supplying. Installing, Testing and Commisioning of Split Type Air Conditioner 1.8/2 TR 3 Star inverter SPLIT AIR CONDITIONER (Hot and Cold) confirming to I.S.I1391 Part-1992 with ammendent No. 1(expect power consumptions norms) fitted with Hermatically shielded Air Conditioner with installation & testing and commissioning etc. as rquired in all respects.	Makes:-Deeplast,BEC.	Supplying and fixing of following sizes of heavy class FRLS PVC conduit having wall thickness 2.0mm along with accessories insurface/recess including painting in case of surface conduit, or cutting the walland making good the same in case of recessed conduit as required.	(Makes:- Quantum/ Cisco/ ATI/ Dlink)	Supply, Installation, Testing and Commissioning of 8 Port GE PoE Switch web managed as required complete in all respects matching specs given in Bidding Document	(Makes:- Standard Make	Supplying, Installation Testing and commissioning of Rj-45 jacks as required to have complete solution in all respects and to best statisfaction of engineer in charge.	(Makes:- Comrack /Rittal /APC President /Dlink)	required complete in all respects matching specs given in Bidding Document	Providing and fixing of All Mail (Miolex/Dlink)	(Makes:- Belden /Panduit /Corning in
	-			65		-		O				හ
	67267			99		6950		55		4254		310
	Rupees Sixty Seven Thousand Two Hundred Sixty Seven Only			Rupees Ninety Nine Only		Rupees Six Thousand Nine Hundred Fifty Only		Rupees Fifty Five Only	City	Rupees Four Thousand Two Hundred Fifty Four		Rupees Three Hundred Ten Only
	Each			P/Mtr.		Each		Each		Each		Each
	67267			6435		6950		275		4254		1550

	ã	17	6	th	4		ä
Total	Providing and fixing PVC Trunking for covering of copper pipe of following size 105X50mm as required complete in all respects. Makes: Polyplast,Deeplast,BEC.	S/F of Drain pipe of size 1" Dia (25mm) complete with elbows tees, socket etc. of superior quality as per satisfacation of Engineer-In-Charge.	conductor, 2.5Sq,mm 3Core cable in the existing surface/ recessed steel/ PVCconduit as required	S/F of Copper tube with insulation for A C 1 8/2 TR capacity complete in all respects as required	1.8/2 TR split A.C with six Nos. Anchor bolts as required complete in all respects and as per direction of Engineer - in- charge.	Automatic Voltage Stabilizer 5KVA	with output 240 volts with voltage regulation range from 130 volt to with output 240 volts with voltage regulation range from 130 volt to 280 volts and auto cut off beyond this range and time delay operation for the surges and fluctuations suitable for 2 TR capacity split type Air-Conditioner including making connections etc. as required complete in all respects. Makes: Godrej, Whirlpool, Microtok.
	4	Ċħ.	W	*	-	4	
	1300	195	280	1350	950	5426	
	Rupees One Thousand Three Hundred Only	Rupees One Hundred Ninety Five Only	Rupees Two Hundred Eighty Only	Rupees One Thousand Three Hundred Fifty Only	Rupees Nine Hundred Fifty Only	Rupees Five Thousand Four Hundred Twenty Six Only	
	P/Mtr	P/ mtr	Р/Мп	P/ mtr	Each	Each	
384171	1300	975	840	1350	950	5426	

Scholule of quentily chulous and opprince for 2384171 was land

	1 Providing and including the problem of Dorests	NO.	SR.	Controller for 250 K of School Educatio	
	Providing and fixing AMF controller suitable for 250 KVA D G Set including the Lebour charges for callibration, repairing and rectifying the problem of DG Set making connections, etc. as required complete in all respects		DESCRIPTION	NAME OF WORK :-Replacement of burnt and damaged AMF Controller for 250 KVA D.G Set installed in the Complex of H.P Board of School Education Dharamshala in District Kangra (H.P.)	SCHEDULE OF QUANTITY
	-		QTY.	-	NAUC
	64731	FIGURES		job No 2	TITY
	Rupees Sixty Four Thousand Seven Hundred Thirty One Only	WORDS	RATES	ESTIMATED COST: Rs. 64,731/-only EARNEST MONEY: Rs.1300/-only TIME ALLOWED: Three Months	
	Each		TINU	.1300/-only .Months	
64/37	64731		AMOUNT	y.	

Schooling grap charles and spring fix answering

3	ω	N	4	SR.	RPGM Work,	
For doors windows and ventilators and glazed partitions frames.	Providing and fixing aluminium work for doors, windows, ventilators and partitions with extruded built up standard tubular sections/ appropriate Z sections and other sections of approved make conforming to IS: 733 and IS: 1285, fixing with dash fasteners of required dia and size, including necessary filling up the gaps at junctions, i.e. at top, bottom and sides with required EPDM rubber/ neoprene gasket etc. Aluminium sections shall be smooth, rust free, straight, mitred and jointed mechanically wherever required including cleat angle, Aluminium snap beading for glazing / paneling, C.P. brass / stainless steel screws, all complete as per architectural drawings and the directions of Engineer-incharge, (Glazing, paneling and dash fasteners to be paid for separately): Powder coated aluminium (minimum thickness of powder coating 50 micron)	15mm thick cement plasters in single coat on rough side of brick/concrete/stone walls for interior plastering upto all floor level including arises, internal rounded angles, chamfers and or rounded angles not exceeding 80mm in girth and linished even and smooth with cement mortar 1:6 (1 cement: 6 sand) upto floor two level	Providing and laying in position cement concrete of specified grade excluding the cost of centering and shuttering - All work up to plinth level 1:2:4 (1 cement: 2 coarse sand): 4 graded stone aggregate 20 mm nominal size)	DESCRIPTION	NAME OF WORK :- C/o Centre of Excellence in Mental Health for Dr. RPGMC Kangra at Tanda. (SH:-Providing and fixing steel work, Aluminium work, Plastering and Painting work in Lift room area of staff lift and Patient lift therein).	SCHEDULE OF QUANTITY
56.16		18.08	9,22	QTY.	oſ	QUA
560.00		241.20	5954.35	FIGURES	80 on do	YTITY
Rupees Five Hundred		Rupees Two Hundred Forty One and Twenty Paisas Only	Rupees Five Thousand Nine Hundred Fifty Four and Thirty Five Palsas Only	RATES	ESTIMATED COST: Rs.2,80,103/-only. EARNEST MONEY: Rs.5700/-only TIME ALLOWED: One Month	
Per Kg.		Per Sqm.	Per Cum	TINU	.2,80,103/-only .5700/-only Month	
31450		4361	54899	AMOUNT	nly.	

=	2	6	=	1,2	cn.	=	į ė	4	3
100 mm	125mm	Providing and fixing aluminium handles anodized transparent or dyed to required colour & shade with necessary screws etc.	250x10mm	200x10mm	Providing and fixing anodized aluminium tower bults (barrel type anodized trans parent or dyed to required shade and colour with screws etc. Complete.	250x10mm	300x10mm	Providing and fixing anodized aluminium sliding door bolts anodized transparent or dyed to required colour and shade with necessary screws etc. complete.	For shutters of doors, windows & ventilators including providing and fixing hinges/ pivots and making provision for fixing of fittings wherever required including the cost of EPDM rubber / neoprene gasket required (Fittings shall be paid for separately) Powder coated aluminium (minimum thickness of powder coating 50 micron)
2.00	2.00	5	2,00	2.00	B 42	2.00	2.00		56,16
50.75	57.55		370,15	296.35		99.20	112.46		540.00
Rupees Fifty and Seventy Five Paisas Only	Rupees Fifty Seven and Fifty Five Paisas Only		Rupees Three Hundred Seventy and Fifteen Paisas Only	Rupees Two Hundred Ninety Six and Thirty Five Palsas Only		Rupees Ninety Nine and Twenty Paisas Only	Rupees One Hundred Twelve and Forty Five Paisas Only		Rupees Five Hundred Forty Only
Each	Each		Each	Each		Each	Each		Per Kg
102	115		740	593		198	225		30326

I	12	=	10	ø	œ	7
Total	Painting two coats (excluding priming coat) on new steel and steel based surface under coat with enamel and finishing coating with flat oil paint, brushing to give an even shade including cleaning of all dirt, dust and other foreign matter, sand papering and stopping:- With paint other than white	Supplying and fixing expended metal to wood or steel members in partitions etc. Weight exceeding 3kg and not exceeding 5kg Per Square metre complete as directed by the Engineer-in-charge including entire carriage of materials within all leads, lifts and other incidentals.	Wall painting (Two coat) with plastic emulsion paint of approved brand and manufacture on undecorated wall surfaces to give an even shade including thoroughly bushing the surface free from mortar droppings and other foreign matter and sand papered smooth including applying of putty as required for marking the surface.	Providing and applying white cement based putty of average thickness 1 mm, of approved brand and manufacturer, over the plastered wall surface to prepare the surface even and smooth complete	noisting, fixing in position and applying a priming coat of approved steel primer using structural steel etc. as required in gratings, frames, guard bar, ladder, railings, brackets, gates and similar works	both side bwp phenol bonded exterior/interior grade panelled shutters including bright finished/black enamelled iron butt hinges with necessary screws complete
	28.74	17.14	595.28	595.28	278,88	10.08
	53.85	950.00	74.80	85.10	107,45	1400.00
	Rupees Fifty Three and Eighty Frve Paisas Only	Rupees Nine Hundred Fifty Only	Rupees Seventy Four and Eighty Paisas Only	Rupees Eighty Five and Ten Paisas Only	Rupees One Hundred Seven and Forty Five Paisas Only	Rupees One Thousand Four Hundred Only
	Per Sqm.	Per Sqm.	Per Sqm.	Per Sqm.	Per kg	Per Sqm.
280103	1548	16283	44527	50658	29966	14112

Seperate grandity checked and papersed for P.1280103-fort

	ω	N	4	30	SR.	RPGN	NAME
Total	Providing and fixing 0.60 mm thick pre painted plain steel sheet in partition with hot dipped mettalic zinc coated sheet with top coat of regular modified polyster (RNP) organic coating of 20 microns over 5 microns primer coating to black coat of polyster of 5 microns over 5 microns primer coating lic fixing with pre painted iron J or L hooks bolts and nuts 6mm Dia meter with pre painted limpet and rubber washers complete with all accessories as required complete in all respects.	Steel work welded in built up sections / frame work including cutting hoisting fixing in position and applying a priming coat of approved steel primer using strctural steel etc. as required in gratings frames, guard bar, ladder, railings, brackets, gates and similar works	of windows etc. with M.S. grills of required patterns in wooden frames of windows etc. with M.S. Flats, square or round bars with round headed bolts and nuts or by screws fixed ti steel windows by welding as requited complete in all respects.		DESCRIPTION	RPGMC Kangra at Tanda. (SH:-Providing and fixing steel and grill work in Fire Fighting pump Room at Basement floor therein).	SCHEDULE OF QUANT
	52.00	772.00	280.00		אום.	oľ	= QUA
	1490,10	117.60	188.00	FIGURES		by on gol	VTITY
	Rupees One Thousand Four Hundred Ninety and Ten Paisas Only	Rupees One Hundred Seventeen and Sixty Paisas Only	Rupees One Hundred Eighty Eight Only	\vdash	RATES	ESTIMATED COST: Rs.2,20,912/-only. EARNEST MONEY: Rs.4500/-only TIME ALLOWED:One Month	
	P/Sq.mtr	P/kgs.	P/kgs.		TINU	.2,20,912/-o .4500/-only Month	
220042	77485	90787	52640	1	AMOUNT	nly.	

Schoolute of quentity charbed and approved for \$220912 whole

Simc Kangra at Tanda, (RH: Replacement of old and damaged switch-kets, LEDs, fans etc. (room no. 201 to 216) and campus lights thereof) DESCRIPTION DESCRIPTION OTY. FIGURES Supplying and drawing following sizes of FRLS PVC insulated copper conductor, single core cable in the existing surface/ recessed steel/ PVCconduit as required. 1 3x1.5 Sq. mm. Makes:- Finolex/Anchor/Polycab Supplying and fixing following modular switch box including connections but excluding modular plate & switch box including connections but excluding modular plate etc. as required. 5/10 Amps. Modular switch 15/10 Amps. Modular switch 15/16 amp modular socket outlet Makes:- Legrand/L&T/Schneider Supplying and erection of MCB of following rating, 10 KA breaking capacity, 240 voits / 415 voits, 'C' curves, miniature circuit breaker of following poles in the existing MCB DB complete with connections etc. as following poles in the existing MCB DB complete with connections etc. as	NA NA	SCHEDULE OF QUANT	UANT	Ŧ	ECTIMATED CO.	AT. De
Supplying and drawing following sizes of FRLS PVC insulated copper conductor, single core cable in the existing surface/ recessed steel/ PVCconduit as required. 1 3x1.5 Sq. mm. Make:- Finolex/Anchor/Polycab Supplying and fixing following modular switch/socket on the existing modular plate & switch box including connections but excluding modular plate & switch box including connections but excluding modular surface/ 15/20 Amps. Modular switch 15/10 Amps. Modular switch 15/10 Amps. Modular switch 15/16 amp modular socket outlet	RPGN	NAME OF WORK :- Repair & Maintenance of E.I. to Vivekanand Hostel, Dr. RPGMC Kangra at Tanda. (SH: Replacement of old and damaged switchsockets, LEDs, fans etc. (room no. 201 to 216) and campus lights thereof)	Jot	30	EARNES TIME AL	ESTIMATED COST: Rs 2,23,492/-only. EARNEST MONEY: Rs.4500/-only \(\) TIME ALLOWED: Three Months
Supplying and drawing following sizes of FRLS PVC insulated copper conductor, single core cable in the existing surface/ recessed steel/ PVCconduit as required. 1 3x1.5 Sq. mm. Make:- Finolex/Anchor/Polycab Supplying and fixing following modular switch/socket on the existing modular plate & switch box including connections but excluding modular plate etc. as required. 5/10 Amps. Modular switch 15/20 Amps. Modular switch 15/20 Amps. Modular socket outlet 15/16 amp modular socket outlet 15/18.00	SR.	DESCRIPTION	QTY.		RATES	
Supplying and drawing following sizes of FRLS PVC insulated copper conductor, single core cable in the existing surface/ recessed steel/ PVCconduit as required. 1 3x1.5 Sq. mm. Make:- Finolex/Anchor/Polycab Supplying and fixing following modular switch/socket on the existing modular plate & switch box including connections but excluding modular plate etc. as required. 5/10 Amps. Modular switch 15/10 Amps. Modular switch 15/10 Amps. Modular switch 15/10 Amps. Modular socket outlet 15/16 amp modular socket outlet 15/17 136.00	NO.			FIGURES		WORDS
Make:- Finolex/Anchor/Polycab Supplying and fixing following modular switch/socket on the existing modular plate & switch box including connections but excluding modular plate etc. as required. 5/10 Amps. Modular switch 15/20 Amps. Modular switch 15/20 Amps. Modular switch 15/20 Amps. Modular socket outlet 15/16 amp modular socket outlet	1	Supplying and drawing following sizes of FRLS PVC insulated copper conductor, single core cable in the existing surface/ recessed steel/ PVCconduit as required.				
Make:- Finolex/Anchor/Polycab Supplying and fixing following modular switch/socket on the existing modular plate & switch box including connections but excluding modular plate etc. as required. 5/10 Amps. Modular switch 15/20 Amps. Modular switch 15/2	11	3x1.5 Sq. mm.	8	100.00	Rupee	Rupees One Hundred Only
Supplying and fixing following modular switch/socket on the existing modular plate & switch box including connections but excluding modular plate etc. as required. 5/10 Amps. Modular switch 15/20		Make:- Finolex/Anchor/Polycab				
15/10 Amps. Modular switch 15/20 Amps. Modular switch 15	N	Supplying and fixing following modular switch/socket on the existing modular plate & switch box including connections but excluding modular plate etc. as required.		=		
15/20 Amps. Modular switch 5/6 amp modular socket outlet 15/16 a	2.1	5/10 Amps. Modular switch	15	93.00	Rupe	Rupees Ninety Three Only
15/16 amp modular socket outlet 15/18 231.00	2.2	15/20 Amps. Modular switch	15.	164.00	Rupe	Rupees One Hundred Sixty Four Only
Makes:- Legrand/L&T/Schneider Supplying and erection of MCB of following rating, 10 KA breaking capacity, 240 volts / 415 volts, 'C' curves, miniature circuit breaker of following poles in the existing MCB DB complete with connections etc. as	2.3	5/6 amp modular socket outlet	⊂ ⁵	136.00	Rup	Rupees One Hundred Thirty Six Only
	2.4	15/16 amp modular socket outlet	12	231.00	Rup	Rupees Two Hundred Thirty One Only
		00			- 7	
		Supplying and erection of MCB of following rating, 10 KA breaking capacity, 240 volts / 415 volts, 'C' curves, miniature circuit breaker of following poles in the existing MCB DB complete with connections etc. as required.				

0	<u>51</u>	o	1	4	4	3
Providing and Fixing of IP20 LED fixture of 18 watt +/- 1 W LED Surface Mounted Downlighter Round Shape with minimum system lumen efficacy of 100 lm/W with Polycarbonate housing, pressure die cast heat sink and P.F.>0.95 with THD<10%, CRI 80.The LED shall be tested with LM80-08 standard with Useful life of 50000 Hrs at L70. The LEDs used in the luminaire shall have CCT of ANSI Bin 5700 K with CRI of minimum 80.The Input voltage range shall be 150V to 270V, 50/60 HZ complete with all accessories, including connections, testing and commissioning etc.as required complete in all respects. With 5 year warranty	Exhaust Fan, Light duty, (Domestic)	Providing and installation exhaust fan of following sizes in the existing opening, including making the hole to suit the size of the above fan, making good the damages, connections, testing and commissioning etc. as required:	Makes:- Usha/Havells/Bajaj	BLDC Ceiling Fan 1200 mm sweep	Makes:-Legrand/L&T/Schnelder Providing, Installation, testing and commissioning of BLDC ceiling fan (5 star rating), including wiring the down rods of standard length (up to 30 cm) with 16/0.20 mm twin twisted flexible, cotton braided, copper cable, including providing and fixing phenolic laminated sheet cover on the fan box and earthing etc. as required:	
	a 3		V	3	1	20
	2567.00			4323.00		239,00
	Rupees Two Thousand Five Hundred Sixty Seven Only			Rupees Four Thousand Three Hundred Twenty Three Only		Rupees Two Hundred Thirty Nine Only
	Each			Each		Each
	15402			12969		4780

9		8.1	œ		7.1	7	5
Supplying and fixing following size SMC Junction box suitable for pole mounting arrangement etc. as required.	Makes: Panasonic/Wipro/Havells	LED Street Light 70 Watt	Supplying and fixing of LED street light turninaire with the use of the latest technology 70 Watt (7000 lumens), 6500K made of CRCA housing and it should be compatible with specifications i.e. power factor ≥ 0.95, harmonic distortion ≤ 10% and efficacy ≥ 80 lumens per watt, CRI > 70, suitable for input voltage AC 150-270V, 50/60 Hz complete with all accessories, connections, testing and commissioning etc.as required. With 5 year warranty	Makes: Wipro/Panasonic/Havells	LED Batten Light of IP40 20W	Makes: Panasonic/Havells/ Wipro Providing and fixing LED Batten Light of IP40 LED fixture 20 W+/- 1W with Surface Mounted 4 Feet with Polycarbonate diffuser with Extruded aluminium housing having minimum system lumen output 1000 lumens and system lumen efficacy of 100 lm/W with P.F.>0.95 with THD<20% CRI 80. The LED with Useful life of 50000 Hrs at L70. The LEDs used in the luminaire shall have CCT of ANSI Bin 5700 K with CRI of minimum 80. The Input voltage range shall be 150V to 270V, 50/60 HZ complete with all accessories, including connections, testing and commissioning etc.as required complete in all respects. With 5 year warranty	LED Surface mounting round downlighter 18 Watt
		1			7 20		^ 20
		5573.00			1138.00		1821.00
	1000	Rupees Five Thousand Five Hundred Seventy Three Only			Rupees One Thousand One Hundred Thirty Eight Only		Rupees One Thousand Eight Hundred Twenty One Only
		Each			Each	¥1	Each
		39011			22760		36420

	1	1,01	10 9	T	>	9.1
otal	Total	Makes British 6 sq. mm (Twin Core)	grade of following sizes on wall surface as required.	roviding & laving of one	Makes: Sintex/Havells/Schoolde	SMC Junction box (230 x 170 x 105)
		350			1	7
		208.00				570.00
		Rupees Two Hundred Eight Only			Severity Only	Rupees Five Hundred
		Each				Each
223492		72800				3990

Selvente of quantity checked and approved for 2, 223492-20 bit

483594				7	
169124	Per Year	Rupees One Lacs Sixty Nine Thousand One Hundred Twenty Four Only	169124	٠	(iii For 3rd year. i.e. 2026-27
161070	Per Year	Rupees One Lacs Sixty One Thousand Seventy Only	161070	4	(ii) For 2nd year, i.e. 2025-26
153400	Per Year	Rupees One Lacs Fifty Three Thousand Four Hundred Only	153400	4	(I) For Ist Year, i.e. 2024-25
					(Machine No. L-08066)
					(v) Cost of lift attendent of Johnson company required on urgent basis during VVIP's visit on demand.
					(iv) The firm will provide emergency minor adjustment all back services 24 hours as all working days as well as holidays/ Sunday. The firm will maintain the lift in reliable and efficient operating connections.
					(III) Examine periodically all safety devices and governor and all customary safety test.

Schooling at Smouthy checker and opposed for 18334110/18

Exceptive Engineer
Electrical Division
HPPWD Palampur

NAME Superi Dehra,	NAME OF WORK :- Providing wiring for AE residence converted to Superintending Engineer Office(B&R) (First Floor) at Dehra in Tehsil job Dehra, Distt. Kangra(H.P.) DESCRIPTION OTY.	job		No 36	28	SEARNE AL RATES
SR.	DESCRIPTION	QTY.	_	FIGURES		WORDS
-	Wiring for light point/ fan point/ exhaust fan point/ call bell point with 1.5 sq.mm Wiring for light point/ fan point/ exhaust fan point/ call bell point with 1.5 sq.mm FRLS PVC insulated copper conductor single core cable in surface / recessed steel conduit, with modular switch, modular plate, suitable GI box and earthing the point with 1.5 sq.mm. FRLS PVC insulated copper conductor single core cable etc as required.					
	Group C. Makes: Legrand(Myrius),Schiender(Livia),Anchor Roma(Plus),L&T(Entice).	30		1202	Rupees One 1202 Thousand Two Hundred Two Only	
N	Wiring for Twin Control light point with 1.5 sq.mm FRLS PVC insulated copper conductor single core cable in surface / recessed steel conduit, with 2 Way modular switch, modular plate, suitable GI box and earthing the point with 1.5 sq.mm. FRLS PVC insulated copper conductor single core cable etc as required.					
-	Group C. Makes: Legrand(Myrius),Schiender(Livia),Anchor Roma(Plus),L&T(Entice).			1274	Rupees One Thousand Two 1274 Hundred Seventy Four Only	
ω	Wiring for circuit/ submain wiring alongwith earth wire with the following sizes of FRLS PVC insulated copper conductor, single core cable in surface/ recessed steel conduit as required			5 Ji II		
-	2X1.5Sq.mm+1X1.5Sq.mm Earth wire Makes: KEl/Anchor/Finolex/GrandLay.	30		198	198 Rupees One Hundred Ninety Eight Only	
4	Wiring for circuit/ submain wiring alongwith earth wire with the following sizes of FRLS PVC insulated copper conductor, single core cable in					

9		-	88		N	7	-	α α α <	-	5 1 8 S	3	1 23
Supplying and drawing following sizes of FRLS PVC insulated copper conductor, single core cable in the existing surface/ recessed steel/ PVC conduit as required.	Makes: KEllAnchor/Polycab/GrandLay.	2 X 10 sq. mm + 1 X 6 sq. mm earth wire	Wiring for circuit/ submain wiring alongwith earth wire with the following sizes of FRLS PVC insulated copper conductor, single core cable in surface/ recessed steel conduit as required	Makes: KEl/Anchor/Polycab/GrandLay.	2 X 6 sq. mm + 1 X 6 sq. mm earth wire	Wiring for circuit/ submain wiring alongwith earth wire with the following sizes of FRLS PVC insulated copper conductor, single core cable in surface/ recessed steel conduit as required	Makes: KEl/Anchor/Polycab/GrandLay.	Wiring for light/ power plug with 4X4 sq. mm FRLS PVC insulated copper conductor single core cable in surface/ recessed steel conduit alongwith 1 No 4 sq mm FRLS PVC insulated copper conductor single core cable for loop earthing as required.	Makes:KEUAnchor/Polycab/GrandLay.	Wiring for light/ power plug with 2X4 sq. mm FRLS PVC insulated copper conductor single core cable in surface/ recessed steel conduit alongwith 1 No 4 sq.mm FRLS PVC insulated copper conductor single core cable for loop earthing as required.	Makes: KEUAnchor/Polycab/GrandLay.	2X2.5Sq.mm+1X2.5Sq.mm Earth wire
		ā			20		15		25			35
		571			432		524		311			249
		Rupees Five Hundred Seventy One Only			Rupees Four Hundred Thirty Two Only		Rupees Five Hundred Twenty Four Only		Rupees Three Hundred Eleven Only			Rupees Two Hundred Forty Nine Only
		P/Mtr			P/Mtr		РЛИИ		P/Mtr			P/Mtr
		571			8640		7860		7775			3735

13		-	12	-	=	1		T	Г		
Supplying and fixing suitable size GI box with modular plate and cover in front on surface or in recess, including providing and fixing 25 amps modular socket outlet and 25 amps modular SP MCB "C" curve including connection painting etc. as required.	Makes:- Legrand(Myrius),L&T(Oris),Anchor Roma(Plus),L&T(Entice).	12 Module (200mmX150mm)	Supplying and fixing suitable size GI box with modular plate and cover in front on surface or in recess, including providing and fixing 3Nos-3 pin 5/6 amps modular socket outlet and 5/6 amps modular switch, connection etc. as required (For light plugs to be used in NR Buildings)	Makes: Legrand(Myrius), Schlender(Livia), Anchor Roma(Plus)	FRLSont on surface or in recess, including providing and fixing 6 pin 15/16 amps modular socket outlet and 15/16 amps modular socket outlet and 15/16 amps modular switch, connection etc as required.	Makes: Legrand(Myrius).Schiender(Livia),Anchor Roma(Plus)	front on surface or in recess, including providing and fixing 3 pin 5/6 etc. as required.	Makes: KEVAnchor/Polycab/GrandLay.	3X4Sq.mm		ii 3X2.5Sq.mm
		۵			cn		œ		20	30	4
		1191			621		469		220	367	100
		Rupees One Thousand One Hundred Ninety One Only			Rupees Six Hundred Twenty One Only		Rupees Four Hundred Saty Nine Only	Twenty Only	Rupees Two Hundred	Rupses One Hundred Fifty One Only	Rupees One Hundred Only
		Each			Eg		Each	P.M.	Date	PiMir	PAMIT
		4764			3105		3752	4400		4530	4000

-	19		18	_	17		-	_	T						1
	8 &	3	S S	3		2		6		-	6		-	4	-
Makes: & Til egrand/Schonider	Supplying and fixing Fan Regulator on the existing switch box including connection etc. as required.	Makes: Anchor/Goldmedal/SSK	Supplying and fixing batten/ angle holder including connection etc. as required.	Makes: Anchor/Goldmedal/SSK	Supplying and fixing Ding dong bell suitable for single phase, 230 volts, complete as required.	Makes: L&T, Legrand, Schenider	63 Amps. Cat-A.	Supplying and fixing following rating, double pole, (single phase and neutral), 240 volts, residual current circuit breaker (RCCB), having a sensitivity current 30 milli amperes in the existing MCB DB complete with connections, testing and commissioning etc. as required.	Makes: L&T, Legrand,Schenider	63 Amps. Cat-A.	Supplying and fixing following rating, double pole, 240 volts, isolator in the existing MCB DB complete with connections, testing and commissioning etc as required.	Makes: L&T, Legrand, Schenider	Single pole. Cat-A.	Supplying and erection of 6 amps to 32 amps, rating, 10 KA breaking capacity, 240 volts, 'C' curves, miniature circuit breaker of following poles in the existing MCB DB complete with connections etc. as required.	Makes:- Legrand(Myrius),Schiender(Livia),Anchor Roma(Plus),L&T(Entice).
	ω		2		4		2			N			12		1
	728		88		206		3104			530			239		705
	Rupees Seven Hundred Twenty Eight Only		Rupees Eighty Eight Only		Rupees Two Hundred Six Only		Rupees Three Thousand One Hundred Four Only			Rupees Five Hundred Thirty Only			Rupees Two Hundred Thirty Nine Only		Rupees Seven Hundred Five Only
	Each		Each		Each		Each			Each			Each		Each
	2184		176		824		6208			1060			2868		705

H	-	22	П			П	-
2	E	0 < 0 = 0		5	23	-	20
Makes:Winro Baiai & Panasonic	LED Round Downlighter (Surface) 18Watts	Providing and Fixing of IP20 LED fixture of 18 watt +/- 1 W LED Surface Mounted Downlighter Round Shape with minimum system lumen efficacy of 100 lm/W with Polycarbonate housing pressure die cast heat sink and P F >0.95 with THD<10%, CRI 80. The LED shall be tested with LM60-08 standard with Useful life of 50000 Hrs at L70. The LEDs used in the luminaire shall have CCT of ANSI Bin 5700 K with CRI of minimum 80. The Input voltage range shall be 150V to 270V, 50/60 HZ complete with all accessories, including connections, testing and commissioning etc. as required complete in all respects, with 5 year warranty	Makes:-Havells,Wipro,Bajaj.	LED Mirror Light 10Watts	Supplying and fixing of LED Batton/LED Mirror Light 10WAtts, 6500K (Five YEAR WARRANTY) and it should be compatible with specification e.i. Power Factor > 9. Harmonic Distortion<10% and efficacy >100 Lumens per watt, suitable for input voltage. AC 220-240 V, 50/60Hz, complete with all accessories, connections, testing and commissioning etc as required of Approved Makes. (Including 5 Years Warranty).	Makes: Anchor/Goldmedal, Havells.	Supplying and fixing LED bulb 0.5 Watts on the existing batten holder as required complete in all respects.
	o o			*			N
	1821			224			45
	Rupees One Thousand Eight Hundred Twenty One Only			Rupees Two Hundred Twenty Four Only			Rupees Forty Five Only
	Each			Each			Each
1	10926			224			90

25	=		12		2	23
Providing and Fixing of IP20 LED Surface mounted CRCA Powder Coated Box Type Channel with Pro LED Lamp Suitable for mounting 1 X 18 W LED Tube T8 type having minimum system efficacy of 100 lm/W. P.F.>0.95 with THD<10%, CCT 6500 K,CRI 80,Surge Protection 2 Kv The LED with Useful life of 50000 Hrs at L70. The Input voltage range shall be 150V to 270V, 50/60 HZ complete with all accessories, including connections, testing and commissioning etc.as required complete in all respects with 5 year warranty	Makes:Wipro,Bajaj & Panasonic.	LED 10 Watt Bulk Head	Providing and fixing of IP65 Bulkhead led fixture 10 W +/- 1 W Wall Mounted with minimum system lumen efficacy of 100 lm/W with Pressure Die Cast Aluminum housing, Polycarbonate Opal Diffuser and P.F.>0.95 with THD<10%, CRI 80 The LED shall be tested with LM80-08 standard with Useful life of 50000 Hrs at L70. The LEDs used in the luminaire shall have CCT of ANSI Bin 5700 K only with CRI of minimum 80. The Input voltage range shall be 140V to 280V, 50/60 HZ complete with all accessories, including connections, testing & commissioning etc.as required complete in all respects, with 5 year warranty.	Makes:Wipro,Bajaj & Panasonic.		Providing and Fixing of 1200 mm X 300 mm LED fixture 36 W +/- 1W Surface mounted fixture with HET Plastic diffuser with CRCA Powder Coated housing having minimum system lumen efficacy 100 m/W with P F >0.95 with THD<10%. The LED with Useful life of 50000 Hrs at L70. The LEDs used in the luminaire shall have CCT of 5700 K with CRI of minimum 80. The Input voltage range shall be 150V to 270V , 50/60 HZ complete, with all accessories, including connections, testing and commissioning etc as required complete in all respects with 5 year warranty.
		2			N	
		1420			3964	
		Rupees One Thousand Four Hundred Twenty Only			Rupees Three Thousand Nine Hundred Sixty Four Only	
		Each			Each	
		2840			7928	

	-	28	_	-	27	_		N		
Makes: L&T. Legrand, Schenider	Double door 2+12 way		ii Make:Usha(AEROCLI			ii Make:Usha, Bajaj & Cromptons		26 size by means of suitable rag-bott commissioning etc. as required co-satisfaction of Engineer-in-charge	ii Makes:Wipro,Bajaj & Havells	1 1
Schenider	Double door 2+12 way (MCCB+6+36) module:	Supplying and fixing of following way triple pole and neutral, sheet steel MCB distribution board, 415 volts, on surface / recess, with provision to mount 4 pole MCCB incomer, 2 module sub-incomer and SP MCBs as outgoing, complete with tinned copper bus- bar, wire-set, neutral link, earth bar, din-bar, detachable gland plate, cable, identification labels interconnections, phosphatized and powder painted, including earthing etc. as required.	Make: Usha (AEROCLEAN PLUS DBB), Bajaj, Crompton	Exhaust Fan, Light duty, (Domestic) 300 mm sweep	Providing and installation exhaust fan of following sizes in the existing opening including making the hole to suit the size of the above fan, making good thedamages, connections, testing and commissioning etc. as required.	romptons.	p p	Providing, Installation, testing and commissioning of wall fan of following size by means of sulfable rag-bott/ nuts, connections, testing and commissioning etc. as required complete in all respects to the best satisfaction of Engineer-in-charge.	Havells.	atts
	1			2			4			6
	13628		1	2567			3041			867
	Rupees Thirteen Thousand Six Hundred Twenty Eight Only			Rupees Two Thousand Five Hundred Sixty Seven Only			Rupees Three Thousand Forty One Only			Rupees Eight Hundred Sixty Seven Only
	Each			Each			Each			Each
	13628			5134			12164			346B

		u	w		177	
		31	30		-	29
The Dismental metrial deducted from the contractor that is Rs.1315/- in the Final will.	Total	Providing and fixing 4mm dia Cu wire on surface or in recess for loop earthing as required.	Earthing with copper earth plate 600 mm X 600 mm X 3 mm thick including accessories, and providing masonry enclosure with cover plate having locking arrangement and watering pipe of 2.7 metre long etc. with charcoal/ coke and salt as required.	Makes: L&T, Legrand, Schenider	100 A - 125A 18 KA	Providing and fixing following rating and breaking capacity MCCB with thermomagnetic release and terminal spreaders in existing cubicle panel board including drilling holes in cubicle panel, making connections, etc. as required.
		8	-		7	
		179	18856		6868	
		Rupees One Hundred Seventy Nine Only	Rupees Eighteen Thousand Eight Hundred Fifty Six Only		Rupees Six Thousand Eight Hundred Sixty Eight Only	
		P/Mtr	P/Set		Each	
	197927	5370	18856		6868	

Secretable Quantity checked and Approved for B1 197927-/only

Executive Engineer Electrical Division HPPWD Palampur

Wirin condu	Supp FRLS & 15 Connu (Livia	2 amp etc. Legr	i) Gro	sq., suit inst. KEI (My		NAME OF WORK: accessory, LED fit Complex building Distt Kangra (HP).	
Wiring for power plug with 2X4 sq. mm FRLS PVC insulated copper conductor single core cable in surface/ recessed steel conduit alongwith 1 No 4 sq. mm FRLS PVC insulated copper conductor single core cable for loop earthing as required. Make: KEI/Eincley/Archae	Supplying and fixing suitable size GI box with modular plate and cover in FRLSont on surface or in recess, including providing and fixing 6 pin 5/6 & 15/16 amps modular socket outlet and 15/16 amps modular switch, connection etc. as required. Make: Anchor (Roma Plus)/Schneider (Livia)/ Legrand (Myrius)/L&T(Entice).	Supplying and fixing suitable size GI box with modular plate and cover in front on surface or in recess, including providing and fixing 3 pin 5/6 amps modular socket outlet and 5/6 amps modular switch, connection etc. as required. Make: Anchor (Roma Plus)/Schneider (Livia)/Legrand (Myrius)/L&T(Entice).	Group B.	Wiring for light point/ fan point/ exhaust fan point/ call bell point with 1.5 sq.mm FRLS PVC insulated copper conductor single core cable in surface / recessed steel conduit, with modular switch, modular plate, suitable GI box and earthing the point with 1.5 sq.mm FRLS PVC insulated copper conductor single core cable etc. as required. Make: KEI/Plaza/Anchor/ Anchor (Roma Plus)/Schneider (Livia)/ Legrand (Myrius) /L&T(Entice).		NAME OF WORK :- Replacement of old accessory to modular accessory, LED fittings, exhaust fan, ceiling fan etc. at Court Complex building and Civil Judge -cum- JMFC residence, Indora, Distt Kangra (HP). DESCRIPTION	SCHEDULE OF QUANTITY
40	ω	o,	th .			QTY.	QUAI
484.00	769.00	601.00	1522.00		FIGURES	Job No	YTITY
Rupees Four Hundred Eighty Four Only	Rupees Seven Hundred Sixty Nine Only	Rupees Six Hundred One Only	Rupees One Thousand Five Hundred Twenty Two Only		WORDS	ESTIMATED COST: Rs. 1,67,520/jonly. EARNEST MONEY: Rs. 3400/-only TIME ALLOWED: One year RATES UNIT A	
Per Meter	each	each	Per Point			1,67,520/o .3400/-only ear	
19360	2307	3606	7610			AMOUNT	

	0	9		œ	0	7		T		Т		
	Ceiling Fan Plus)/Bajaj(M	standard le cotton braid laminated s	Providing.	as required			ii) 2 X 10 sc	10000	6 sizes of surface/	for loop	5 conduct	Wiring
	Ceiling Fan 1200 mm sweep (Make: Usha, Model: Technix Plus)/Bajaj(Model: Sabse Tezz Kassels)/Crompton(Model: WWHE).	mark with electronic fan regulator, including wiring the down rods of standard length (up to 30 cm) with 16/0.20 mm twin twisted flexible, cotton braided, copper cable, including providing and fixing phenolic laminated sheet cover on the fan box and earthing etc. as required.	Providing, Installation, testing and commissioning of ceiling for BLDC ISI	as required.Make :-GoldMedal/SSK/Anchor	, mm	conductor, single core cable in the existing surface/ recessed steel/ PVC conduit as required. Make: KEI/Finolex/Anchor.	2 X 10 sq. mm + 1 X 6 sq. mm earth wire	2 X 1.5 sq. mm + 1 X 1.5 sq. mm earth wire	witing for circuit/ submain wiring alongwith earth wire with the following sizes of FRLS PVC insulated copper conductor, single core cable in surface/ recessed steel conduit as required. Make: KEI/Finolex/Anchor.	for loop earthing as required. Make: KEUFinolex/Anchor.	conductor single core cable in surface/ recessed steel conduit alongwith 2 Nos 4 sq. mm FRLS PVC insulated copper conductor single core cable	Wiring for power plug with 4X4 sq. mm FRLS PVC insulated copper
	77		1	ω	20		œ	22			25	
	4397.00			99 00	112.00		808.00	346.00			767.00	
- C	Rupees Four Thousand Three Hundred Ninety Seven		Only	Rupees Ninety Nine	Rupees One Hundred Twelve Only		Rupees Eight Hundred Eight Only	Rupees Three Hundred Forty Six Only		S. S.	Rupees Seven Hundred Sixty Seven	
	Each		each		Per Meter		Per Meter	Per Meter			Per Meter	
	4397		297		2240		6464	7612			19175	

	ಸ		#		6
LED Down Light 15 watt, (Make: Jaquar Cat no. LNRP02R015SC/Bajaj/Crompton.	Providing and installation of Back Light (Non slim model)15 W +/- 1 W LED round Surface/recess Mounted Downlighter with minimum system lumen efficacy of ≥110 lm/W with and P.F.>0.95 with THD<10% ,CCT 5700 K,CRI 80.The LED with Useful life of 50000 Hrs at L70 with 5-years warranty. The Input voltage range shall be 150V to 270V , 50/60 HZ complete with all accessories, including connections, testing and commissioning etc.as required complete in all respects.	LED Batten 20W, 4 feet long (Make: Jaquar, cat no. LGLZ01X020XC)/Bajaj/Panasonic.	Providing and installation of IP20 Led fixture 20 W+I- 1W with Surface Mounted 4 Feet Batten Fixture with system efficacy ≥110lm/W with Aluminium housing P.F.>0.95 with THD<10% CCT 6500 K,CRI 80,Surge Protection 2 Kv.The LED with Useful life of 50000 Hrs at L70 with 5- years warranty. The Input voltage range shall be 150V to 270V, 50/60 HZ complete with all accessories, including connections, testing and commissioning etc. as required complete in all respects.	Exhaust Fan, Light duty, (Domestic) 300 mm sweep (Make: Usha, Model: Aeroclean LD)/Bajaj (Model: Freshee)/Anchor (Model: Anmol).	Providing and installation exhaust fan of following sizes in the existing opening, including making the hole to suit the size of the above fan, making good the damages, connections, testing and commissioning etc. as required.
11		8		cنه	
882.00		574.00		2309,00	
Rupees Eight Hundred Eighty Two Only		Rupees Five Hundred Sevenly Four Only		Rupees Two Thousand Three Hundred Nine Only	
Each		Each		Each	
9702		10332		6927	

	ō		ž.		ಪ
LED Panel Light 36 watt 1'x4' , (Make: Bajaj, Cat no. BZSSLL36L LED WH 1/Wipro/Panasonio).	Providing and installation of LED fixture 1200mmX300mm 36 W+/- 1W Surface Mounted with PMMA diffuser with having minimum system lumen efficacy ≥ 110lm/W with CRCA Housing and PMMA Diffuser with P.F.>0.95,THD<10%,CCT 5700 K. CRI 80.The LED shall be tested with LM80-08 standard with Useful life of 50000 Hrs at L70, with 5- years warranty. The Input voltage range shall be 150V to 270V, 50/60 HZ complete with all accessories, including connections, testing and commissioning etc.as required complete in all respects	Mirror light 10 Watt, 2 Feet Long Surface Mounted (at par with (Make: Jaquar, cat no. LGLZ01X010XC)/Bajaj/Panasonic.	Supplying & fixing following type of Surface mounted luminalizes, white power coated CRCA housing diffusser to avoid glaire, it should be compatible with specification i.e. Power Factor > 0.9, Harmonic Distortion < 20% and efficacy > 110 Lumens per watt, CRI rating> 70 with 5- years warranty, suitable for input voltage; AC 220-240 V, 50 Hz, complete with all accessories, connections, testing and commissioning etc. as required Make:-Jaquar/Bajaj/Panasonic.	LED Wall Bracket 9W (Make: Havells cat no. LHFOFUE11Z1W012)/ Phillips/Jaquar.	Supplying and fixing of LED wall Bracket having luminous flux 150 lumens, colour temp. 3000K, should be compatible with specification i.e. Power factor > 0.9, Harmonic distortion < 10% and efficacy > 100 lumens per wait, CRI rating>80. suitable for input voltage AC 220-240v, 50/60 HZ complete with all accessories, including connections,testing and commissioning etc.as required complete in all respect, with 5- years warranty Make-Havells/Philips/Jaquar.
4		N		00	
6754.00		473.00		812.00	
Rupees Six Thousand Seven Hundred Fifty Four Only		Rupees Four Hundred Seventy Three Only		Rupees Eight Hundred Twelve Only	
Each		each		Each	
27016		946		6496	

	18.5	18.4	18.3	18.2	18.1				
Sup					_	18	7	ij	6
Supplying & fixing Modular blanking plate on the existing modular metal box as required:- Make :- L&T/Anchor/Schenider	Modular base and cover plate, 18 module	Modular base and cover plate, 8 module	Modular base and cover plate, 6 module	Modular base and cover plate, 4 module	Modular base and cover plate, 3 module	Supplying & fixing following size modular base and cover plate on the existing modular metal boxes as required:- Make :- L&T/Anchor/Schenider	Supplying and erection of street light bracket made of G.I. pipe 'A' class of suitable length and dia, the pipe bended to give an angle of 100 to 110 degree fitted with boit & nuts at the top of existing pole or wall including painting the pipe with two coats of approved paint over priming coat complete in all respects as required:- Make:- TaTa/Jindal/Surya	LED Street Light 20 W (Make:- Havells Cat no. LHEXAYP7PN6K020	having cat No. LHEXAYP7PN6K020, powder coated pressure die-cast aluminium heat sink and toughened glass SMDLED streetlight with heat resistant toughened glass It should be compatible with specification i.e. power factor ≥ 0.9, Harmonic Distortion < 10% and efficiency ≥ 110 Lumens per watt, CRI rating> 70 with 5- years warranty, suitable for input voltage: AC 220-240 V, 50 Hz with all accessories, connections, testing and commissioning etc. as required. Make:-
6	7	N	15	1	6		_	٠,	
20	290	180	130	110	90		814.00	1616.00	
Rupees Twenty Only	Rupees Two Hundred Ninety Only	Rupees One Hundred Eighty Only	Rupees One Hundred Thirty Only	Rupees One Hundred Ten Only	Rupees Ninety Only		Rupees Eight Hundred Fourteen Only	Rupees One Thousand Six Hundred Sixteen Only	
Each	Each	Each	Each	Each	Each		Each	Each	
120	2030	360	1950	110	540		814	1616	

					_							
23	Ü	22	21	20	19.7	19.6	19.5	19.4	19.3	19.2	19.1	19
Supplying and fixing following rating, double pole, 240 V, isolator in the existing MCB DB complete with connections, testing and commissioning etc. as required.	Single pole (Make:-Schneider/ Legrand/L&T)	Supplying and fixing 6 A to 32 A rating, 240/415 V, 10 kA, "C" curve, miniature circuit breaker suitable for inductive load of following poles in the existing MCB DB complete with connections, testing and commissioning etc. as required.	Supplying and fixing 2C PVC wire 10 sq. mm. including making connections etc. as required.	Supplying and fixing stepped type Modular fan regulator on the existing modular box including making connections etc. as required. Make:-L&T/Legrand/Schenider	2 pin Modular Socket	Bell push, Modular.	S.P. 5/ 6 Amps two way Modular switch.	6 pin,15/16 Amps Modular socket outlet.	S.P. 15/ 16 Amps one way Modular switch.	5 pin, 5/ 6 Amps Modular socket outlet.	S.P. 5/6 Amps one way Modular switch.	existing switch box / cover plate including connections etc. as required. Make:-L&T/Anchor/Schenider
	#		55	7	2	-	22	12	12	24	60	
	272.00		40.00	465.00	90.00	150.00	105.00	180.00	130.00	85.00	30.00	
26	Rupees Two Hundred Seventy Two Only		Rupees Forty Only	Rupees Four Hundred Sixty Five Only	Rupees Ninety Only	Rupees One Hundred Fifty Only	Rupees One Hundred Five Only	Rupees One Hundred Eighty Only	Rupees One Hundred Thirty Only	Rupees Eighty Five Only	Rupees Thirty Only	
	Each		Per Meter	Each	Each	Each	Each	Each	Each	Each	Each	
	2992		2200	3255	180	150	210	2160	1560	2040	1800	

		25	=	24	0
The Dismental metrial deducted from the contractor that is Rs.	Total	Providing and fixing LED Bulb 9 watts to 10 watt in the exising fixture as requaired complete in all respect.	63 Amps. (Make:- Schneider/ Legrand/L&T)	neutral), 240 V, residual current circuit breaker (RCCB), having a sensitivity current 30 mA in the existing MCB DB complete with connections, testing and commissioning etc. as required.	63 Amps. (Make:- Schneider/ Legrand/L&T)
		ω	N		12
		150.00	3625.00		623.00
		Rupees One Hundred Fifty Only	Rupees Three Thousand Six Hundred Twenty Five Only		Rupees Six Hundred Twenty Three Only
		each	Each		Each
167520		450	7250		1246

Schedule of guerney chalant and grown fix 187520 which

Executive Engineer Electrical Division HPPWD Palampur

3 75 15 15 15	2	0	4	NO.	JMFC ; (No. II) Session	
Supplying and fixing metal box of 180mm X 100mm X 60mm deep (nominal size) on surface or in recess with suitable size of phenolic laminated sheet cover in front including providing and fixing 6 pin 5/6 & 16/16 A socket outlet and 15/16 A piano type switch, connections, painting etc. as required. Make: KEUPolycab/ GrandLay/Artchor (Roma Penta)/ Havells(Reo)/SSK	Supplying and fixing metal box of 150mm X 75mm X 60mm deep (nominal size) on surface or in recess with suitable size of phenolic laminated sheet cover in FRLSont including providing and fixing 3 pin 5/6 amps socket outlet and 5/6 amps piano type switch, connection, painting etc. as required. (For light plugs to be used in non residential buildings). Make: KEI/Polycab/GrandLay/ Anchor (Roma Penta)/HaveIls(Reo)/SSK	Group C.	Rewiring for light point/ fan point/ exhaust fan point/ call bell point with 1.5 sq.mm FRLS PVC insulated copper conductor single core cable and 1.5 sq.mm. FRLS PVC insulated copper conductor single core cable as earth wire in existing surface/recessed steel conduit including earthing the light point wioth 1.5sq.mm. HRFRLS/PVC insulated single core copper conductor cable including dismantling as required. (Including switch & bakelite sheet etc.) Make: KEl/Polycab/GrandLay/ Anchor (Roma Penta)/ Havelts(Reo)/SSK	DESCRIPTION	NAME OF WORK:- Providing replacement of E.I. to Civil Judge-cum- JMFC at Indora, LED fittings etc. to Civil Judge-cum-JMFC residence (No. II) and providing of DG supply to Additional District and Sessions Court at Nurpur, Distt. Kangra (HP)	SCHEDULE OF QUANT
N	N	m		617	_	QUAN
494.00	300.00	831.00		FIGURES	job No 34	TITY
Rupees Four Hundred Ninety Four Only	Rupees Three Hundred Only	Rupees Eight Hundred Thirty One Only		WORDS	ESTIMATED COST: Rs. 99,737/-only. EARNEST MONEY: Rs.2000/-only TIME ALLOWED: Two Years	
each	each	Per Point		0011	1. 99,737/-only 1.2000/-only 1.2000/-only	
988	600	4986		- Amount	awount.	

0	œ	0	4	3	3	=	a	on .	4
Providing and installation exhaust fan of following sizes in the existing opening, including making the hole to suit the size of the above fan, making good the damages, connections, testing and commissioning etc. as required.	Supplying and fixing bakelite batten/angle holder including connections etc. as required:- Make: Anchor/Gold Medal/SSK	3 x 1.5 sq. mm	Supplying and drawing following sizes of FRLS PVC insulated copper conductor, single core cable in the existing surface/ recessed steel/ PVC conduit as required. Make: KEI/Polycab/Anchor/GrandLay	2 X 10 sq. mm + 1 X 6 sq. mm earth wire	2 X 2.5 sq. mm + 1 X 2.5 sq. mm earth wire	2 X 1.5 sq. mm + 1 X 1.5 sq. mm earth wire	Wiring for circuit/ submain wiring alongwith earth wire with the following sizes of FRLS PVC insulated copper conductor, single core cable in surface/ recessed steel conduit as required. Make: KEI/Polycab/Anchor/GrandLay	Wiring for power plug with 4X4 sq. mm FRLS PVC insulated copper conductor single core cable in surface/ recessed steel conduit alongwith 2 Nos 4 sq. mm FRLS PVC insulated copper conductor single core cable for loop earthing as required. Make: KEI/Plaza/Anchor/SCI.	Wiring for power plug with 2X4 sq. mm FRLS PVC insulated copper conductor single core cable in surface/ recessed steel conduit alongwith 1 No 4 sq. mm FRLS PVC insulated copper conductor single core cable for loop earthing as required. Make: KEI/Polycab/Anchor/GrandLay
<u>υ ⊃ ω</u>	2	18	0.4	Ó	10	58		ದೆ	22
	105.00	112,00		800.00	401.00	340.00		761,00	478.00
	Rupees One Hundred Five Only	Rupees One Hundred Twelve Only		Rupees Eight Hundred Only	Rupees Four Hundred One Only	Rupees Three Hundred Forty Only		Rupees Seven Hundred Sixty One Only	Rupees Four Hundred F Seventy Eight Only
	each	Per Meter		Per Meter	Per Meter	Per Meter		Per Meter	Per Meter
	210	2016		4000	4010	19720		11415	10516

ಪ	3	ñ	3	4	5	10	3)
Providing and fixing LED Bulb 9 watts to 10 watt in the exising fixture as requaired complete in all respect. Make:- OSRAM/Philips/Bajaj	25 mm. dia	Supplying and fixing of following sizes of PVC conduit of medium class with 1.4 mm thickness along with the accessories in surface / racess including cutting the wall and making good the same in case of recessed conduit as required:- (Make: BEC Plast/Anchor/PolyFit).	25 mm. dia	Supplying and fixing of following sizes of steel conduit along with accessories in surface/recess including painting in case of surface conduit, or cutting the wall and making good the same in case of recessed conduit as required. (Make: Sidharth/BEC)	Mirror light 10 Watt, 2 Feet Long Surface Mounted (at par with (Make: Jaquar, cat no. LGLZ01X010XC)/Bajaj/Panasonic.	power coated CRCA housing tiffusser to avoid glaire, it should be power coated CRCA housing diffusser to avoid glaire, it should be compatible with specification i.e. Power Factor > 0.9, Harmonic Distortion < 20% and efficacy > 110 Lumens per watt, CRI rating> 70 suitable for input voltage: AC 220-240 V, 50 Hz, complete with all accessories, connections, testing and commissioning etc. as required, with 5 year warranty. Make:-Jaquar/Bajaj/Panasonic.	Exhaust Fan, Light duty, (Domestic) 225 mm sweep (Make: Usha, Model: Aeroclean LD)/Bajaj (Model: Freshee)/Crompton
N	4		4		N		+
150.00	116.00		270.00		470.00		1964.00
Rupees One Hundred Fifty Only	Rupees One Hundred Sixteen Only		Rupees Two Hundred Seventy Only		Rupees Four Hundred Seventy Only		Rupees One Thousand Nine Hundred Sixty Four Only
each	Per Meter		Per Meter		each		Each
300	464		1080		940		1964

8	ij	17	J)	16	0	i i		74
Providing and errection of LED 20 watt street light luminaries of Crompton Greaves Electric having cat No. Jordening code LSTS-20-CDL-M, powder coated pressure die-cast aliminium SMDLED streetlight with heat resistant toughened glass it should be compatible with specification l.e. power factor > 0.9, Harmonic Distortion < 10% and efficiency > 100 Lumens per watt, CRI rating> 70 suitable for input voltage: AC 220-240 V, 50 Hz,including connection, testing and commissioning etc. as required.with 5 year warranty.	20 mmx 12 mm	Providing and fixing of following sizes of PVC casing and capping on surface as required:-Make:- PolyFit/Deplast	Unarmoured cable 10 sq. mm (twin core)	Providing, laying and fixing of one No. aluminium conductor, PVC insulated and PVC sheathed, unarmoured cable, working voltage 1100 volts grade on surface etc. of the required size:-Make >- KEI/Havells/Polycab	32 A DP, On Load Change over switch (SS Enclosure type)	Providing and fixing following rating, two pole, 240 volts, On- Load change over switch unit, in sheet steel enclosure, with side handle operation, including drilling holes on the board, making connections, etc. as required. Make:-L&T/Legrand/Schenlder	Armoured cable 6 sq. mm (Twin core)	Providing & Laying of one number aluminium conductor, PVC insulated and PVC sheathed armoured/ XLPE power cable, 1.1 KV grade of following sizes direct in ground including excavation, sand cushioning, protective covering and refilling the trench etc as require (Make:- KEI/ Polycab/Havells/GrandLay).
	2		90		4		19	
	30.00		50.00		2800,00		480.00	
	Rupees Thirty Only		Rupees Fifty Only		Rupees Two Thousand Eight Hundred Only		Rupees Four Hundred Eighty Only	
	Per meler		Per R.Mtr.		each		Per R.Mtr.	
	60		4500	T	2800		9120	

3		ū	22		20		19	
6 pin 15/16 amps socket outlet	3 pin 5/6 amps socket outlet	15/16 amps switch	Supplying and fixing following plane type switch/ socket on the existing switch box/ cover including connections etc. as required. Make :- Anchor/L&T/Legrand	LED Batten 20W, 4 feet long Make: Crompton (Cat no. CCS-180-20-65-HL2-DP-NWH)/Bajaj/W/pro	Supplying & fixing following type of Surface mounted luminaires, white power coated CRCA housing diffusser to avoid glaire, it should be compatible with specification i.e. Power Factor > 0.9, Harmonic Distortion < 10% and efficacy >100 Lumens per watt, CRI rating >70 suitable for input voltage; AC 220-240 V, 50 Hz, complete with all accessories, connections, testing and commissioning etc. as required, with 5 year warranty.	40 mm dia. G.I. pipe, heavy class	of suitable length and dia, the pipe bended to give an angle of 100 to 110 degree fitted with bolt & nuts at the top of existing pole or wall including painting the pipe with two coats of approved paint over priming coat complete in all respects as required:-	Street light fixture 20 watt LED with Lens, Make: Crompton (cat No. LSTS-20-CDL-M)/Bajaj/Wipro
N	2	2		2		4		4
149.00	45.00	138.00		764.00		801.00		1905,00
Rupees One Hundred Forty Nine Only	Rupees Forty Five Only	Rupees One Hundred Thirty Eight Only		Rupees Seven Hundred Sixty Four Only		Rupees Eight Hundred One Only		Thousand Nine Hundred Five Only
each	each	each		each		each		each
298	90	276		1528		3204		7620

	3		22
Total	requaired complete in all respect.Make:- Philips/Bajaj/Havells	LED Post Top light - 20 watt (Moon Opal, 250), Make:- Havells (Cat. No. LHFXBON1TN5Q020) /Twinkle/K-Lite	powder coated pressure die-cast aluminium with heat resistant toughened glass including connections, testing and commissioning etc. as required. Twinkle/K-Lite
	4	4	
	415.00	1343.00	
	Rupees Four Hundred Fifteen Only	Rupees One Thousand Three Hundred Forty Three Only	
	each	each	
99737	1660	5372	

Schedule of grundity checked and approved for R-s 99737 tonly

Executive Engineer Electrical/Division HPPWD Palampur

4.0 S	3.0	ij	2.0		1)	1.0		NO.	Fish	NAN
S/F of Copper tube (1/4"x 1/2") with insulation for A.C 1.5 TR capacity complete in all respects as required.	P/F of M.S out door heavy duty stand powder coated suitable to hang 1.5/2 TR split A.C with six Nos. Anchor bolts as required complete in all respects and as per direction of Engineer - in- charge.	Make: Whirlpool (CAT No. WPLM 1340S Digital 12 Amp, 130 to 280 Volt)/ Voltas/V-Guard.	type with output 240 Volts with voltage regulator range from 130 volts to 280 volts and Auto cut off beyond this range and time delay operation for the surges and fluctuations suitable for 1.5 TR capacity Split AC making connections etc. as required.	Makes: Daikin 1.5 Ton (Hot &Cold) Invertor Split type (Model No. : FTHT50, 3 star/Mitsubishi/Voltas	A.C. Unit 1.5 Ton capacity	0 = -	Supplying, installation, testing and commissioning	DESCRIPTION	Conditioner (Hot & Cold type) in the office of Assistant Director Fisheries, Division Pong Dam in Tehsil Fatehpur Distt. Kangra HP.	NAME OF WORK :- Providing and fixing Split top 15 THEDULE OF QUANTITY
5	ω	ω		ω				QTY.	_	FQUA
1250	950	5327		56857			FIGURES		N S B N	YTITN
Rupees One Thousand Two Hundred Fifty Only	Rupees Nine Hundred Fifty Only	Rupees Five Thousand Three Hundred Twenty Seven Only		Rupees Fifty Six Thousand Eight Hundred Fifty Seven Only			\vdash	RATES	ESTIMATED COST: Rs.2,48,597/-only. EARNEST MONEY: Rs.5000/-only TIME ALLOWED: Three Months	
p/Mtr.	Each	Each		Each			0111	TINIT	.2,48,597/-on .5000/-only Months	
18750	2850	15981		170571			AMOUNT	AMOUNT	ıly.	

ij	8.00	=	7,00	=	6,00		3	5,00
2 X 6 sq. mm + 1 X 6 sq. mm earth wire	Wiring for circuit/ submain wiring alongwith earth wire with the following sizes of FRLS PVC insulated copper conductor, single core cable in surface/ recessed heavy class PVC conduit having wall thickness 2.0mm as required. Make: KEI/Polycab/Anchor/GrandLay	4 X 4 sq. mm + 2 X 4 sq. mm earth wire	sizes of FRLS PVC insulated copper conductor, single core cable in surface/ recessed heavy class PVC conduit having wall thickness 2.0mm as required. Make: KEI/Polycab/Anchor/GrandLay	Wiring for circuit/ submain wiring alcounts		Wiring for circuit submain wiring alongwith earth wire with the following	25 mm. día	with 1.4 mm thickness along with the accessories in surface / recess conduit as required:- (Make: BEC Plast/Anchor)
15		25		40		5		
432		524		311		86		
Rupees Four Hundred Thirty Two Only		Rupees Five Hundred Twenty Four Only		Rupees Three Hundred Eleven Only		Only	Dispose Nine	
P/Mtr		P/Mu		PIMIL		P/Mtr.		
6480		13100		12440		1683		

	12,00	0	11.00	8	10.00	3	9,00
	Supplying & fixing suitable size GI box with modular plate and cover in front on surface or in recess i/c providing and fixing 25 amp modular socket outlet and 25 Amps modular SP MCB, "C" curve including connection, painting etc. as required. Make: Anchor (Roma Plus)/Schneider (Livia)/ Legrand (Myrlus)/L&T(Entice).	Double door-4 way (Make:- Schneider/ Legrand/L&T)	Supplying and fixing following way, single pole and neutral, sheet steet, MCB distribution board, 240 V, on surface/ recess, complete with tinned copper bus bar, neutral bus bar, earth bar, din bar, interconnections, powder painted including earthing etc. as required (But without MCB/RCCB/Isolator)	63 Amps. (Make:- Schneider/ Legrand/L&T)	Supplying and fixing following rating, double pole, 240 V, Isolator in the existing MCB DB complete with connections, testing and commissioning etc. as required.	Single pole (Make:- Schneider/ Legrand/L&T)	miniature circuit breaker suitable for inductive load of following poles in the existing MCB DB complete with connections, testing and commissioning etc. as required.
i	ω	N		2		ω	
	705.00	1425		90,00		239.00	
	Rupees Seven Hundred Five Only	Rupees One Thousand Four Hundred Twenty Five Only		Rupees Five Hundred Thirty Only		Rupees Two Hundred Thirty Nine Only	
	each	each	141	each		each	
248597	2115	2850		1080		717	

Solvetiles & Shortily checked and opproved for 248 SON-010g

Executive Engineer
Electrical Division
HPPWD Palampur

Havells/KEI/Phinolex make Wiring for light/ power plug with 2X4 sq. mm FRLS PVC insulated copper conductor single core cable in surface/ recessed steel conduit alongwith 1 No 4 sq. mm FRLS PVC insulated copper conductor single core cable for loop earthing as required. Havells/KEI/Phinolex make Wiring for light/ power plug with 4X4 sq. mm FRLS PVC insulated copper conductor single core cable in surface/ recessed steel conduit alongwith 2 Nos 4 sq. mm FRLS PVC insulated copper conductor single core cable for loop earthing as required. Havells/KEI/Phinolex make Wiring for circuit/ submain wiring alongwith earth wire with the following sizes of FRLS PVC insulated copper conductor, single core cable in surface/ recessed steel conduit as required		1	Havells/KEI/Phinolex make	Group c	Wiring for light point/ fan poi sq mm FRLS PVC insulated surface / recessed steel con suitable GI box and earthing insulated copper conductor s	NO.	SR.	NAME OF WORK :- Providing & Fixing Power wiring, geyser, Exhaust fan etc. in in OT Room (3rd Floor) in Additional Block Civil Hosptal at palampurTehsil Palampur in Distt. Kangra (HP)	
sizes of FRLS PVC insulated copper conductor, single core cable in surface/ recessed steel conduit as required	in alana ith and the sallander	Wiring for light/ power plug with 4X4 sq. mm FRLS PVC insulated copper conductor single core cable in surface/ recessed steel conduit alongwith 2 Nos 4 sq. mm FRLS PVC insulated copper conductor single core cable for loop earthing as required.	Wiring for light/ power plug with 2X4 sq. mm FRLS PVC insulated copper conductor single core cable in surface/ recessed steel conduit alongwith 1 No 4 sq. mm FRLS PVC insulated copper conductor single core cable for loop earthing as required.		Wiring for light point/ fan point/ exhaust fan point/ call bell point with 1.5 sq mm FRLS PVC insulated copper conductor single core cable in surface / recessed steel conduit, with modular switch, modular plate, suitable GI box and earthing the point with 1.5 sq.mm, FRLS PVC insulated copper conductor single core cable etc as required.		DESCRIPTION	NAME OF WORK :- Providing & Fixing Power wiring , geyser , Exhaust fan etc. in in OT Room (3rd Floor) in Additional Block in Civil Hosptal at palampurTehsil Palampur in Distt. Kangra (HP)	SCHEDULE OF QUANTI
		32	40	i i			QTY.	-	= QUA
-		703	395	1588		FIGURES		Job No	NTITY
Rupees Three		Rupees Seven Hundred Three Only	Rupees Three Hundred Ninety Five Only	Rupees One Thousand Five Hundred Eighty Eight Only		WORDS	RATES	ESTIMATED COST: Rs.2,70,950/-only. EARNEST MONEY: Rs.5500/-only TIME ALLOWED: Two Months	
PIMIT		P/Mtr.	P/Mtr.	Per point			TINU	2,70,950/-orly s.5500/-only Months	
8300		22496	15800	22232			AMOUNT	ıly.	

ø		00		7	-	a		-	th		-
Providing, Installation, testing and commissioning of ceiling fan with regulator, including wiring the down rods of standard length (up to 30 cm) with 16/0.20 mm twin twisted flexible, cotton braided, copper cable, including providing and fixing phenolic laminated sheet cover on the fan how and earthing etc. as required.	Make :- Schenider/L&T/Legrand	Supplying and fixing suitable size G I box with modular plate and cover in front on surface or in recess including providing and fixing 6 pin 15/16 amps, modular switch, connections etc. as required.	Make :- Schenider/L&T/Legrand	Supplying and fixing suitable size G I box with modular plate and cover in front on surface or in recess including providing and fixing 3 pin 5/6 amps modular socket outlet and 5/6 amps, modular switch, connections etc. as required.	4 X 10 sq. mm + 2 X 6 sq. mm earth wire	Wiring for circuit submain wiring alongwith earth wire with the following sizes of FRLS PVC insulated copper conductor, single core cable in surface/ recessed steel conduit as required	Havells/KEI/Phinolex make	3x2.5 sq mm	Supplying and drawing following sizes of FRLS PVC insulated copper conductor, single core cable in the existing surface/ recessed steel PVC conduit as required	Havells/KEI/Phinolex make	2 X 10 sq. mm + 1 X 6 sq. mm earth wire
		ω		11	72			26			ω
		621		469	1197			151		×	898
		Rupees Six Hundred Twenty One Only		Rupees Four Hundred Sixty Nine Only	Ruppes One Thousand One Hundred Ninety Seven Only			Rupees One Hundred Fifty One Only			Rupees Six Hundred Ninely Six Only
		Each.		Each.	P/Mtr.			P/Mtr.			P/Mir
		5589		5159	86184			3926			2088

~	12		-	=		-	10		-
100 amps 18 k	Providing and fixing following rating and breaking capacity MCCB with thermomagnetic release and terminal spreaders in existing cubicle panel board including drilling holes in cubicle panel, making connections, etc. as required.	Makes :-Wipro (Cat No :-LD80-171-xxx-60-SM/Phlips/Bajaj	LED Surface mounting round downlighter 12 watt	Providing and installation of LED fixture 12 W +/- 1 W LED Square Surface Mounted Downlighter Round Shape with minimum system lumen efficacy of 85 lm/W with and P. F ≥ 0.95 with THD <20%, CCT 6000 K,CRI 80, The LED with useful life of 50000 Hrs at L70. The input voltage range shall be 150V to 270V with 5 year warranty.	Make:- Usha/Bajaj/Havells	Exhaust Fan, Light duty, (Domestic) 300 mm sweep	Providing and installation of exhaust fan of following sizes in the existing opening, including making the hole to suit the size of the above fan, making good the damages, connections, testing and commissioning etc. as required:-	Makes :-Ceiling Fan 1200 mm sweep, Category-A usha Technix Plus 5 Star,Philips,Bajaj	Ceiling Fan 1200 mm sweep, Category-A
a	L		N			œ			
6868			1412			2267			4323
Rupees Six Thousand Eight Hundred Sixty Eight Only			Rupees One Thousand Four Hundred Twelve Only			Rupees Two Thousand Two Hundred Sixty Seven Only			Rupees Four Thousand Three Hundred Twenty Three Only
Each			Each			Each			Each
6868			2824			18136			4323

6		-	th		=1	-	7		\mathbb{R}^{2}	ä
Supplying and fixing following rating, double pole (single phase & neutral) 240 volts, residual current circuit breaker (RCCB), having a sensitivity current up to 300 miliampers in the existing MCB DB complete with connections, testing and commissioning etc. as required.	L&T/Legrand/Schneider make	63 Amps. Cat-A.	Supplying and fixing following rating, double pole, 240 volts, isolator in the existing MCB DB complete with connections, testing and commissioning etc. as required.	L&T/Legrand/Schneider make	16 Amp Single pole. Cat-A.	6 Amp Single pole. Cat-A.	Supplying and fixing of 6 amps, to 32 amps, rating, 240/415 volts,10 kA 'C' curves, miniature circuit breaker suitable for inductive load of following poles in the existing miniature circuit breaker suitable for inductive load of following poles in the existing MCB DB complete with connections testing and commissioning etc. as required:-	L&T/Legrand/Schneider make	Double door-12 way	Supplying and fixing of following way, single pole and neutral sheet steel MCB distribution board, 240 volts, on surface / recess, complete with tinned copper bus- bar, neutral link, earth bar, din-bar, interconnections, powder painted, including earthing etc. as required; (But without MCB/RCCB/Isolator)
U W X		à			(5)	4			ے	
		530			239	239			2055	
		Rupees Five Hundred Thirty Only			Rupees Two Hundred Thirty Nine Only	Rupees Two Hundred Thirty Nine Only			Rupees Two Thousand Fifty Five Only	
		Each			Each	Each			Each	
		530			1434	958			2055	

			18		-	17		-
Total	Make :- Havells/ KEI/ Phinolex	Armoured cable 50 sq. mm (3.5 core)	Providing & Laying of one number aluminium conductor, PVC insulated and PVC sheathed armoured/ XLPE power cable, 1.1 KV grade of following sizes on wall surface as required.	Make :- Baja/ / Crompton/Usha	25 Liter capacity water heater (Cat-A)	Providing and installation of stationary storage type Electric water heater (Geyser) of various sizes by means of expansion-bolts with nuts and washers, including embedding of expansion-bolts in the wall, making good the damages, electrical connections, testing etc. complete as required:-	L&T/Legrand/Schneider make	63 Amps. Cat-A.
			60		-			4
			769		12806			3104
			Rupees Seven Hundred Sixty Nine Only		Rupees Twelve Thousand Eight Hundred Six Only			Rupees Three Thousand One Hundred Four Only
			P/Mtr.		Each			Each
270950			46140		12806			3104

Schedule of Guantisty checked and Affrond for R.s 270950-forty. Executive Engineer HPPWAR Electrical physician